

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月22日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 0.64 | 6.21 | 60.32 | 2.65 | 15.03 | 12.45 | 1.46 | 69866.00 |
| 1 | 1.26 | 7.60 | 56.02 | 2.75 | 14.69 | 12.10 | 1.46 | 73001.55 |
| 2 | 2.14 | 6.35 | 47.50 | 2.70 | 15.22 | 12.28 | 1.46 | 71550.32 |
| 3 | 7.92 | 10.07 | 51.68 | 3.97 | 12.94 | 12.49 | 1.46 | 71498.76 |
| 4 | 10.68 | 4.71 | 48.94 | 4.44 | 12.55 | 12.67 | 1.46 | 70044.54 |
| 5 | 6.77 | 4.62 | 55.11 | 2.91 | 14.21 | 12.30 | 1.46 | 65247.37 |
| 6 | 8.71 | 5.57 | 48.70 | 3.71 | 13.16 | 12.44 | 1.46 | 71370.27 |
| 7 | 8.17 | 6.59 | 50.22 | 3.65 | 13.38 | 12.51 | 1.46 | 71040.68 |
| 8 | 7.93 | 4.88 | 53.27 | 3.87 | 12.96 | 12.65 | 1.47 | 70197.59 |
| 9 | 9.57 | 4.61 | 55.88 | 3.68 | 13.44 | 12.58 | 1.45 | 70387.32 |
| 10 | 11.01 | 5.39 | 50.38 | 4.16 | 12.76 | 12.83 | 1.45 | 68249.94 |
| 11 | 8.64 | 6.04 | 51.60 | 3.89 | 13.29 | 12.69 | 1.47 | 68915.78 |
| 12 | 9.04 | 5.40 | 54.64 | 4.05 | 13.05 | 12.72 | 1.44 | 69094.12 |
| 13 | 8.77 | 4.65 | 53.04 | 3.84 | 13.15 | 12.74 | 1.42 | 69291.85 |
| 14 | 9.08 | 6.33 | 53.04 | 4.18 | 12.77 | 12.96 | 1.42 | 67064.77 |
| 15 | 9.95 | 8.07 | 52.91 | 3.73 | 13.27 | 12.68 | 1.42 | 69231.49 |
| 16 | 10.21 | 7.10 | 53.46 | 3.58 | 13.86 | 12.51 | 1.41 | 70406.59 |
| 17 | 12.89 | 6.76 | 53.55 | 3.78 | 13.46 | 12.59 | 1.42 | 69999.97 |
| 18 | 10.16 | 3.78 | 60.97 | 2.68 | 15.15 | 12.22 | 1.46 | 72080.50 |
| 19 | 11.85 | 7.40 | 53.04 | 3.90 | 12.97 | 12.67 | 1.48 | 69928.62 |
| 20 | 13.04 | 7.43 | 60.23 | 3.51 | 13.84 | 12.44 | 1.48 | 70991.86 |
| 21 | 12.58 | 8.33 | 61.76 | 3.19 | 14.24 | 12.40 | 1.49 | 71162.45 |
| 22 | 10.10 | 9.13 | 48.27 | 3.52 | 13.81 | 12.49 | 1.49 | 70968.02 |
| 23 | 10.36 | 7.62 | 54.55 | 3.56 | 13.59 | 12.55 | 1.49 | 70649.58 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 8.81 | 6.44 | 53.71 | 3.58 | 13.62 | 12.54 | 1.46 | 70093.33 |
| 最大值 | 13.04 | 10.07 | 61.76 | 4.44 | 15.22 | 12.96 | 1.50 | 73001.55 |
| 發生時間 | 20 | 3 | 21 | 4 | 2 | 14 | | 1 |
| 最小值 | 0.64 | 3.78 | 47.50 | 2.65 | 12.55 | 12.10 | 1.41 | 65247.37 |
| 發生時間 | 0 | 18 | 2 | 0 | 4 | 1 | | 5 |
| 零點偏移(率) | -0.02 % | 0.00 % | -0.10 % | 0.00 % | | 0.00 | 0.00 | 0.00 % |
| 全幅偏移(率) | 2.86 % | 0.00 % | -0.19 % | 0.07 % | | 0.30 | -0.03 | 0.40 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月22日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 4.66 | 6.92 | 39.05 | 0.89 | 20.05 | 9.67 | 1.43 | 90453.75 |
| 1 | 7.52 | 9.85 | 45.25 | 1.70 | 17.28 | 10.47 | 1.43 | 85470.56 |
| 2 | 6.36 | 3.40 | 52.77 | 1.69 | 17.28 | 10.65 | 1.43 | 81003.86 |
| 3 | 9.93 | 3.54 | 53.46 | 1.49 | 18.79 | 10.32 | 1.45 | 84232.44 |
| 4 | 8.49 | 3.33 | 45.07 | 1.54 | 18.67 | 10.30 | 1.43 | 84213.78 |
| 5 | 7.95 | 3.85 | 48.10 | 1.72 | 18.21 | 10.21 | 1.42 | 84781.15 |
| 6 | 5.77 | 5.87 | 57.16 | 1.46 | 17.86 | 11.19 | 1.43 | 83979.27 |
| 7 | 6.74 | 4.54 | 53.10 | 1.40 | 18.67 | 10.86 | 1.44 | 82248.86 |
| 8 | 9.98 | 4.35 | 52.16 | 2.03 | 16.67 | 10.73 | 1.44 | 85172.45 |
| 9 | 9.89 | 3.87 | 58.23 | 2.20 | 15.53 | 10.99 | 1.40 | 83112.28 |
| 10 | 9.16 | 3.27 | 58.69 | 2.22 | 15.28 | 11.12 | 1.42 | 80697.46 |
| 11 | 9.74 | 3.89 | 49.41 | 2.24 | 15.82 | 10.77 | 1.42 | 80644.22 |
| 12 | 10.70 | 4.77 | 60.11 | 2.60 | 15.81 | 11.05 | 1.38 | 82084.61 |
| 13 | 8.24 | 3.69 | 54.08 | 2.18 | 16.16 | 10.78 | 1.37 | 82042.62 |
| 14 | 9.14 | 3.57 | 59.94 | 2.24 | 15.17 | 11.00 | 1.38 | 81017.15 |
| 15 | 8.69 | 5.23 | 51.69 | 1.96 | 16.74 | 10.57 | 1.38 | 83265.78 |
| 16 | 12.19 | 5.24 | 54.05 | 2.51 | 16.21 | 10.73 | 1.38 | 82264.02 |
| 17 | 17.56 | 6.68 | 64.14 | 2.84 | 15.40 | 11.09 | 1.38 | 83035.15 |
| 18 | 9.76 | 3.62 | 55.96 | 1.96 | 16.23 | 10.84 | 1.39 | 84379.54 |
| 19 | 10.28 | 3.80 | 62.92 | 1.92 | 15.82 | 10.84 | 1.44 | 84830.45 |
| 20 | 11.50 | 4.88 | 59.01 | 2.06 | 16.23 | 10.78 | 1.44 | 84909.86 |
| 21 | 10.42 | 5.04 | 53.03 | 1.86 | 17.55 | 10.37 | 1.44 | 86287.88 |
| 22 | 10.50 | 5.57 | 57.41 | 2.22 | 16.83 | 10.74 | 1.44 | 83688.75 |
| 23 | 9.45 | 5.56 | 57.02 | 1.93 | 17.29 | 10.60 | 1.44 | 85081.39 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.36 | 4.76 | 54.24 | 1.95 | 16.90 | 10.69 | 1.42 | 83704.05 |
| 最大值 | 17.56 | 9.85 | 64.14 | 2.84 | 20.05 | 11.19 | 1.47 | 90453.75 |
| 發生時間 | 17 | 1 | 17 | 17 | 0 | 6 | | 0 |
| 最小值 | 4.66 | 3.27 | 39.05 | 0.89 | 15.17 | 9.67 | 1.37 | 80644.22 |
| 發生時間 | 0 | 10 | 0 | 0 | 14 | 0 | | 11 |
| 零點偏移(率) | -0.01 % | 0.00 % | -0.08 % | 0.00 % | | -0.03 | 0.00 | 0.00 % |
| 全幅偏移(率) | 0.66 % | -0.33 % | -0.58 % | 0.14 % | | 0.20 | -0.06 | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

