

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月10日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 6.56     | 4.04     | 46.24    | 0.84     | 17.35    | 11.40    | 1.31     | 82366.34  |
| 1                 | 2.80     | 4.27     | 48.97    | 0.72     | 19.56    | 10.85    | 1.31     | 85065.27  |
| 2                 | 7.73     | 3.93     | 52.70    | 1.43     | 16.07    | 11.66    | 1.32     | 82059.42  |
| 3                 | 8.72     | 3.60     | 61.69    | 1.09     | 16.36    | 11.70    | 1.33     | 81486.34  |
| 4                 | 8.35     | 4.31     | 63.21    | 0.63     | 17.41    | 11.42    | 1.34     | 83027.49  |
| 5                 | 7.68     | 4.37     | 59.07    | 0.79     | 17.57    | 11.34    | 1.31     | 85934.66  |
| 6                 | 8.13     | 3.17     | 61.09    | 0.88     | 17.43    | 11.43    | 1.31     | 82426.22  |
| 7                 | 5.57     | 3.55     | 62.06    | 0.66     | 17.18    | 12.18    | 1.33     | 76964.44  |
| 8                 | 1.36     | 3.46     | 63.37    | 0.46     | 18.02    | 11.91    | 1.35     | 78008.67  |
| 9                 | 2.28     | 3.50     | 48.91    | 0.43     | 18.08    | 11.36    | 1.32     | 82631.40  |
| 10                | 5.36     | 3.93     | 31.64    | 0.86     | 17.51    | 11.32    | 1.30     | 83495.23  |
| 11                | 5.19     | 17.25    | 33.70    | 1.41     | 16.83    | 11.45    | 1.34     | 82480.91  |
| 12                | 1.06     | 1.32     | 31.57    | 1.29     | 16.26    | 11.84    | 1.29     | 78717.11  |
| 13                | 2.21     | 1.41     | 32.14    | 0.85     | 16.29    | 11.91    | 1.29     | 77492.37  |
| 14                | 2.81     | 2.30     | 32.72    | 1.42     | 15.09    | 12.06    | 1.29     | 78345.57  |
| 15                | 9.85     | 2.80     | 29.53    | 2.23     | 14.60    | 12.14    | 1.29     | 77713.53  |
| 16                | 2.94     | 2.88     | 36.17    | 0.93     | 16.44    | 12.22    | 1.30     | 76531.41  |
| 17                | 3.10     | 3.39     | 52.38    | 0.57     | 17.31    | 12.78    | 1.37     | 71045.32  |
| 18                | 6.60     | 5.54     | 34.14    | 0.50     | 17.74    | 11.42    | 1.34     | 82450.32  |
| 19                | 8.93     | 2.37     | 46.23    | 0.91     | 16.28    | 11.60    | 1.33     | 82223.34  |
| 20                | 9.31     | 2.41     | 46.62    | 0.69     | 17.01    | 11.53    | 1.31     | 82488.98  |
| 21                | 9.05     | 2.27     | 46.69    | 0.66     | 17.90    | 11.17    | 1.31     | 84368.06  |
| 22                | 9.45     | 2.50     | 54.06    | 0.56     | 17.46    | 11.60    | 1.31     | 81229.73  |
| 23                | 9.49     | 2.82     | 57.74    | 0.47     | 18.51    | 11.33    | 1.31     | 82466.66  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 6.02     | 3.81     | 47.19    | 0.89     | 17.09    | 11.65    | 1.32     | 80875.78  |
| 最 大 值             | 9.85     | 17.25    | 63.37    | 2.23     | 19.56    | 12.78    | 1.40     | 85934.66  |
| 發生時間              | 15       | 11       | 8        | 15       | 1        | 17       |          | 5         |
| 最 小 值             | 1.06     | 1.32     | 29.53    | 0.43     | 14.60    | 10.85    | 1.28     | 71045.32  |
| 發生時間              | 12       | 12       | 15       | 9        | 15       | 1        |          | 17        |
| 零點偏移(率)           | -0.01 %  | 0.00 %   | -0.04 %  | -0.02 %  |          | -0.08    |          | 0.30 %    |
| 全幅偏移(率)           | -0.64 %  | 0.63 %   | -0.34 %  | 0.24 %   |          | -0.05    |          | 0.30 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |



P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月10日

| 項目<br>單位<br>小時\限標 | #3-HCl_C<br>ppm | #3-CO_C<br>ppm | #3-NOx_C<br>ppm | #3-SO2_C<br>ppm | #3-H2O<br>% | #3-O2_C<br>% | #3-OPAC<br>% | #3-FLOW_C<br>m3/Hour |
|-------------------|-----------------|----------------|-----------------|-----------------|-------------|--------------|--------------|----------------------|
| 0                 | 7.50            | 2.57           | 55.66           | 1.08            | 16.08       | 11.05        | 1.49         | 79411.15             |
| 1                 | 13.03           | 5.45           | 54.02           | 0.99            | 17.93       | 10.70        | 1.50         | 80805.68             |
| 2                 | 8.02            | 2.10           | 56.32           | 1.06            | 16.46       | 10.73        | 1.50         | 81994.82             |
| 3                 | 11.30           | 1.52           | 47.84           | 1.24            | 15.98       | 10.72        | 1.50         | 78797.84             |
| 4                 | 7.15            | 4.68           | 50.86           | 0.80            | 16.63       | 10.78        | 1.50         | 78446.95             |
| 5                 | 10.03           | 5.70           | 48.69           | 1.06            | 16.67       | 10.65        | 1.49         | 79894.84             |
| 6                 | 9.05            | 6.31           | 49.23           | 0.88            | 17.46       | 10.42        | 1.49         | 82870.48             |
| 7                 | 7.35            | 3.64           | 55.42           | 1.27            | 16.93       | 10.46        | 1.48         | 85159.00             |
| 8                 | 9.92            | 8.69           | 38.44           | 1.41            | 16.56       | 10.69        | 1.48         | 82164.41             |
| 9                 | 7.84            | 1.39           | 42.19           | 1.13            | 16.29       | 10.94        | 1.48         | 81112.73             |
| 10                | 13.58           | 6.05           | 39.65           | 2.69            | 13.98       | 11.41        | 1.48         | 78268.26             |
| 11                | 6.53            | 2.23           | 44.34           | 1.51            | 14.98       | 11.44        | 1.49         | 77630.50             |
| 12                | 10.59           | 3.75           | 41.97           | 1.63            | 16.22       | 10.71        | 1.49         | 82322.93             |
| 13                | 7.52            | 3.52           | 43.35           | 3.50            | 13.96       | 11.53        | 1.49         | 77726.29             |
| 14                | 8.50            | 7.50           | 42.99           | 1.40            | 15.95       | 11.01        | 1.48         | 79557.75             |
| 15                | 6.24            | 9.38           | 44.38           | 1.09            | 15.66       | 11.74        | 1.48         | 74433.70             |
| 16                | 9.01            | 6.34           | 43.71           | 1.14            | 18.81       | 9.84         | 1.48         | 86490.07             |
| 17                | 6.99            | 8.51           | 40.72           | 1.54            | 18.33       | 9.81         | 1.48         | 87251.51             |
| 18                | 7.65            | 4.03           | 56.77           | 1.64            | 16.61       | 10.32        | 1.48         | 85272.89             |
| 19                | 9.80            | 5.09           | 52.70           | 1.81            | 15.53       | 10.89        | 1.48         | 81429.33             |
| 20                | 5.68            | 1.08           | 56.30           | 1.03            | 16.23       | 10.93        | 1.48         | 79020.19             |
| 21                | 5.41            | 1.96           | 57.36           | 0.66            | 16.87       | 10.71        | 1.48         | 80795.01             |
| 22                | 5.59            | 4.33           | 61.82           | 0.61            | 18.03       | 10.25        | 1.48         | 84488.28             |
| 23                | 9.23            | 3.50           | 56.62           | 0.92            | 17.93       | 10.24        | 1.48         | 84124.25             |
| 監測時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 超限次數              | 0               | 0              | 0               | 0               | 0           | 0            | 0            | 0                    |
| 有效時數              | 24              | 24             | 24              | 24              | 24          | 24           | 24           | 24                   |
| 平 均 值             | 8.48            | 4.55           | 49.22           | 1.34            | 16.50       | 10.75        | 1.49         | 81227.87             |
| 最 大 值             | 13.58           | 9.38           | 61.82           | 3.50            | 18.81       | 11.74        | 1.51         | 87251.51             |
| 發生時間              | 10              | 15             | 22              | 13              | 16          | 15           |              | 17                   |
| 最 小 值             | 5.41            | 1.08           | 38.44           | 0.61            | 13.96       | 9.81         | 1.47         | 74433.70             |
| 發生時間              | 21              | 20             | 8               | 22              | 13          | 17           |              | 15                   |
| 零點偏移(率)           | -0.07 %         | -0.01 %        | -0.03 %         | -0.02 %         |             | -0.04        |              | 0.20 %               |
| 全幅偏移(率)           | -0.10 %         | 0.29 %         | -0.10 %         | 0.14 %          |             | -0.24        |              | 0.20 %               |
| 有效比率              | 100.00 %        | 100.00 %       | 100.00 %        | 100.00 %        | 100.00 %    | 100.00 %     | 100.00 %     | 100.00 %             |
| 備註                |                 |                |                 |                 |             |              |              |                      |