

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年07月15日

報表日期: 113年07月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.03	2.85	56.44	0.82	19.00	11.37	1.06	78351.86
1	1.11	3.50	57.78	1.11	19.35	12.13	1.06	73054.67
2	3.92	2.73	40.85	1.49	19.49	10.53	1.06	86509.30
3	5.42	3.34	38.98	2.29	16.17	11.08	1.06	79143.83
4	6.34	5.59	31.47	2.47	16.64	11.18	1.03	80811.98
5	8.16	3.81	52.90	2.27	17.59	11.35	1.02	78050.63
6	8.57	5.14	59.39	1.51	16.91	11.99	1.02	73573.84
7	6.73	5.10	45.11	1.23	18.14	10.47	1.03	82597.43
8	8.44	6.26	50.84	2.18	16.14	11.52	1.05	77537.72
9	6.15	5.47	27.90	2.34	17.25	11.13	1.02	76304.88
10	6.03	3.50	32.35	2.13	16.98	11.33	1.04	76609.25
11	7.20	3.80	44.45	1.80	18.23	11.11	1.03	76123.45
12	8.34	5.57	55.00	1.45	18.74	10.44	1.02	78851.96
13	6.99	10.30	50.13	1.96	16.92	10.60	1.02	76197.21
14	6.16	8.28	34.69	1.53	16.65	11.43	1.02	72113.53
15	5.20	6.91	55.21	1.03	18.64	11.12	1.02	78316.66
16	6.60	6.66	66.68	1.25	18.62	11.04	1.02	76272.65
17	7.72	8.66	68.41	1.36	19.61	10.15	1.02	83820.55
18	8.81	7.90	54.99	1.64	18.69	10.56	1.04	82188.32
19	9.07	7.46	49.05	1.99	17.79	10.74	1.04	81609.13
20	8.95	6.99	50.90	1.34	18.43	10.88	1.05	82448.89
21	8.87	6.37	52.70	1.65	18.17	10.80	1.05	84686.38
22	9.53	7.40	47.81	2.16	17.08	11.23	1.04	80400.67
23	9.91	6.85	56.81	1.61	18.13	11.30	1.03	78659.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.09	5.85	49.20	1.69	17.89	11.06	1.03	78926.44
最 大 值	9.91	10.30	68.41	2.47	19.61	12.13	1.07	86509.30
發生時間	23	13	17	4	17	1		2
最 小 值	1.11	2.73	27.90	0.82	16.14	10.15	1.01	72113.53
發生時間	1	2	9	0	8	17		14
零點偏移(率)	-0.20 %	-0.08 %	-0.17 %	-0.01 %		-0.09		0.00 %
全幅偏移(率)	0.00 %	0.68 %	-0.02 %	0.31 %		0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月15日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	1.18	3.06	40.72	0.85	16.88	10.70	0.92	78173.94
1	1.20	3.58	49.29	0.98	17.09	10.82	0.92	77035.01
2	1.18	5.10	43.37	2.01	14.25	11.04	0.92	72908.85
3	1.20	2.78	47.20	1.20	15.66	11.12	0.94	73628.80
4	1.24	2.54	60.88	1.07	16.55	11.31	0.98	72318.70
5	1.18	10.51	49.97	1.32	15.83	10.92	0.98	74153.68
6	4.24	5.11	50.50	1.19	15.79	10.58	0.95	75068.95
7	1.64	4.54	59.02	0.74	17.99	9.87	0.99	75123.93
8	1.31	2.08	52.70	1.11	16.39	10.03	1.01	75498.09
9	1.31	3.13	38.08	0.74	16.20	10.48	0.99	72431.03
10	1.18	2.27	57.60	0.63	18.43	10.54	1.04	76706.03
11	1.17	3.45	49.99	0.83	16.79	10.67	1.00	77032.14
12	1.18	2.98	51.95	0.90	16.12	10.87	0.98	75818.07
13	1.16	3.39	48.45	0.81	16.32	10.64	0.98	74178.55
14	1.15	2.84	41.26	0.82	16.21	10.58	0.97	73091.09
15	1.20	2.20	54.58	0.88	17.15	10.58	0.96	74634.99
16	1.84	2.62	54.99	0.91	17.35	10.80	0.98	76700.17
17	2.01	2.60	51.41	0.94	17.80	10.31	1.01	80508.04
18	3.53	2.78	37.21	0.98	16.30	10.71	1.02	77408.59
19	1.15	2.27	37.46	1.03	15.91	10.68	0.98	78120.68
20	4.78	2.40	49.09	0.94	17.66	10.48	1.00	81793.47
21	3.41	3.73	37.59	1.15	16.68	10.42	0.98	81097.13
22	1.80	2.25	50.38	1.06	16.55	10.97	0.97	77115.74
23	3.39	2.32	50.86	1.02	16.48	11.01	1.00	78487.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	1.86	3.36	48.52	1.00	16.60	10.67	0.98	76209.73
最 大 值	4.78	10.51	60.88	2.01	18.43	11.31	1.04	81793.47
發生時間	20	5	4	2	10	4		20
最 小 值	1.15	2.08	37.21	0.63	14.25	9.87	0.92	72318.70
發生時間	14	8	18	10	2	7		4
零點偏移(率)	-0.08 %	-0.08 %	-0.12 %	-0.06 %		-0.01		-0.10 %
全幅偏移(率)	0.02 %	0.02 %	-0.40 %	0.02 %		0.29		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								