

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.88	6.62	49.73	1.46	17.53	11.49	1.05	72040.47
1	8.32	6.59	51.15	1.52	17.84	11.67	1.04	70474.64
2	9.22	6.54	56.77	1.15	19.93	11.51	1.05	71480.01
3	9.77	6.25	46.88	1.19	18.64	11.14	1.04	75688.81
4	8.18	6.92	51.29	1.36	17.69	11.48	1.05	73961.55
5	10.37	11.80	55.43	0.73	20.21	10.71	1.05	72968.28
6	9.99	10.89	46.23	0.86	19.21	10.99	1.05	76400.02
7	9.34	14.22	43.82	1.25	17.49	11.60	1.05	72080.03
8	9.25	10.82	41.85	0.72	19.64	10.57	1.06	77236.85
9	6.96	13.33	43.37	1.19	17.68	11.08	1.08	72939.69
10	9.35	12.87	53.68	1.27	18.31	11.45	1.10	71387.73
11	8.92	8.20	48.77	1.32	19.73	10.71	1.09	76914.78
12	7.72	8.24	50.92	0.65	19.52	10.86	1.07	75841.77
13	6.36	7.33	46.24	0.92	18.37	11.00	1.08	74366.77
14	6.46	9.78	48.23	1.00	17.46	11.43	1.09	72913.41
15	9.94	15.08	41.81	2.56	17.73	11.12	1.09	74141.12
16	5.72	6.48	55.92	0.81	19.56	10.89	1.08	76685.33
17	8.16	5.84	45.76	1.25	18.24	10.78	1.10	78715.87
18	9.06	5.67	42.79	1.46	17.70	10.95	1.10	77312.05
19	6.91	8.59	44.70	1.35	17.21	11.14	1.10	74755.53
20	9.00	10.81	47.51	0.75	18.58	10.87	1.09	77208.87
21	9.16	10.00	46.10	1.01	18.29	11.08	1.09	74764.24
22	9.05	5.65	47.89	0.83	18.60	10.91	1.09	76672.24
23	8.31	6.61	63.32	0.56	19.78	11.08	1.10	74434.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.56	8.96	48.76	1.13	18.54	11.10	1.07	74641.02
最大值	10.37	15.08	63.32	2.56	20.21	11.67	1.10	78715.87
發生時間	5	15	23	15	5	1		17
最小值	5.72	5.65	41.81	0.56	17.21	10.57	1.03	70474.64
發生時間	16	22	15	23	19	8		1
零點偏移(率)	-0.11 %	-0.01 %	-0.03 %	-0.00 %		0.03		0.00 %
全幅偏移(率)	0.00 %	-0.73 %	-0.44 %	-0.96 %		0.12		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.19	4.92	57.84	2.00	15.27	11.65	0.98	76541.29
1	8.71	4.78	51.26	1.37	16.93	10.96	0.99	80688.02
2	9.71	10.38	38.97	2.16	17.35	10.27	0.99	85850.69
3	8.35	4.24	53.51	1.69	16.86	10.76	0.99	82769.73
4	6.26	5.57	53.44	0.92	17.99	10.17	0.99	86086.42
5	9.51	5.05	54.15	1.48	17.81	9.80	0.99	88565.87
6	6.63	9.87	51.34	1.71	16.83	10.30	0.95	87594.51
7	8.50	8.39	54.65	1.43	17.77	10.08	0.97	86459.61
8	10.63	3.33	56.38	2.33	16.08	10.25	0.98	86598.21
9	9.82	2.70	58.28	1.56	16.18	10.76	0.98	82653.15
10	9.15	2.54	57.65	1.64	17.02	10.36	0.95	85470.49
11	9.94	5.83	54.37	1.31	17.13	10.44	0.94	84568.38
12	8.43	5.45	45.53	1.78	15.95	10.69	0.95	83429.62
13	5.41	6.75	51.37	1.70	15.14	11.14	0.97	80448.93
14	8.27	6.76	57.23	1.87	14.55	11.19	0.97	80906.88
15	4.17	9.88	58.31	1.62	14.84	11.81	0.97	75379.18
16	0.09	2.74	54.35	1.10	16.31	10.95	0.96	81451.44
17	1.96	4.98	58.01	1.26	16.97	10.36	0.94	85647.31
18	0.87	5.83	49.76	2.20	14.59	10.84	0.94	83700.82
19	0.52	6.05	45.82	1.53	16.79	10.28	0.97	85864.18
20	1.43	8.76	44.84	1.70	16.77	10.07	0.97	87476.91
21	1.38	9.16	49.46	1.44	17.24	9.99	0.97	87665.43
22	1.85	6.20	44.79	1.04	17.98	9.98	0.97	87110.03
23	3.17	6.24	45.41	1.37	17.97	10.16	0.97	85341.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.87	6.10	51.95	1.59	16.60	10.55	0.97	84094.53
最大值	10.63	10.38	58.31	2.33	17.99	11.81	1.10	88565.87
發生時間	8	2	15	8	4	15		5
最小值	0.09	2.54	38.97	0.92	14.55	9.80	0.94	75379.18
發生時間	16	10	2	4	14	5		15
零點偏移(率)	-0.07 %	-0.01 %	-0.01 %	-0.00 %		0.02		-0.20 %
全幅偏移(率)	0.02 %	0.03 %	-0.18 %	0.49 %		-0.19		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.57	10.57	46.50	2.32	14.06	11.10	0.91	74502.88
1	9.06	2.35	45.62	1.81	15.32	10.78	0.92	75641.36
2	7.19	3.66	42.14	1.46	15.86	10.88	0.91	75306.06
3	4.45	10.26	43.46	1.32	16.83	10.67	0.91	77492.20
4	7.86	7.78	47.15	1.37	16.59	10.80	0.92	77812.65
5	8.98	4.92	50.95	1.58	17.80	10.27	0.93	82169.77
6	9.37	3.40	52.96	2.10	15.84	10.22	0.94	80774.67
7	11.57	8.54	39.41	2.15	15.73	9.95	0.91	73620.19
8	8.86	3.61	44.04	1.72	15.26	10.32	0.91	73526.07
9	9.32	2.72	52.09	2.12	15.19	10.24	0.91	71964.16
10	10.29	4.28	35.72	1.92	15.69	10.01	0.92	76502.91
11	8.40	8.45	39.62	1.50	15.26	10.49	0.91	74257.63
12	3.63	6.15	40.87	1.18	14.19	10.99	0.90	71240.81
13	1.51	6.22	46.10	0.98	15.00	10.61	0.90	73299.66
14	2.18	7.34	51.53	1.45	14.33	10.74	0.89	72540.47
15	0.63	6.31	50.17	1.80	13.19	11.06	0.89	73145.51
16	2.18	4.91	48.55	0.90	15.73	10.76	0.92	81399.34
17	1.02	4.63	51.48	1.34	14.56	11.33	0.93	78798.12
18	0.29	4.99	52.29	1.96	13.34	11.48	0.92	77096.04
19	0.07	5.16	50.95	1.63	14.38	11.19	0.91	78726.31
20	1.24	5.96	54.72	1.33	15.16	11.29	0.94	81456.72
21	6.18	6.95	57.01	1.85	14.31	11.47	0.94	81919.34
22	2.18	4.73	57.54	0.75	17.47	10.94	0.92	77698.06
23	3.52	5.13	58.19	1.10	16.27	10.63	0.92	84470.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.36	5.79	48.29	1.57	15.31	10.76	0.92	76890.04
最大值	11.57	10.57	58.19	2.32	17.80	11.48	0.95	84470.01
發生時間	7	0	23	0	5	18		23
最小值	0.07	2.35	35.72	0.75	13.19	9.95	0.89	71240.81
發生時間	19	1	10	22	15	7		12
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.00 %		0.01		0.00 %
全幅偏移(率)	0.02 %	1.32 %	-0.19 %	0.40 %		0.07		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								