

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.95	12.64	56.82	0.26	20.56	10.81	1.05	77293.12
1	4.71	10.42	48.64	0.43	21.43	10.11	1.05	81694.80
2	9.05	5.77	41.64	1.30	18.74	10.57	1.05	79398.24
3	6.19	6.44	46.02	1.05	17.47	10.95	1.05	76528.38
4	6.36	8.80	48.01	1.77	16.51	11.26	1.05	74201.52
5	5.83	5.31	56.38	1.10	17.52	11.15	1.05	74128.89
6	5.06	9.60	57.40	0.81	18.15	11.19	1.05	75426.21
7	1.94	8.14	59.10	0.53	17.93	11.19	1.04	76273.68
8	1.05	8.79	44.79	1.73	15.31	11.53	1.01	71556.62
9	0.40	2.79	53.22	1.32	15.87	11.33	1.00	72643.67
10	0.19	4.65	49.66	1.50	15.26	11.28	0.99	72491.27
11	0.78	5.41	56.98	1.36	15.13	11.42	0.98	72884.19
12	0.11	7.68	41.99	2.37	13.64	11.22	0.99	73956.01
13	1.66	8.55	39.31	2.33	14.09	10.67	0.99	78081.50
14	3.14	3.06	50.98	1.38	15.33	11.20	1.00	72293.58
15	4.07	11.08	47.45	1.23	16.35	11.09	1.02	75833.13
16	0.97	9.33	61.39	0.76	17.92	11.52	1.03	73401.50
17	1.57	10.16	62.05	0.74	18.14	11.29	1.02	75189.73
18	3.04	12.25	56.01	0.66	17.86	11.54	1.02	72815.23
19	0.42	11.67	65.01	0.83	16.64	12.51	1.02	66704.16
20	2.14	6.71	53.42	0.50	18.76	11.71	1.03	71437.10
21	4.26	6.74	51.28	0.51	19.82	10.91	1.02	76696.24
22	7.04	10.26	54.87	0.68	20.01	10.42	1.02	79635.48
23	9.50	11.51	45.69	2.03	16.34	11.52	1.02	71795.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.39	8.24	52.00	1.13	17.28	11.18	1.02	74681.67
最大值	9.50	12.64	65.01	2.37	21.43	12.51	1.08	81694.80
發生時間	23	0	19	12	1	19		1
最小值	0.11	2.79	39.31	0.26	13.64	10.11	0.98	66704.16
發生時間	12	9	13	0	12	1		19
零點偏移(率)	-0.05 %	-0.01 %	-0.02 %	-0.00 %		-0.11		0.00 %
全幅偏移(率)	-1.41 %	-0.30 %	-0.36 %	0.03 %		0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.10	3.89	61.65	1.47	18.02	10.13	1.03	86662.85
1	0.08	7.97	53.08	2.36	17.82	10.25	1.01	85773.22
2	0.88	3.76	60.62	3.17	16.52	10.27	1.00	87391.70
3	1.13	3.71	51.28	2.18	17.90	10.17	1.01	86297.07
4	2.21	8.08	56.90	1.46	19.15	9.85	1.02	87466.01
5	1.20	8.57	48.49	1.48	20.16	9.31	1.02	90529.82
6	1.30	4.97	49.57	2.39	17.76	9.92	0.99	84664.45
7	0.89	4.48	52.04	2.16	18.50	9.79	0.99	88299.93
8	0.27	5.90	49.14	2.72	16.17	11.60	0.99	76877.42
9	0.97	2.17	52.80	2.30	16.08	11.77	0.98	75441.04
10	0.21	1.60	55.38	1.20	17.30	11.57	0.98	76028.20
11	0.20	2.83	49.27	1.22	17.27	11.41	0.99	76959.56
12	0.11	3.57	43.51	1.22	18.04	11.00	0.99	78918.60
13	1.23	6.47	50.61	1.80	16.62	11.13	1.00	80212.89
14	1.58	8.37	52.05	1.74	17.40	10.67	1.02	82744.72
15	5.81	4.66	47.34	1.65	19.44	9.21	1.02	91714.00
16	8.34	6.50	46.44	1.17	20.03	9.12	1.02	90891.19
17	8.97	5.10	50.94	1.45	18.71	9.77	1.02	87881.79
18	9.71	7.42	58.30	1.64	17.80	10.02	1.02	87424.00
19	9.37	6.90	65.73	1.75	17.32	10.22	1.02	85490.25
20	7.86	7.19	63.43	0.70	18.49	10.40	1.02	83022.92
21	7.97	8.27	41.34	1.32	18.46	10.24	1.02	85108.91
22	10.01	9.19	49.98	2.55	16.52	10.60	1.02	83835.48
23	11.02	7.24	50.16	2.70	15.92	10.84	1.02	82216.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.81	5.78	52.50	1.83	17.81	10.39	1.01	84243.85
最大值	11.02	9.19	65.73	3.17	20.16	11.77	1.03	91714.00
發生時間	23	22	19	2	5	9		15
最小值	0.08	1.60	41.34	0.70	15.92	9.12	0.98	75441.04
發生時間	1	10	21	20	23	16		9
零點偏移(率)	-0.04 %	-0.01 %	-0.03 %	-0.01 %		0.01		-0.20 %
全幅偏移(率)	0.02 %	0.03 %	-0.11 %	0.03 %		0.02		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.06	7.74	33.23	1.09	15.86	10.16	0.98	75252.83
1	3.93	3.22	38.11	0.94	16.00	10.42	0.99	74011.35
2	5.17	4.77	39.82	1.34	16.09	10.29	0.99	75985.62
3	7.79	8.78	48.21	3.08	13.01	10.99	0.99	76310.53
4	3.37	4.08	49.94	2.00	14.40	11.22	0.99	76004.05
5	1.63	5.85	61.63	0.80	17.03	10.72	1.01	80749.94
6	1.54	12.81	42.18	0.91	16.70	10.49	0.99	82017.43
7	0.73	5.85	49.69	1.12	15.37	11.14	1.00	86059.24
8	0.02	6.97	48.45	1.97	13.30	12.31	1.00	62209.53
9	0.19	4.88	46.60	2.12	12.94	12.55	0.99	59198.87
10	1.31	4.23	43.87	1.43	14.14	12.02	1.00	62091.27
11	1.18	3.74	47.50	1.21	14.61	12.03	0.99	63007.52
12	0.57	8.98	41.44	1.44	14.02	11.65	0.99	65807.08
13	2.00	7.07	48.74	1.82	13.48	11.73	0.99	65159.95
14	3.71	7.46	42.02	2.63	14.01	11.01	1.00	70963.69
15	4.49	5.05	34.39	1.30	15.16	9.92	1.00	79513.96
16	3.73	4.44	46.84	1.17	16.28	10.29	1.02	81204.58
17	4.90	6.51	44.27	1.38	15.54	10.48	1.02	79593.43
18	6.41	10.15	51.66	1.70	14.27	10.97	1.02	75795.29
19	6.85	9.46	52.96	1.48	15.34	10.79	1.02	76525.05
20	6.40	8.89	44.83	1.51	14.88	10.40	1.02	77304.16
21	6.77	9.78	44.79	1.91	13.67	10.82	1.02	74656.47
22	8.48	11.43	46.17	2.77	12.66	10.87	1.01	72587.08
23	9.94	5.08	43.01	2.74	12.90	10.80	0.99	70574.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.05	6.97	45.43	1.66	14.65	11.00	1.00	73440.97
最大值	9.94	12.81	61.63	3.08	17.03	12.55	1.02	86059.24
發生時間	23	6	5	3	5	9		7
最小值	0.02	3.22	33.23	0.80	12.66	9.92	0.97	59198.87
發生時間	8	1	0	5	22	15		9
零點偏移(率)	-0.04 %	0.00 %	-0.25 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	0.02 %	0.32 %	-0.10 %	0.16 %		0.43		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								