

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.61	11.88	53.03	1.65	18.68	11.11	1.34	82731.91
1	8.84	12.31	49.03	2.34	17.88	11.32	1.34	81258.48
2	10.15	12.27	53.22	2.15	17.31	11.61	1.34	79844.60
3	11.41	11.60	56.64	2.29	17.28	11.17	1.35	83210.68
4	6.65	12.78	59.31	2.48	16.59	11.20	1.34	83874.65
5	11.14	12.68	57.95	3.47	17.15	11.20	1.34	83895.80
6	9.23	12.82	58.14	2.44	17.12	11.37	1.34	82207.91
7	10.59	13.03	46.49	2.47	17.61	11.22	1.34	83084.60
8	7.01	12.86	55.42	1.98	17.53	11.28	1.34	81310.64
9	9.48	13.42	50.80	2.14	16.58	11.82	1.31	77273.05
10	13.58	13.00	50.41	3.00	16.57	11.43	1.30	80345.61
11	5.93	12.81	54.32	2.39	15.64	11.54	1.33	80625.79
12	12.32	12.91	57.99	2.86	15.14	11.68	1.34	79231.35
13	6.63	12.84	56.12	2.25	15.97	11.53	1.29	79324.99
14	11.53	12.84	53.75	2.44	15.85	11.55	1.29	80162.04
15	8.53	13.05	55.67	2.86	15.66	11.72	1.29	79265.76
16	14.40	12.68	52.27	3.03	16.32	11.31	1.30	81005.37
17	12.79	12.86	55.70	3.28	14.48	11.70	1.34	77329.64
18	11.27	12.85	53.32	2.79	15.72	11.56	1.31	79117.37
19	7.15	12.89	50.85	2.15	15.78	11.57	1.29	80237.79
20	13.51	13.22	52.88	3.56	15.38	11.68	1.29	78077.25
21	4.90	12.74	54.62	2.99	16.76	11.37	1.29	80637.45
22	5.97	13.15	53.21	2.53	17.18	11.61	1.29	78423.20
23	10.72	12.75	47.49	2.86	16.36	11.39	1.29	80275.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.72	12.76	53.69	2.60	16.52	11.46	1.32	80531.30
最大值	14.40	13.42	59.31	3.56	18.68	11.82	1.36	83895.80
發生時間	16	9	4	20	0	9		5
最小值	4.90	11.60	46.49	1.65	14.48	11.11	1.29	77273.05
發生時間	21	3	7	0	17	0		9
零點偏移(率)	-0.02 %	-0.01 %	-0.10 %	-0.08 %		-0.06	-0.01	0.40 %
全幅偏移(率)	-0.84 %	-2.10 %	-0.54 %	-0.48 %		-0.01	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.84	11.94	43.36	1.57	17.94	10.23	1.01	80515.50
1	6.72	11.79	46.61	1.85	17.26	10.44	1.02	77246.82
2	13.29	12.99	53.35	1.88	18.26	10.38	1.02	77921.26
3	6.00	13.49	40.80	2.03	17.23	10.09	1.02	81798.23
4	13.41	11.83	48.27	2.07	17.55	10.40	1.02	79277.01
5	6.92	11.72	41.29	2.33	16.51	10.49	1.02	78876.84
6	4.20	12.14	36.16	2.16	16.96	10.40	1.02	78135.13
7	8.44	11.81	45.28	1.83	17.36	10.55	1.02	80301.94
8	7.50	11.89	52.52	1.97	16.45	10.75	1.02	80398.04
9	9.88	12.07	54.04	1.57	16.82	10.90	1.00	80040.95
10	10.19	12.57	52.42	2.94	14.81	11.01	1.01	79072.94
11	11.16	12.49	55.50	2.90	15.36	10.91	1.02	78983.96
12	10.09	11.96	50.72	2.16	15.84	10.91	1.02	79229.95
13	9.00	11.85	49.83	1.98	15.76	10.82	0.99	79859.61
14	10.24	11.88	51.67	2.26	15.57	10.83	0.99	79137.65
15	8.95	11.84	52.41	1.51	16.30	10.75	0.98	79833.06
16	12.18	11.65	51.49	2.11	15.65	10.61	0.98	80176.68
17	7.36	11.83	48.79	1.88	15.44	10.72	1.02	80269.58
18	15.26	12.69	56.09	2.39	13.83	10.96	1.01	79294.06
19	7.12	12.34	59.82	3.51	14.38	10.90	0.99	79421.39
20	11.02	11.86	49.79	3.36	15.56	10.82	0.99	80060.46
21	9.66	11.93	52.15	3.46	15.93	10.84	0.98	79621.71
22	6.55	11.31	47.12	1.36	17.25	10.09	0.97	78295.08
23	7.31	11.65	44.23	1.45	16.70	10.25	0.97	79971.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.18	12.06	49.32	2.19	16.28	10.63	1.00	79489.14
最大值	15.26	13.49	59.82	3.51	18.26	11.01	1.05	81798.23
發生時間	18	3	19	19	2	10		3
最小值	4.20	11.31	36.16	1.36	13.83	10.09	0.97	77246.82
發生時間	6	22	6	22	18	3		1
零點偏移(率)	-0.01 %	-0.01 %	-0.06 %	-0.01 %		-0.05	-0.01	0.00 %
全幅偏移(率)	-1.91 %	-1.67 %	-0.59 %	-0.11 %		0.00	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.89	11.50	54.44	3.14	18.84	9.80	1.41	77306.81
1	5.65	11.49	52.10	3.10	17.55	10.10	1.43	76778.36
2	7.62	11.60	52.48	3.02	16.14	10.13	1.42	75980.73
3	8.13	11.71	53.53	3.31	16.28	10.21	1.42	75764.37
4	9.36	11.51	54.53	3.35	17.15	10.09	1.42	76723.31
5	7.59	12.16	55.61	3.14	16.42	10.38	1.42	75727.57
6	7.53	12.07	50.20	3.12	17.28	9.93	1.42	78359.97
7	6.99	11.64	48.87	2.77	16.86	10.09	1.41	78789.86
8	9.95	11.39	48.07	2.96	17.31	9.89	1.41	76318.64
9	7.75	11.31	46.71	2.61	17.26	9.84	1.43	76405.69
10	10.44	12.21	48.39	2.93	16.06	10.09	1.43	74374.51
11	8.87	11.99	46.40	3.00	15.96	9.74	1.43	75230.34
12	7.74	12.03	52.71	3.05	14.50	10.02	1.41	73713.59
13	6.26	11.44	53.44	2.25	15.61	10.00	1.40	74684.66
14	8.35	12.14	51.22	2.77	16.11	9.64	1.41	76537.78
15	10.06	11.22	51.71	3.03	16.11	9.76	1.40	76194.97
16	8.28	11.21	42.92	3.20	15.86	9.49	1.40	75471.84
17	13.31	11.47	48.85	3.89	15.11	9.59	1.40	75118.02
18	5.96	11.69	47.55	3.81	15.31	9.71	1.40	74555.65
19	6.84	11.34	51.41	3.33	16.15	9.73	1.40	74296.41
20	11.50	11.28	44.92	3.00	16.38	9.39	1.41	75032.48
21	3.21	11.58	47.94	2.77	17.10	9.23	1.41	75162.99
22	4.96	11.33	55.45	2.88	16.20	9.45	1.41	73865.64
23	6.66	11.20	56.92	2.67	16.49	9.48	1.42	73879.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.95	11.60	50.68	3.05	16.42	9.82	1.41	75678.08
最大值	13.31	12.21	56.92	3.89	18.84	10.38	1.44	78789.86
發生時間	17	10	23	17	0	5		7
最小值	3.21	11.20	42.92	2.25	14.50	9.23	1.38	73713.59
發生時間	21	23	16	13	12	21		12
零點偏移(率)	-0.02 %	-0.05 %	-0.01 %	-0.06 %		-0.05	-0.01	0.00 %
全幅偏移(率)	0.31 %	0.15 %	0.03 %	0.09 %		0.06	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								