

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月17日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.57	12.68	57.83	1.63	18.07	11.17	0.93	80883.47
1	2.08	13.03	62.38	1.36	19.71	11.05	0.94	80000.68
2	3.76	12.79	63.52	1.85	18.43	11.04	0.94	81795.69
3	5.28	12.78	55.01	1.87	18.08	11.09	0.94	81768.87
4	1.12	13.25	58.81	1.40	18.25	11.39	0.94	79380.72
5	1.01	13.33	57.81	1.37	18.92	11.31	0.94	78813.38
6	1.92	12.30	50.44	1.34	21.62	10.24	0.94	80397.64
7	1.14	12.34	54.29	2.22	18.89	10.78	0.94	82910.89
8	3.77	12.85	52.28	1.82	18.94	10.82	0.94	82816.02
9	5.18	12.76	59.34	2.10	18.34	11.04	0.94	81448.04
10	3.66	13.58	60.39	1.61	18.31	11.01	0.94	81807.49
11	7.92	12.73	55.67	1.13	17.85	11.28	0.94	79349.28
12	7.45	12.56	43.02	1.32	18.93	11.02	0.94	81132.33
13	1.03	14.11	43.92	1.86	16.96	12.20	0.94	72549.81
14	2.90	11.35	50.50	2.24	15.91	13.34	0.94	64518.00
15	4.56	9.74	39.57	1.65	18.79	10.92	0.93	82065.46
16	6.55	11.42	46.53	1.74	18.55	10.84	0.92	82510.48
17	10.40	12.28	43.45	1.83	17.80	10.99	0.92	82520.88
18	8.08	12.68	48.89	1.98	17.93	11.02	0.93	81829.78
19	8.38	12.38	48.58	1.82	17.86	10.97	0.94	82118.39
20	11.05	12.38	44.43	3.23	18.22	10.86	0.92	81439.70
21	7.22	11.87	50.66	2.05	19.59	10.40	0.93	84871.00
22	3.98	12.61	48.93	1.25	19.47	11.03	0.94	80492.93
23	3.15	12.69	52.77	0.79	19.37	11.07	0.94	80448.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.84	12.52	52.04	1.73	18.53	11.12	0.94	80327.91
最 大 值	11.05	14.11	63.52	3.23	21.62	13.34	0.97	84871.00
發生時間	20	13	2	20	6	14		21
最 小 值	1.01	9.74	39.57	0.79	15.91	10.24	0.92	64518.00
發生時間	5	15	15	23	14	6		14
零點偏移(率)	-0.13 %	-0.01 %	-0.05 %	-0.01 %		0.00	-0.01	-0.10 %
全幅偏移(率)	-1.80 %	0.02 %	0.86 %	0.30 %		-0.12	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月17日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.86	12.58	56.29	3.38	15.88	11.09	1.27	74117.83
1	6.38	12.54	59.31	2.99	17.39	10.74	1.26	74881.37
2	9.12	12.74	60.63	3.49	16.67	10.96	1.25	73715.17
3	7.64	11.79	57.73	3.48	15.70	10.71	1.25	74185.87
4	15.38	11.71	57.78	3.74	17.09	10.32	1.25	77535.98
5	7.28	11.70	57.86	3.51	16.13	10.61	1.26	73063.50
6	9.98	11.87	58.39	3.44	19.33	10.34	1.26	73880.65
7	5.13	12.66	55.98	2.99	18.16	10.35	1.28	75921.92
8	11.72	12.20	47.30	3.49	19.87	9.09	1.30	74809.55
9	10.02	8.55	33.59	3.50	19.62	8.08	1.27	80142.19
10	9.58	9.66	50.60	0.38	16.18	10.01	1.29	72141.94
11	5.31	8.80	54.96	1.72	17.84	9.47	1.26	67626.96
12	5.72	9.08	46.10	2.38	18.58	8.95	1.25	70898.22
13	5.95	10.49	47.18	2.63	17.81	9.49	1.25	67069.76
14	1.98	13.97	63.95	3.18	15.18	12.25	1.24	52080.40
15	2.76	13.22	44.76	2.31	20.03	9.49	1.24	65079.89
16	4.18	10.81	53.69	1.77	19.68	8.08	1.25	82922.45
17	11.48	10.57	50.59	1.55	17.83	9.28	1.28	78760.23
18	4.26	11.36	43.75	1.29	16.64	10.25	1.27	75156.49
19	6.40	11.80	47.08	1.37	18.05	10.51	1.27	76555.44
20	4.46	11.86	42.15	1.29	17.29	10.61	1.25	77386.30
21	10.83	12.31	58.54	1.50	17.88	10.80	1.27	77156.94
22	6.04	12.05	58.30	1.51	18.82	10.63	1.27	73626.61
23	7.76	11.81	55.27	2.28	18.75	10.27	1.27	75365.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.38	11.51	52.57	2.47	17.77	10.10	1.26	73503.38
最 大 值	15.38	13.97	63.95	3.74	20.03	12.25	1.32	82922.45
發生時間	4	14	14	4	15	14		16
最 小 值	1.98	8.55	33.59	0.38	15.18	8.08	1.23	52080.40
發生時間	14	9	9	10	14	9		14
零點偏移(率)	-0.10 %	0.00 %	-0.01 %	-0.02 %		-0.03	-0.01	-0.20 %
全幅偏移(率)	-0.11 %	0.77 %	0.81 %	0.71 %		0.26	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								