

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.25	11.58	66.25	0.56	19.86	11.05	1.08	81657.12
1	8.17	12.62	53.79	0.92	19.72	11.00	1.07	81960.44
2	4.18	14.23	62.21	1.04	17.95	11.69	1.07	77981.21
3	0.73	11.67	61.94	0.42	19.06	11.60	1.13	78353.22
4	2.38	13.34	58.69	0.47	20.64	10.72	1.10	83525.09
5	3.72	13.69	57.44	0.85	18.78	11.43	1.05	82214.21
6	2.81	11.58	67.40	0.75	18.22	12.25	1.06	73121.13
7	3.55	12.75	57.96	0.58	18.81	11.85	1.07	76111.66
8	4.24	14.42	65.39	0.74	19.14	11.91	1.08	74925.33
9	2.80	11.31	56.20	0.56	19.54	11.11	1.07	80398.88
10	0.92	11.67	57.95	1.52	18.13	12.17	1.07	70536.81
11	1.54	12.83	51.06	0.87	18.55	11.22	1.06	81182.84
12	3.02	12.57	67.46	0.80	18.53	11.46	1.05	78885.90
13	5.56	10.39	59.79	0.67	18.84	11.28	1.05	79253.35
14	7.21	12.90	59.01	1.05	18.47	11.46	1.06	78001.52
15	6.84	13.90	67.73	0.53	20.58	11.00	1.07	80119.34
16	7.69	13.72	49.22	1.37	17.52	11.51	1.07	76999.09
17	8.75	12.20	57.21	1.44	18.30	11.16	1.07	78083.13
18	8.83	10.15	56.76	1.05	17.94	11.40	1.06	77616.92
19	8.62	10.28	60.14	1.07	19.03	11.22	1.07	79766.43
20	4.37	10.50	67.99	0.31	19.60	11.56	1.07	76582.04
21	3.73	10.53	49.96	0.70	18.59	11.35	1.06	79554.50
22	5.71	9.95	60.70	0.78	18.87	11.41	1.05	78323.68
23	6.31	11.90	49.49	1.21	17.42	11.47	1.05	78527.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.83	12.11	59.24	0.84	18.84	11.43	1.07	78486.72
最大值	8.83	14.42	67.99	1.52	20.64	12.25	1.29	83525.09
發生時間	18	8	20	10	4	6		4
最小值	0.73	9.95	49.22	0.31	17.42	10.72	1.02	70536.81
發生時間	3	22	16	20	23	4		10
零點偏移(率)	-0.18 %	0.00 %	-0.03 %	-0.00 %		-0.01		0.00 %
全幅偏移(率)	0.17 %	0.37 %	-0.26 %	0.75 %		-0.13		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.80	9.13	52.52	1.31	18.16	10.51	1.15	80462.11
1	0.92	8.26	61.69	0.91	19.59	10.64	1.15	79257.53
2	0.14	9.13	57.70	0.91	18.17	11.36	1.16	74830.92
3	0.08	11.88	68.54	1.43	17.71	11.72	1.17	72645.77
4	0.11	10.96	53.17	0.85	18.68	10.98	1.17	77625.23
5	0.07	10.72	59.68	1.17	17.60	12.09	1.19	69429.65
6	0.23	12.55	45.25	1.99	18.49	9.83	1.15	82794.53
7	2.04	10.61	56.29	2.28	17.41	10.35	1.15	83435.24
8	3.88	8.57	60.02	1.48	17.97	10.61	1.16	80893.56
9	6.86	9.04	53.56	1.54	18.47	10.21	1.16	83272.28
10	9.22	11.25	53.81	3.80	16.10	10.59	1.16	82066.73
11	5.31	8.95	65.00	1.77	16.99	11.22	1.16	76991.14
12	5.18	9.41	46.85	1.38	18.35	10.13	1.15	84132.10
13	5.21	13.38	55.72	1.62	17.33	10.64	1.15	80579.37
14	8.30	15.47	42.86	1.38	19.04	9.95	1.15	83856.15
15	9.22	7.76	51.17	1.52	18.65	10.06	1.15	83518.93
16	9.78	9.76	56.30	2.16	17.10	10.23	1.15	83136.13
17	8.91	6.71	53.92	2.16	17.81	10.28	1.15	82411.17
18	6.54	5.01	59.94	1.05	18.09	10.36	1.15	81915.41
19	8.31	9.75	50.86	1.42	17.97	10.27	1.15	82673.69
20	6.52	6.56	55.61	0.86	18.31	10.42	1.16	80863.64
21	4.57	8.79	49.93	0.79	18.83	10.03	1.16	84027.44
22	4.77	11.21	52.07	1.51	17.48	10.49	1.15	81603.20
23	2.34	9.26	61.27	1.54	17.34	11.06	1.15	77600.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.80	9.75	55.16	1.53	17.98	10.58	1.16	80417.58
最大值	9.78	15.47	68.54	3.80	19.59	12.09	1.22	84132.10
發生時間	16	14	3	10	1	5		12
最小值	0.07	5.01	42.86	0.79	16.10	9.83	1.14	69429.65
發生時間	5	18	14	21	10	6		5
零點偏移(率)	0.00 %	-0.03 %	-0.03 %	-0.00 %		-0.01		0.00 %
全幅偏移(率)	-1.15 %	0.65 %	-1.10 %	0.57 %		-0.26		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.06	14.30	58.83	0.57	17.84	10.86	1.05	83482.50
1	0.15	9.02	52.88	0.83	17.60	10.97	1.05	83955.45
2	1.18	8.99	52.13	0.90	16.74	10.81	1.04	83975.26
3	1.17	9.62	53.47	0.90	16.44	11.02	1.01	80796.70
4	1.75	9.55	53.43	0.79	17.77	10.55	1.00	83246.32
5	1.89	12.49	53.04	0.88	17.12	10.82	1.01	82253.06
6	4.25	10.62	51.23	0.94	17.44	10.52	1.00	82873.88
7	3.93	7.71	47.86	0.94	16.71	10.38	1.02	74784.79
8	1.89	10.11	59.74	1.14	15.86	11.39	1.04	75816.58
9	3.51	10.56	45.76	0.73	17.35	10.47	1.05	83593.69
10	2.94	7.40	52.24	0.87	16.34	10.80	1.05	78682.47
11	1.80	11.10	54.27	1.16	15.41	11.00	1.06	77121.73
12	0.17	9.29	54.18	1.18	15.05	11.14	1.05	77823.86
13	0.54	9.11	51.20	0.96	16.05	10.91	1.07	78781.49
14	0.85	7.79	51.41	0.53	17.30	10.66	1.06	78414.39
15	1.25	12.32	51.45	0.86	16.82	10.55	1.03	80855.77
16	1.37	9.27	54.73	0.89	16.20	10.84	1.06	80984.19
17	6.26	11.53	54.01	1.66	15.06	11.13	1.06	78720.83
18	0.60	6.95	52.83	0.53	16.82	10.88	1.05	79739.54
19	0.60	6.37	54.29	0.66	16.81	10.86	1.03	81481.01
20	0.60	5.76	51.61	0.59	17.26	10.65	1.03	81772.60
21	0.60	8.64	51.46	1.09	15.65	11.06	1.05	79489.72
22	0.88	8.85	56.51	1.28	15.15	11.15	1.07	78680.34
23	0.65	10.10	59.16	1.01	15.60	11.30	1.09	80301.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	1.62	9.48	53.24	0.91	16.52	10.86	1.04	80317.81
最大值	6.26	14.30	59.74	1.66	17.84	11.39	1.10	83975.26
發生時間	17	0	8	17	0	8		2
最小值	0.06	5.76	45.76	0.53	15.05	10.38	0.99	74784.79
發生時間	0	20	9	14	12	7		7
零點偏移(率)	-0.39 %	-0.01 %	0.00 %	-0.05 %		-0.01		0.00 %
全幅偏移(率)	-3.57 %	0.64 %	-0.39 %	0.43 %		0.18		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								