

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.25	7.45	59.31	1.38	16.70	12.12	1.02	69746.38
1	0.39	7.22	60.95	0.99	18.85	11.43	1.01	73597.92
2	5.09	8.26	47.11	1.75	17.14	11.51	0.99	74009.88
3	5.63	4.93	51.37	1.95	16.57	11.58	0.99	72745.52
4	7.95	7.14	49.61	1.95	17.14	11.08	0.99	76031.85
5	6.48	4.63	61.61	1.61	17.06	12.02	0.99	69592.37
6	7.28	10.66	55.65	1.31	17.88	11.42	0.99	73237.06
7	9.39	10.04	53.17	1.68	17.36	11.22	0.99	74641.36
8	5.53	5.23	69.67	1.24	17.08	11.64	1.03	71788.31
9	5.84	7.86	43.99	2.75	15.67	12.41	1.00	63760.07
10	7.27	5.65	55.71	1.19	18.25	11.25	1.01	74567.42
11	8.31	10.36	48.36	1.17	18.30	11.26	1.02	73926.48
12	9.22	5.54	49.85	1.99	16.99	11.68	1.01	71749.51
13	4.91	6.08	61.09	1.06	17.11	11.83	1.01	71175.71
14	2.59	9.71	51.06	2.12	15.48	12.05	1.01	70490.80
15	2.19	4.50	64.55	1.27	16.22	12.31	1.03	68101.97
16	0.57	5.61	47.82	0.98	17.14	11.69	1.02	72429.84
17	0.58	5.28	48.00	0.83	17.41	11.69	0.99	72330.02
18	0.91	6.42	56.34	0.83	17.28	11.62	1.00	73395.47
19	0.22	8.32	60.35	0.89	16.88	12.02	1.03	70018.48
20	1.91	8.27	54.13	1.09	17.08	11.60	1.04	73536.06
21	6.01	14.83	50.86	1.94	15.71	11.88	1.03	72169.22
22	8.94	6.31	57.64	1.35	17.20	11.57	1.02	73580.36
23	5.22	7.87	58.76	0.94	17.48	11.74	1.02	72013.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.78	7.42	54.87	1.43	17.08	11.69	1.01	72026.50
最大值	9.39	14.83	69.67	2.75	18.85	12.41	1.05	76031.85
發生時間	7	21	8	9	1	9		4
最小值	0.22	4.50	43.99	0.83	15.48	11.08	0.99	63760.07
發生時間	19	15	9	17	14	4		9
零點偏移(率)	-0.02 %	0.00 %	-0.03 %	0.00 %		0.01		0.00 %
全幅偏移(率)	0.02 %	0.09 %	-0.20 %	0.22 %		-0.04		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.73	2.14	53.05	2.42	16.67	10.60	0.99	84542.90
1	1.74	2.52	49.96	1.95	17.44	10.50	0.99	84246.32
2	7.14	6.91	55.39	2.31	17.27	10.34	0.99	86329.59
3	8.29	7.35	51.92	2.25	16.76	10.38	1.00	86495.06
4	8.56	7.37	51.97	1.83	17.35	10.40	1.01	85368.68
5	9.51	4.75	51.44	1.90	17.67	10.07	1.01	87169.68
6	9.68	6.40	50.57	1.88	17.55	10.18	1.01	81842.18
7	9.65	5.48	56.70	1.79	17.60	10.26	1.01	86041.77
8	9.51	8.46	61.15	1.45	17.74	9.86	1.01	89333.29
9	8.87	3.71	49.76	1.83	16.73	10.42	1.01	85812.97
10	7.56	3.49	52.74	2.03	16.06	10.87	1.03	82552.47
11	5.61	10.07	54.15	1.80	17.05	10.68	1.02	82717.67
12	2.16	3.68	52.04	1.79	16.63	10.78	1.02	83138.01
13	4.16	4.90	53.09	2.07	16.15	10.87	1.01	83029.43
14	8.58	9.29	53.15	2.74	15.06	10.89	1.00	83062.67
15	7.80	3.12	51.26	2.50	16.40	10.63	1.01	83908.60
16	2.39	4.00	53.39	1.10	18.29	10.61	1.02	82760.38
17	0.11	6.67	49.04	0.76	18.69	10.17	0.99	85439.33
18	2.66	5.17	46.06	1.91	16.98	10.23	0.99	86522.71
19	4.38	3.15	50.56	2.00	16.70	10.48	0.99	85237.07
20	8.21	6.55	51.57	2.73	15.80	10.37	0.99	86649.97
21	6.97	7.56	52.50	2.54	16.00	10.67	0.99	84352.24
22	6.21	5.81	52.10	2.39	16.36	10.68	0.99	83761.95
23	1.61	4.00	59.57	1.09	17.87	10.87	0.99	80664.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.17	5.52	52.63	1.96	16.95	10.49	1.00	84624.14
最大值	9.68	10.07	61.15	2.74	18.69	10.89	1.04	89333.29
發生時間	6	11	8	14	17	14		8
最小值	0.11	2.14	46.06	0.76	15.06	9.86	0.99	80664.50
發生時間	17	0	18	17	14	8		23
零點偏移(率)	-0.10 %	-0.08 %	-0.01 %	-0.01 %		0.02		-0.20 %
全幅偏移(率)	0.04 %	-0.11 %	-0.56 %	0.10 %		0.00		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.87	5.47	43.65	2.02	15.81	10.46	0.97	79573.78
1	6.42	3.88	47.90	1.57	17.88	10.51	0.95	79450.85
2	4.67	9.59	46.50	1.90	16.52	10.03	0.94	80384.42
3	6.10	3.43	45.64	2.19	15.32	10.53	0.94	76919.93
4	4.81	9.18	46.33	2.23	14.79	10.71	0.94	75034.78
5	5.57	6.15	65.71	1.83	17.63	10.06	0.96	84157.86
6	11.38	5.58	54.13	3.64	15.03	10.64	0.97	85299.40
7	6.05	7.61	60.67	2.05	15.80	10.82	1.00	81331.34
8	9.01	4.99	52.26	2.35	15.47	10.50	0.97	78090.56
9	9.27	7.16	42.98	2.89	14.27	10.33	0.95	75719.60
10	8.28	3.80	45.25	2.62	14.58	10.36	0.98	73063.32
11	3.25	5.44	45.25	2.15	13.79	10.64	0.95	70320.21
12	0.58	3.52	62.77	1.00	15.60	10.80	0.92	69779.28
13	0.92	5.37	48.80	1.80	13.90	11.44	0.92	68119.97
14	0.27	5.08	51.55	1.20	15.14	11.01	0.92	72408.35
15	1.52	16.60	54.92	1.89	13.90	10.78	0.96	74059.57
16	2.83	2.31	49.83	1.73	14.62	10.73	0.97	76588.65
17	1.73	5.44	54.98	1.35	14.95	11.03	0.95	80493.65
18	0.60	4.02	54.79	1.00	16.07	10.95	0.96	79579.70
19	1.04	4.94	52.78	1.15	16.14	10.84	0.99	81602.72
20	0.53	4.54	54.48	1.12	15.97	10.84	0.98	80768.42
21	1.10	10.42	51.37	1.67	14.43	11.09	0.98	79758.63
22	3.44	7.37	56.08	1.94	14.26	11.42	0.98	79484.68
23	4.49	5.91	52.31	1.55	15.05	11.14	0.97	77173.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.24	6.16	51.71	1.87	15.29	10.74	0.96	77465.12
最大值	11.38	16.60	65.71	3.64	17.88	11.44	1.02	85299.40
發生時間	6	15	5	6	1	13		6
最小值	0.27	2.31	42.98	1.00	13.79	10.03	0.91	68119.97
發生時間	14	16	9	12	11	2		13
零點偏移(率)	-0.02 %	0.00 %	-0.09 %	-0.01 %		0.03		-0.10 %
全幅偏移(率)	0.16 %	0.53 %	-0.28 %	0.23 %		0.35		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								