

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.46	11.66	48.70	2.79	18.51	10.84	1.33	83251.73
1	8.96	11.72	45.64	2.61	19.30	10.70	1.35	83368.40
2	9.30	12.10	53.44	3.53	19.23	10.80	1.35	82365.26
3	9.13	11.33	53.14	3.81	17.78	10.98	1.34	82697.92
4	7.29	11.89	53.18	4.40	16.42	11.14	1.34	81655.91
5	9.25	12.70	65.14	3.61	16.39	11.27	1.34	84758.50
6	8.92	12.70	47.64	2.76	17.49	11.05	1.32	82907.54
7	9.83	12.80	55.64	2.93	17.26	10.87	1.34	85078.41
8	11.24	12.66	53.99	3.84	15.35	11.44	1.33	79756.45
9	8.67	11.68	53.39	1.54	18.95	10.85	1.33	82132.84
10	9.99	11.35	52.38	2.27	16.81	10.95	1.29	83212.11
11	8.74	11.65	45.43	2.15	15.86	11.52	1.31	77319.88
12	9.29	12.28	46.87	1.55	17.27	11.77	1.33	73217.49
13	9.76	12.02	38.93	1.46	18.22	11.29	1.30	77540.35
14	9.05	11.50	43.54	1.59	17.69	11.01	1.30	80192.60
15	9.44	11.75	48.42	1.82	17.48	11.39	1.29	76438.19
16	9.21	11.21	52.14	2.59	17.89	10.68	1.29	84662.28
17	9.41	11.18	39.65	2.32	18.66	10.54	1.29	85017.21
18	10.09	12.46	47.67	2.14	18.27	10.59	1.29	84700.63
19	9.23	11.92	41.99	2.20	17.46	10.82	1.29	83813.57
20	8.40	12.23	42.80	3.58	15.11	10.98	1.29	82231.54
21	9.13	11.51	47.81	1.93	17.04	10.73	1.29	83209.33
22	9.19	11.89	44.45	2.25	17.83	10.71	1.29	82475.15
23	8.93	12.07	37.06	2.82	16.96	11.07	1.30	81709.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.25	11.93	48.29	2.60	17.47	11.00	1.31	81821.37
最大值	11.24	12.80	65.14	4.40	19.30	11.77	1.36	85078.41
發生時間	8	7	5	4	1	12		7
最小值	7.29	11.18	37.06	1.46	15.11	10.54	1.28	73217.49
發生時間	4	17	23	13	20	17		12
零點偏移(率)	0.00 %	-0.00 %	-0.02 %	-0.02 %		-0.06	-0.01	0.30 %
全幅偏移(率)	0.37 %	-0.56 %	-0.21 %	-0.14 %		0.27	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.87	9.86	63.21	0.54	19.20	11.37	0.83	69091.76
1	10.37	25.28	67.56	0.64	20.65	10.50	0.83	79940.32
2	14.90	10.54	55.69	1.06	19.85	10.64	0.84	81394.71
3	17.37	9.67	60.47	1.16	19.06	11.12	0.83	80393.97
4	11.54	9.48	56.79	0.73	18.96	10.87	0.83	80530.05
5	12.56	9.78	65.77	0.95	18.25	11.33	0.83	79032.75
6	12.75	7.48	58.29	0.79	19.53	10.70	0.82	82362.75
7	12.47	8.27	52.73	0.58	19.41	10.73	0.82	80314.07
8	9.57	8.70	53.15	0.82	18.40	11.36	0.83	73210.83
9	12.08	8.40	45.22	1.00	18.66	11.12	0.84	72858.33
10	8.72	7.40	51.52	0.84	18.32	11.24	0.84	71495.20
11	10.65	8.03	49.49	1.02	17.94	11.19	0.83	71073.41
12	9.16	7.87	50.16	1.01	17.64	11.18	0.84	71808.05
13	10.31	9.36	49.17	0.73	18.05	11.36	0.83	69918.41
14	14.34	9.31	44.90	1.18	17.74	11.32	0.83	72084.57
15	12.91	8.34	48.98	0.99	17.74	11.67	0.83	71914.27
16	15.54	8.63	59.61	0.93	17.74	11.49	0.83	77613.07
17	14.22	8.14	58.92	0.88	18.51	10.90	0.84	80826.16
18	12.62	9.19	49.79	0.76	18.39	10.83	0.84	79879.41
19	9.66	8.38	64.89	0.28	19.78	10.68	0.84	78109.46
20	10.36	10.00	54.97	0.29	21.27	10.01	0.84	84739.23
21	10.41	10.68	58.67	0.52	19.16	11.09	0.85	78618.99
22	9.62	10.61	62.72	0.71	18.75	11.82	0.84	70656.02
23	9.43	11.67	57.66	0.71	18.89	11.57	0.83	72459.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.81	9.79	55.85	0.80	18.83	11.09	0.83	76263.57
最大值	17.37	25.28	67.56	1.18	21.27	11.82	0.86	84739.23
發生時間	3	1	1	14	20	22		20
最小值	8.72	7.40	44.90	0.28	17.64	10.01	0.81	69091.76
發生時間	10	10	14	19	12	20		0
零點偏移(率)	-0.07 %	-0.03 %	-0.07 %	-0.00 %		-0.10	-0.06	0.00 %
全幅偏移(率)	-0.36 %	0.82 %	-0.10 %	0.04 %		-0.16	0.31	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.47	11.50	57.59	3.03	18.51	10.10	1.36	76032.75
1	11.07	11.37	53.87	3.03	19.97	9.79	1.37	77480.62
2	14.33	11.70	55.35	4.00	19.15	10.15	1.38	75041.03
3	9.57	11.47	57.82	3.15	17.61	10.07	1.36	74702.71
4	10.10	12.49	54.91	3.50	16.55	10.20	1.36	71543.98
5	9.49	11.56	57.36	3.23	17.59	10.14	1.36	71574.68
6	12.90	11.60	60.78	3.39	17.68	10.18	1.36	76045.97
7	10.95	9.94	60.64	3.04	17.31	10.43	1.36	79273.83
8	9.07	11.49	53.41	3.11	16.47	10.32	1.36	76751.95
9	9.34	11.40	54.44	1.73	17.15	10.20	1.35	73485.30
10	10.05	11.26	55.43	1.61	16.67	10.09	1.38	73295.33
11	9.36	10.95	56.65	1.45	17.16	9.84	1.32	72901.09
12	8.27	11.07	52.83	1.37	18.30	9.82	1.31	73773.83
13	9.02	11.41	54.83	1.36	17.62	10.23	1.31	74424.44
14	9.73	11.44	54.74	1.48	18.77	9.95	1.34	76654.42
15	9.37	11.64	58.23	2.39	16.40	10.51	1.36	73689.75
16	9.70	11.63	58.72	2.92	16.73	10.39	1.36	75289.20
17	8.68	11.67	53.93	2.86	16.92	10.28	1.36	76381.08
18	9.44	11.50	59.98	2.94	18.56	10.09	1.37	79341.03
19	9.51	11.65	55.11	3.06	18.49	10.25	1.38	80571.92
20	9.09	11.59	54.96	2.92	17.74	10.03	1.36	81305.64
21	10.49	12.41	47.72	1.97	17.06	10.25	1.35	76024.49
22	7.60	12.35	58.53	2.37	17.25	10.93	1.31	74783.60
23	8.69	12.08	53.11	2.77	17.92	10.43	1.33	76312.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.80	11.55	55.87	2.61	17.65	10.19	1.35	75695.05
最大值	14.33	12.49	60.78	4.00	19.97	10.93	1.40	81305.64
發生時間	2	4	6	2	1	22		20
最小值	7.60	9.94	47.72	1.36	16.40	9.79	1.31	71543.98
發生時間	22	7	21	13	15	1		4
零點偏移(率)	-0.09 %	-0.05 %	-0.02 %	0.00 %		-0.10	-0.01	0.00 %
全幅偏移(率)	0.20 %	0.47 %	-0.12 %	0.17 %		0.18	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								