

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月05日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.27	15.84	64.99	2.56	15.69	12.24	1.14	71634.93
1	10.54	12.66	44.70	1.19	16.98	10.81	1.13	85061.05
2	9.68	12.76	48.98	2.06	17.33	11.45	1.13	80472.70
3	9.01	13.04	42.10	2.06	16.77	11.67	1.14	79079.79
4	9.52	12.17	43.49	1.98	16.26	11.35	1.16	81829.72
5	9.88	13.00	53.52	1.83	16.54	11.44	1.20	80240.35
6	9.95	12.64	44.54	2.09	16.22	10.99	1.21	84866.58
7	9.14	13.18	54.08	1.75	16.33	11.58	1.22	80030.01
8	9.93	12.96	30.75	2.22	15.72	11.27	1.23	82978.49
9	9.85	13.24	41.19	1.69	16.41	11.35	1.24	82080.36
10	9.46	12.73	42.65	3.20	14.91	11.27	1.25	83542.46
11	8.89	13.82	46.11	3.48	13.50	12.11	1.25	78264.51
12	9.49	13.13	55.47	1.93	15.68	11.70	1.24	80075.12
13	8.90	13.35	48.08	2.58	15.65	11.42	1.25	80779.89
14	6.19	13.71	36.80	3.67	13.79	12.04	1.25	77621.55
15	9.12	13.66	46.16	3.82	14.47	12.15	1.22	76387.95
16	9.30	12.90	51.33	1.89	15.90	11.52	1.22	80384.43
17	9.45	14.97	52.79	1.41	16.62	11.43	1.22	79099.76
18	9.01	8.17	38.62	1.37	17.12	10.79	1.19	84064.61
19	9.68	15.44	47.67	1.57	15.25	11.99	1.22	79752.93
20	9.74	13.24	39.90	0.92	15.24	11.77	1.21	80289.89
21	9.47	13.10	48.28	1.45	15.51	11.89	1.23	78629.67
22	9.34	13.11	46.29	1.33	15.88	11.85	1.25	78641.40
23	10.24	12.36	47.68	1.96	16.33	11.20	1.25	83148.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.34	13.13	46.51	2.08	15.84	11.55	1.21	80373.19
最大值	10.54	15.84	64.99	3.82	17.33	12.24	1.27	85061.05
發生時間	1	0	0	15	2	0		1
最小值	6.19	8.17	30.75	0.92	13.50	10.79	1.13	71634.93
發生時間	14	18	8	20	11	18		0
零點偏移(率)	-0.03 %	-0.04 %	-0.05 %	-0.01 %		-0.18	-0.01	0.20 %
全幅偏移(率)	0.67 %	0.51 %	1.01 %	0.42 %		0.03	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月05日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.77	11.51	54.78	1.17	16.71	10.42	1.02	78386.29
1	1.96	11.61	56.46	1.40	17.30	10.44	1.02	78002.26
2	1.36	11.18	46.47	0.99	17.71	9.93	1.02	78126.59
3	9.60	11.36	44.13	0.84	17.67	9.87	1.02	78941.15
4	9.79	11.28	40.75	0.79	17.37	10.09	1.02	77499.34
5	9.65	11.10	41.57	1.13	17.61	9.85	1.02	78233.40
6	2.88	13.81	57.42	1.59	16.40	10.32	0.99	78140.21
7	10.09	11.33	38.06	1.21	16.43	10.30	0.98	77893.59
8	10.05	11.15	42.34	1.20	17.16	10.02	0.99	78823.39
9	10.04	11.13	44.79	1.13	17.02	10.02	0.99	78905.75
10	9.93	11.08	47.54	1.04	16.85	10.01	1.01	79080.13
11	9.65	11.36	47.48	1.33	15.36	10.19	1.00	77804.96
12	9.58	11.27	43.53	1.41	15.14	10.13	1.01	75720.30
13	9.39	11.10	28.24	0.75	17.28	9.58	0.99	76127.24
14	9.50	10.92	53.59	0.83	16.69	9.84	0.99	77625.79
15	9.48	11.16	43.13	1.05	17.92	9.65	0.99	75716.38
16	9.06	10.82	37.69	0.91	18.16	9.14	1.02	78366.94
17	9.25	11.40	39.64	1.43	16.64	9.95	1.01	77278.37
18	9.37	11.06	42.32	1.11	17.21	9.87	1.00	77853.36
19	9.54	11.17	51.88	1.28	17.34	9.88	0.99	77084.20
20	9.41	11.14	43.61	1.05	16.49	9.90	0.97	78411.57
21	9.80	11.21	47.81	2.08	17.60	10.00	0.99	79518.02
22	10.47	11.60	52.05	2.87	16.44	10.51	1.02	76430.76
23	10.51	11.46	45.86	2.74	17.24	10.29	1.02	78597.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.46	11.34	45.46	1.31	16.99	10.01	1.00	77856.99
最大值	10.51	13.81	57.42	2.87	18.16	10.51	1.03	79518.02
發生時間	23	6	6	22	16	22		21
最小值	1.36	10.82	28.24	0.75	15.14	9.14	0.95	75716.38
發生時間	2	16	13	13	12	16		15
零點偏移(率)	-0.03 %	-0.04 %	-0.03 %	-0.01 %		-0.09	-0.01	0.10 %
全幅偏移(率)	0.42 %	0.06 %	0.96 %	-0.33 %		-0.16	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月05日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.18	10.79	36.82	1.82	17.45	9.19	1.46	73979.66
1	9.90	12.27	40.06	2.69	17.44	9.17	1.46	73511.94
2	7.58	12.06	38.11	2.62	16.81	8.92	1.44	71626.09
3	9.46	10.75	35.78	2.84	17.96	8.73	1.43	75358.61
4	9.78	10.68	35.54	2.71	17.11	9.01	1.43	73916.91
5	10.00	10.96	36.45	2.27	18.60	8.94	1.45	75334.33
6	9.66	10.82	35.85	2.26	17.16	9.16	1.46	74858.58
7	8.59	13.18	34.72	1.61	17.88	9.09	1.46	78358.40
8	9.32	11.11	32.88	2.45	17.68	9.03	1.46	74484.84
9	10.53	11.13	32.73	2.71	17.23	8.99	1.45	75587.00
10	8.92	10.72	33.16	2.50	17.01	9.23	1.47	74827.98
11	9.29	10.78	39.12	2.35	15.69	9.57	1.45	72920.29
12	9.51	10.75	46.34	2.21	16.62	9.56	1.45	72133.78
13	9.97	10.94	40.34	2.29	16.48	9.25	1.43	73776.88
14	9.34	10.76	41.13	2.01	17.07	9.42	1.43	73632.24
15	9.16	10.81	40.54	1.93	17.02	9.56	1.42	72517.61
16	9.65	10.98	49.49	2.32	18.47	9.63	1.43	74003.13
17	9.21	11.11	43.05	1.94	17.27	9.83	1.43	73037.49
18	9.01	10.96	47.13	1.92	17.42	9.79	1.43	73546.42
19	10.05	11.23	54.45	2.65	16.43	9.78	1.43	71631.94
20	9.11	10.95	42.25	2.38	17.74	9.19	1.42	73862.21
21	9.38	11.30	41.91	2.28	16.13	9.57	1.43	72387.62
22	9.86	11.15	46.98	2.23	17.17	9.77	1.45	73026.89
23	10.00	11.12	46.18	1.93	17.83	9.88	1.44	73266.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.44	11.14	40.46	2.29	17.24	9.34	1.44	73816.13
最大值	10.53	13.18	54.45	2.84	18.60	9.88	1.48	78358.40
發生時間	9	7	19	3	5	23		7
最小值	7.58	10.68	32.73	1.61	15.69	8.73	1.41	71626.09
發生時間	2	4	9	7	11	3		2
零點偏移(率)	-0.13 %	-0.06 %	-0.05 %	-0.01 %		-0.08	-0.01	0.00 %
全幅偏移(率)	-1.80 %	0.17 %	-0.19 %	0.02 %		0.00	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								