

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.86	12.31	54.15	1.67	16.90	11.80	0.99	76913.21
1	4.49	8.52	57.30	0.72	19.75	11.56	1.01	76489.17
2	8.88	10.25	56.04	1.99	17.09	11.51	1.00	79268.68
3	3.83	10.75	58.30	0.93	18.58	11.60	0.99	77363.19
4	5.23	9.85	56.75	1.65	17.18	11.62	0.99	77828.23
5	1.13	8.21	65.42	0.90	17.63	12.11	0.99	79755.77
6	7.48	10.27	53.71	1.42	17.52	11.52	0.99	78164.92
7	8.13	9.77	57.65	1.34	18.39	11.42	0.99	77329.66
8	7.44	4.30	51.28	1.76	16.67	11.37	0.99	77288.21
9	7.64	2.48	52.72	1.83	17.01	11.93	1.00	72573.93
10	5.89	3.26	57.33	0.96	17.62	11.98	1.00	74153.00
11	6.04	3.83	50.33	2.49	15.40	12.56	1.00	69033.92
12	8.36	2.22	55.22	2.22	16.96	12.00	0.99	74799.72
13	5.33	5.61	57.57	1.57	17.53	11.81	1.02	75260.19
14	4.24	5.77	58.44	1.23	18.09	11.56	1.04	77768.72
15	9.59	6.27	57.36	2.19	16.62	11.85	1.03	75722.33
16	8.51	7.78	54.24	2.27	16.14	11.90	1.02	74837.18
17	8.90	7.23	60.57	1.17	17.48	11.82	1.02	76466.41
18	4.88	7.90	64.85	0.59	18.41	11.70	1.05	76755.24
19	6.12	8.21	49.88	1.31	17.72	11.52	1.04	78624.93
20	4.89	10.27	59.58	0.54	19.83	11.46	1.05	77506.75
21	1.19	9.24	58.70	1.11	18.18	11.86	1.03	75117.98
22	1.49	8.78	57.06	0.89	18.69	11.65	1.02	76707.34
23	1.36	10.72	64.69	0.70	17.89	11.86	1.02	75784.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.83	7.66	57.05	1.39	17.64	11.75	1.01	76313.04
最大值	9.59	12.31	65.42	2.49	19.83	12.56	1.05	79755.77
發生時間	15	0	5	11	20	11		5
最小值	1.13	2.22	49.88	0.54	15.40	11.37	0.99	69033.92
發生時間	5	12	19	20	11	8		11
零點偏移(率)	-0.02 %	-0.01 %	-0.05 %	-0.01 %		-0.05		0.00 %
全幅偏移(率)	0.02 %	-0.01 %	0.04 %	0.14 %		-0.07		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.34	10.02	46.84	1.30	18.13	10.38	0.99	84737.51
1	0.49	3.50	49.55	1.89	18.33	10.64	0.99	82494.89
2	0.10	5.51	56.75	1.52	18.64	10.38	1.00	83979.46
3	0.16	8.02	57.07	1.73	18.02	10.37	0.99	85278.70
4	1.22	5.97	57.26	1.83	17.83	10.19	0.99	86803.12
5	2.12	6.52	62.14	1.75	17.23	10.61	0.99	84300.77
6	2.34	6.22	56.49	1.91	17.87	10.22	1.02	86714.50
7	1.19	5.20	54.93	1.27	17.89	10.49	1.02	83250.03
8	1.50	6.95	53.77	1.29	18.99	10.08	1.02	85420.02
9	3.33	8.16	56.00	1.62	18.64	10.04	1.02	87522.16
10	6.15	4.44	53.99	1.33	19.35	9.62	1.02	83354.76
11	7.16	8.76	53.60	2.83	15.91	10.51	1.01	81798.09
12	7.10	5.21	53.71	2.48	15.83	11.35	1.02	79028.27
13	3.75	9.25	53.02	2.66	15.33	11.13	1.02	81464.88
14	2.90	2.38	61.58	2.60	15.61	11.02	1.01	82047.59
15	10.66	8.12	56.95	2.98	14.75	11.19	1.02	80764.89
16	8.86	1.87	53.50	2.25	15.93	10.77	1.02	83686.61
17	9.28	5.25	56.89	1.87	16.83	10.68	1.02	84111.28
18	3.82	5.33	59.57	1.90	16.48	10.99	1.02	79754.32
19	1.00	4.52	55.88	1.23	18.41	10.52	1.01	83807.89
20	0.11	6.53	55.38	1.65	18.14	10.31	1.01	85445.94
21	0.16	5.67	57.05	1.95	17.06	10.53	1.02	83567.80
22	0.59	9.15	65.09	1.15	18.12	10.62	1.02	82289.36
23	1.48	7.95	51.82	1.96	17.17	10.50	1.01	84508.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.24	6.27	55.78	1.87	17.35	10.55	1.01	83588.81
最大值	10.66	10.02	65.09	2.98	19.35	11.35	1.03	87522.16
發生時間	15	0	22	15	10	12		9
最小值	0.10	1.87	46.84	1.15	14.75	9.62	0.99	79028.27
發生時間	2	16	0	22	15	10		12
零點偏移(率)	-0.46 %	0.00 %	-0.01 %	-0.01 %		0.00		-0.20 %
全幅偏移(率)	-0.04 %	0.19 %	-0.65 %	-0.07 %		-0.29		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.58	5.28	47.06	1.44	16.52	10.71	0.94	79516.84
1	2.91	5.17	52.83	1.59	17.03	11.03	0.94	77585.64
2	3.27	6.33	55.85	1.69	16.27	10.89	0.96	79502.36
3	1.66	11.14	58.43	1.99	15.02	11.09	0.97	77351.03
4	3.05	10.96	56.30	2.39	14.28	11.21	0.95	76679.42
5	2.72	9.14	59.77	1.54	17.24	10.68	0.96	80066.96
6	4.26	9.45	51.67	1.77	16.14	10.62	0.95	78671.13
7	8.34	3.83	43.46	1.90	16.92	10.22	0.98	73973.08
8	6.73	6.18	49.13	2.23	15.11	11.19	0.99	74766.72
9	6.96	4.08	48.70	1.92	16.32	10.69	0.98	78183.09
10	4.43	2.81	54.05	1.74	16.19	11.19	0.98	75930.88
11	1.68	5.88	57.64	1.74	15.65	11.51	0.98	71940.78
12	4.34	14.52	57.18	2.19	14.65	11.80	0.98	68972.38
13	6.04	6.03	55.04	1.89	15.77	11.30	0.98	71628.48
14	5.36	17.82	50.39	2.23	15.16	10.99	1.03	74005.53
15	3.02	3.93	46.12	1.77	16.07	10.47	0.99	74523.35
16	7.19	2.43	51.12	2.38	15.00	10.78	0.99	74091.16
17	7.06	4.33	56.16	1.79	15.85	10.90	1.00	77738.43
18	3.85	6.64	54.75	1.49	16.88	10.65	1.02	78941.62
19	2.54	6.26	57.25	1.23	17.32	10.82	1.05	80602.30
20	0.46	7.53	58.72	1.24	17.21	10.86	1.04	80637.96
21	0.10	8.22	58.63	1.41	16.06	11.01	1.02	79334.72
22	1.02	8.22	54.89	1.66	15.38	11.16	0.98	77613.03
23	1.76	9.06	57.85	1.41	16.39	10.98	1.00	78288.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.85	7.30	53.87	1.78	16.02	10.95	0.99	76689.38
最大值	8.34	17.82	59.77	2.39	17.32	11.80	1.05	80637.96
發生時間	7	14	5	4	19	12		20
最小值	0.10	2.43	43.46	1.23	14.28	10.22	0.94	68972.38
發生時間	21	16	7	19	4	7		12
零點偏移(率)	0.00 %	0.00 %	-0.10 %	-0.03 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.22 %	-0.50 %	0.18 %		0.04		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								