

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月14日

報表日期: 114年10月14日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.72	13.97	58.03	1.83	16.86	11.96	1.25	76815.46
1	9.25	13.77	41.62	3.34	16.75	11.61	1.25	79078.36
2	8.55	13.91	63.55	2.28	16.54	11.99	1.23	71268.16
3	10.27	13.16	49.54	3.87	15.85	11.51	1.22	72368.89
4	10.95	13.31	45.13	5.09	15.67	11.55	1.23	73196.96
5	5.28	14.63	68.66	3.78	15.57	12.61	1.21	72339.24
6	6.45	13.88	65.36	3.40	15.68	12.19	1.22	68196.16
7	9.16	13.48	66.46	3.64	15.56	11.97	1.23	69907.22
8	8.85	13.25	57.02	2.78	16.53	11.66	1.25	70700.79
9	8.97	12.81	61.31	2.95	16.67	11.36	1.23	73063.83
10	8.00	12.91	53.96	2.45	17.26	11.35	1.23	72265.27
11	9.94	12.79	62.94	3.08	16.73	11.33	1.23	73652.71
12	8.13	13.01	57.34	3.71	14.81	11.70	1.22	71502.33
13	10.28	13.22	55.08	2.73	17.01	11.51	1.21	71653.60
14	9.11	14.17	62.30	2.77	16.87	11.38	1.20	72737.92
15	7.16	15.69	54.19	3.87	14.69	11.90	1.20	70762.03
16	10.67	13.97	60.71	2.91	16.56	11.91	1.23	69745.66
17	9.74	12.90	62.80	4.15	16.09	11.27	1.23	74509.15
18	9.59	13.50	52.70	1.81	17.80	10.73	1.21	77035.10
19	8.59	15.25	49.96	2.57	15.41	11.23	1.22	73500.40
20	8.37	13.69	49.70	2.84	15.77	11.34	1.20	71219.02
21	9.45	13.25	43.98	3.14	15.48	11.43	1.20	71149.25
22	10.33	13.04	47.04	3.03	16.85	11.13	1.21	73633.92
23	7.63	13.27	61.52	2.65	16.40	11.67	1.23	69429.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.89	13.62	56.29	3.11	16.23	11.60	1.22	72488.79
最 大 值	10.95	15.69	68.66	5.09	17.80	12.61	1.25	79078.36
發生時間	4	15	5	4	18	5		1
最 小 值	5.28	12.79	41.62	1.81	14.69	10.73	1.19	68196.16
發生時間	5	11	1	18	15	18		6
零點偏移(率)	-0.10 %	-0.05 %	-0.03 %	-0.01 %		0.04		0.30 %
全幅偏移(率)	0.09 %	0.53 %	0.02 %	-0.37 %		0.15		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月14日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	2.26	12.87	50.02	0.50	18.07	11.21	0.95	75868.05
1	2.45	12.41	38.04	0.75	19.25	10.63	0.96	83293.70
2	2.54	12.25	43.46	0.81	18.24	10.71	0.95	83461.04
3	3.12	12.59	43.16	1.69	17.07	11.08	0.94	82040.54
4	2.68	12.68	43.92	0.95	17.81	11.11	0.94	80855.24
5	2.16	12.59	44.74	1.68	16.99	11.13	0.94	81385.80
6	2.85	12.49	45.89	2.00	17.07	11.01	0.94	79961.87
7	2.62	12.27	47.06	1.96	16.38	10.91	0.94	82949.39
8	3.98	13.55	49.91	1.54	16.51	10.93	0.97	82937.03
9	5.07	12.31	58.19	0.88	17.60	10.84	0.97	83005.96
10	4.92	12.38	48.66	0.79	18.06	10.82	0.96	81909.71
11	3.04	12.34	47.22	1.31	17.45	10.84	0.96	83180.98
12	2.88	12.59	56.28	1.06	17.70	10.73	0.94	83964.83
13	8.86	12.63	54.51	2.17	15.85	11.08	0.94	82324.90
14	6.81	14.01	50.50	1.68	15.40	11.39	0.94	79609.45
15	3.20	14.42	46.71	1.67	16.05	11.18	0.93	82327.97
16	3.14	13.95	50.12	1.30	18.04	10.71	0.94	83377.20
17	4.74	13.45	45.77	0.73	19.07	10.21	0.94	88539.48
18	6.96	14.13	49.07	1.76	17.21	10.86	0.94	84383.92
19	8.59	14.22	46.16	1.79	17.40	10.65	0.94	85556.04
20	7.54	14.26	44.77	2.25	17.39	10.88	0.94	83081.59
21	7.08	12.95	48.86	0.76	19.13	10.32	0.94	86221.17
22	6.13	13.95	61.27	0.88	17.53	11.73	0.94	76905.72
23	5.81	13.20	51.62	1.12	18.08	11.18	0.94	80724.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.56	13.10	48.58	1.33	17.47	10.92	0.95	82411.11
最 大 值	8.86	14.42	61.27	2.25	19.25	11.73	0.98	88539.48
發生時間	13	15	22	20	1	22		17
最 小 值	2.16	12.25	38.04	0.50	15.40	10.21	0.93	75868.05
發生時間	5	2	1	0	14	17		0
零點偏移(率)	-0.12 %	-0.06 %	-0.06 %	-0.01 %		-0.04		-0.20 %
全幅偏移(率)	0.29 %	0.39 %	-0.21 %	-0.20 %		-0.10		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月14日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.87	14.09	56.50	1.85	18.43	9.01	1.34	73144.54
1	9.72	13.75	62.95	2.17	18.08	9.66	1.35	78855.54
2	8.99	12.87	62.76	2.16	16.88	9.85	1.39	80697.42
3	10.60	12.85	60.15	2.43	16.06	9.92	1.41	79228.79
4	8.16	12.60	62.08	2.24	16.31	9.96	1.40	79073.00
5	9.20	13.78	60.67	2.33	16.73	9.80	1.39	77916.33
6	6.84	12.86	53.64	2.31	16.08	9.61	1.40	75318.74
7	13.45	11.19	48.42	2.42	16.58	9.62	1.41	74793.57
8	9.19	11.62	48.74	2.24	16.33	9.81	1.35	79592.69
9	12.10	12.19	47.27	2.76	15.26	10.37	1.37	77976.49
10	8.71	12.33	56.67	2.01	15.77	10.73	1.35	79029.31
11	8.63	12.00	55.06	1.66	17.04	10.32	1.37	80292.92
12	10.86	11.86	58.96	2.07	16.41	10.58	1.34	81209.39
13	5.73	12.29	58.84	1.49	16.03	11.00	1.31	78952.64
14	8.15	13.29	60.19	1.58	17.88	10.30	1.31	84477.39
15	6.87	12.35	54.27	1.77	15.62	10.71	1.31	77931.60
16	9.10	13.86	45.69	2.17	16.51	9.91	1.36	75431.98
17	9.94	12.86	38.05	1.92	15.95	9.75	1.34	76124.60
18	8.51	11.72	37.82	1.92	18.76	8.06	1.33	78636.18
19	8.90	12.05	38.08	1.59	17.94	8.35	1.37	75038.05
20	9.92	11.75	38.73	2.15	18.26	7.92	1.37	77619.47
21	8.82	11.29	37.15	1.73	18.06	8.11	1.36	76882.13
22	9.97	11.53	46.56	2.26	17.43	9.00	1.36	78828.96
23	8.41	11.77	63.66	1.66	16.84	10.28	1.34	77217.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.07	12.45	52.20	2.04	16.88	9.69	1.36	78094.54
最 大 值	13.45	14.09	63.66	2.76	18.76	11.00	1.44	84477.39
發生時間	7	0	23	9	18	13		14
最 小 值	5.73	11.19	37.15	1.49	15.26	7.92	1.31	73144.54
發生時間	13	7	21	13	9	20		0
零點偏移(率)	-0.06 %	0.00 %	-0.01 %	-0.03 %		0.01		0.10 %
全幅偏移(率)	-0.94 %	-0.22 %	0.52 %	-0.52 %		0.35		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								