

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.33	11.33	63.47	1.42	19.07	11.49	1.02	77381.15
1	9.56	12.27	58.85	1.43	19.81	10.86	1.01	81818.97
2	9.28	14.00	50.07	2.68	16.12	11.94	0.99	75800.03
3	6.40	15.16	64.41	1.54	17.81	12.60	1.00	69307.40
4	8.63	13.12	57.47	1.84	18.74	11.41	0.99	78458.68
5	3.61	11.75	50.35	0.93	20.51	11.06	0.97	77147.27
6	10.00	8.86	45.79	1.91	18.48	11.24	0.97	79066.91
7	6.29	12.80	62.63	1.61	17.96	12.64	0.97	68992.62
8	2.28	4.44	60.22	0.88	20.43	11.48	0.99	76137.09
9	7.50	6.56	57.39	1.01	20.75	10.52	1.00	82857.96
10	9.81	7.95	45.05	1.55	18.97	11.16	0.98	79471.78
11	8.70	4.27	43.33	2.31	17.49	11.46	0.99	76761.90
12	9.18	5.49	42.99	2.69	16.70	11.64	1.01	76246.93
13	10.03	5.57	47.17	2.97	16.18	11.60	0.99	76711.36
14	8.12	5.79	55.68	1.76	18.59	11.04	0.99	77448.00
15	10.52	7.05	39.10	3.08	16.54	11.11	0.99	77763.54
16	9.74	10.32	44.06	2.20	17.57	11.44	0.99	74271.43
17	12.45	9.26	43.03	2.60	16.79	11.54	0.99	77085.60
18	9.10	3.35	49.70	2.38	16.06	11.98	0.99	73630.94
19	8.53	6.39	62.68	1.03	17.68	11.94	0.99	74855.71
20	7.03	6.84	35.39	1.29	17.37	11.82	0.98	76094.47
21	7.17	9.27	36.88	1.89	16.33	12.08	0.99	75335.57
22	8.68	6.99	51.92	2.10	17.22	11.74	0.98	76779.29
23	6.98	5.95	56.06	1.13	18.60	11.30	0.99	79455.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.20	8.53	50.99	1.84	17.99	11.55	0.99	76619.99
最大值	12.45	15.16	64.41	3.08	20.75	12.64	1.03	82857.96
發生時間	17	3	3	15	9	7		9
最小值	2.28	3.35	35.39	0.88	16.06	10.52	0.96	68992.62
發生時間	8	18	20	8	18	9		7
零點偏移(率)	-0.07 %	-0.02 %	-0.03 %	-0.02 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	0.04 %	0.15 %	0.04 %		-0.10		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.06	12.76	48.82	2.74	16.51	10.73	0.99	82701.50
1	9.22	7.04	51.55	3.02	16.74	10.86	0.99	81628.57
2	10.05	7.34	53.15	2.83	16.65	10.53	0.99	83197.25
3	8.57	8.20	55.72	2.36	16.96	10.77	0.99	81998.76
4	8.08	6.51	65.00	1.41	19.60	10.21	1.01	84456.91
5	9.36	6.20	51.02	1.84	19.48	9.52	1.00	87913.35
6	10.54	7.68	65.25	1.46	20.08	10.04	0.99	87435.06
7	9.34	7.27	53.19	1.19	20.19	9.78	0.99	87305.10
8	8.81	6.04	51.80	0.86	20.47	9.78	0.99	86839.00
9	9.54	5.21	59.84	1.72	18.56	9.93	0.99	87317.41
10	10.71	4.60	57.20	2.71	15.87	10.67	0.99	84635.60
11	9.80	2.99	56.71	2.39	15.40	10.86	1.00	81171.44
12	8.66	4.73	52.71	2.27	16.59	10.24	0.99	84662.23
13	9.64	4.05	46.78	2.12	16.92	10.19	0.99	83496.10
14	9.12	4.96	54.17	2.24	16.30	10.31	0.99	82443.56
15	10.31	9.51	58.64	2.11	16.48	10.49	0.99	83453.64
16	9.59	6.42	64.75	2.69	15.43	10.74	1.00	83476.38
17	9.10	4.61	42.52	2.12	16.77	10.34	0.99	81792.18
18	9.31	3.89	52.79	1.90	17.12	10.34	0.99	83182.24
19	7.63	6.59	60.54	1.47	17.88	10.29	0.99	84959.32
20	7.75	10.84	53.92	1.72	17.23	10.03	0.99	86083.23
21	5.58	6.66	52.19	2.24	16.56	10.63	0.98	82248.61
22	4.86	5.70	43.71	2.24	17.43	10.54	0.97	81810.31
23	0.63	12.15	48.28	2.37	17.14	10.45	0.98	83966.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.34	6.75	54.18	2.08	17.43	10.34	0.99	84090.59
最大值	10.71	12.76	65.25	3.02	20.47	10.86	1.02	87913.35
發生時間	10	0	6	1	8	1		5
最小值	0.63	2.99	42.52	0.86	15.40	9.52	0.97	81171.44
發生時間	23	11	17	8	11	5		11
零點偏移(率)	-0.16 %	0.00 %	-0.41 %	-0.07 %		0.01		-0.20 %
全幅偏移(率)	0.04 %	0.12 %	-0.37 %	0.05 %		-0.27		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.77	7.76	48.76	2.12	16.52	10.66	0.97	75261.17
1	7.79	7.70	49.83	2.07	17.43	10.67	0.95	74863.49
2	7.35	10.66	51.11	2.76	15.30	10.69	0.94	75644.60
3	9.31	7.95	57.80	3.33	14.50	11.29	0.92	74481.02
4	9.90	7.33	59.39	2.69	16.16	11.02	0.92	74970.06
5	9.49	8.90	53.17	2.99	16.44	10.57	0.93	79189.07
6	9.42	10.03	68.09	2.26	17.58	10.95	0.94	77262.17
7	10.90	6.85	50.69	3.36	17.24	9.97	0.97	83276.23
8	9.17	5.60	48.49	2.44	15.58	10.77	0.98	77078.39
9	10.32	5.98	51.75	2.68	17.65	10.16	0.95	82993.71
10	9.56	10.89	55.80	3.14	14.54	10.99	0.98	78380.84
11	9.18	7.79	52.66	4.14	12.69	11.25	0.96	71601.86
12	7.71	8.60	54.45	4.23	12.27	11.55	0.92	70500.05
13	10.22	3.07	53.52	3.79	13.18	11.37	0.91	71529.65
14	10.79	7.32	51.86	2.95	15.34	10.69	0.92	74198.87
15	15.34	10.79	56.46	5.85	13.44	11.00	0.91	73167.78
16	4.50	9.41	50.32	7.89	13.50	10.83	0.92	73484.30
17	10.66	6.16	49.20	5.05	13.57	10.87	0.94	73093.91
18	8.75	2.74	60.73	1.89	16.22	10.47	0.97	76389.88
19	6.30	4.77	65.98	1.73	16.22	11.20	0.97	70333.65
20	2.53	8.29	57.37	1.89	15.53	10.94	0.97	74243.20
21	1.89	7.42	49.46	2.02	15.04	10.82	0.95	76673.80
22	2.67	6.29	58.27	2.06	15.41	11.00	0.92	74241.97
23	1.66	4.67	64.36	1.82	16.12	10.91	0.94	74747.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.09	7.37	54.98	3.13	15.31	10.86	0.94	75316.97
最大值	15.34	10.89	68.09	7.89	17.65	11.55	0.99	83276.23
發生時間	15	10	6	16	9	12		7
最小值	1.66	2.74	48.49	1.73	12.27	9.97	0.90	70333.65
發生時間	23	18	8	19	12	7		19
零點偏移(率)	0.00 %	0.00 %	-0.06 %	-0.03 %		-0.01		0.00 %
全幅偏移(率)	-0.16 %	-0.06 %	-0.95 %	0.15 %		0.32		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								