

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年04月10日

報表日期: 114年04月10日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.27	3.21	47.28	1.22	18.29	10.29	1.34	79788.24
1	10.10	8.13	45.55	1.34	19.44	10.03	1.32	80461.96
2	8.01	6.20	43.01	1.78	17.30	10.19	1.31	80559.41
3	7.76	7.01	42.24	1.78	16.95	10.39	1.33	80045.69
4	7.23	9.57	44.16	1.19	19.55	9.62	1.34	85090.57
5	7.08	10.92	37.30	1.22	18.89	9.65	1.30	84765.38
6	4.63	8.10	35.20	2.01	20.73	8.56	1.29	78421.16
7	11.07	4.84	50.41	1.73	19.74	9.11	1.29	82420.99
8	9.98	5.39	28.36	1.99	17.53	10.47	1.29	80724.78
9	13.29	10.97	30.61	3.36	16.14	10.88	1.28	79627.66
10	4.21	3.29	54.14	1.46	16.18	11.40	1.25	74086.68
11	14.80	5.38	44.06	2.28	17.17	10.19	1.28	80855.85
12	7.15	5.95	41.02	1.16	17.59	10.63	1.28	78683.62
13	4.10	2.08	55.97	0.81	17.34	11.07	1.29	76849.33
14	3.98	1.70	53.52	1.05	16.53	11.19	1.29	77598.89
15	6.07	2.01	41.33	0.97	17.98	10.97	1.26	80830.95
16	4.13	1.88	47.06	0.55	18.54	10.90	1.26	82753.99
17	3.34	1.87	44.91	0.82	17.67	11.08	1.27	81394.62
18	5.87	1.85	52.62	0.43	19.45	10.22	1.27	82955.50
19	5.88	7.61	56.64	0.36	21.06	9.26	1.27	85025.54
20	9.65	4.69	49.06	1.03	19.90	9.54	1.28	87037.22
21	11.41	2.62	48.46	0.78	20.18	9.63	1.30	84769.60
22	6.16	3.27	57.08	0.72	19.44	9.92	1.31	80666.54
23	11.17	9.14	49.06	1.35	18.05	10.16	1.31	82672.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.85	5.32	45.79	1.31	18.40	10.22	1.29	81170.26
最 大 值	14.80	10.97	57.08	3.36	21.06	11.40	1.36	87037.22
發生時間	11	9	22	9	19	10		20
最 小 值	3.34	1.70	28.36	0.36	16.14	8.56	1.23	74086.68
發生時間	17	14	8	19	9	6		10
零點偏移(率)	-0.13 %	-0.00 %	-0.02 %	0.00 %		-0.05		0.20 %
全幅偏移(率)	0.79 %	-0.21 %	-0.11 %	0.25 %		-0.03		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年04月10日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.91	1.95	51.45	2.57	16.94	10.51	1.07	82522.60
1	9.10	3.89	49.09	2.77	18.14	10.34	1.10	84016.10
2	9.05	11.98	48.86	1.99	18.72	9.81	1.10	88348.42
3	9.11	6.69	45.73	2.52	17.33	10.12	1.10	85939.61
4	10.22	3.02	44.50	2.92	16.71	10.21	1.10	85195.65
5	8.59	4.61	53.03	2.52	16.92	10.19	1.10	86273.16
6	3.69	2.23	48.14	2.17	16.21	10.84	1.09	83607.66
7	2.11	3.64	55.52	1.94	17.01	10.53	1.09	85054.62
8	5.59	4.99	64.42	1.88	17.05	10.93	1.09	79232.74
9	7.98	1.99	60.96	2.16	16.98	10.43	1.09	86298.74
10	8.24	2.80	56.67	3.15	14.61	11.12	1.08	80070.74
11	10.75	4.62	55.78	3.06	15.72	10.29	1.06	86958.32
12	9.33	2.53	60.03	3.20	16.35	11.14	1.06	84662.78
13	10.97	5.75	63.09	3.18	15.97	11.22	1.06	85142.73
14	13.98	3.82	52.56	3.39	15.92	11.15	1.06	84409.81
15	9.21	9.88	54.87	2.55	15.37	10.84	1.09	82967.24
16	6.50	4.86	54.72	1.51	17.74	10.15	1.10	85169.11
17	9.54	1.59	59.15	2.18	17.38	9.90	1.10	87006.81
18	9.67	2.14	60.99	2.64	16.85	10.16	1.10	84205.40
19	8.67	7.56	55.52	2.22	16.28	10.03	1.10	84170.76
20	8.62	4.38	58.44	2.38	16.74	9.80	1.10	82643.32
21	8.33	3.48	52.55	1.74	18.37	9.56	1.10	84207.31
22	10.18	6.11	62.28	2.01	17.37	10.08	1.10	85402.03
23	8.24	3.59	53.18	1.94	16.27	10.46	1.10	83019.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.61	4.50	55.06	2.44	16.79	10.41	1.09	84438.57
最 大 值	13.98	11.98	64.42	3.39	18.72	11.22	1.10	88348.42
發生時間	14	2	8	14	2	13		2
最 小 值	2.11	1.59	44.50	1.51	14.61	9.56	1.06	79232.74
發生時間	7	17	4	16	10	21		8
零點偏移(率)	-0.09 %	-0.01 %	-0.03 %	-0.01 %		-0.01		0.00 %
全幅偏移(率)	0.19 %	0.23 %	-0.24 %	0.26 %		-0.06		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

