

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.23	3.54	63.77	3.36	19.18	11.52	1.47	75462.05
1	7.72	3.12	55.85	3.05	20.31	11.21	1.46	76901.78
2	8.16	3.61	53.84	3.40	18.72	11.64	1.46	74904.87
3	4.87	3.69	65.28	3.49	18.30	11.95	1.51	73271.60
4	7.28	4.14	59.06	3.43	18.44	11.57	1.48	76481.78
5	8.04	3.34	53.06	3.12	19.15	11.26	1.46	80990.70
6	6.38	4.45	66.17	3.47	18.71	12.01	1.47	72188.30
7	8.38	2.62	65.57	3.44	18.95	11.97	1.45	72616.20
8	10.64	1.29	46.48	3.33	19.40	11.20	1.44	77429.41
9	9.26	1.32	54.18	3.28	18.83	11.48	1.46	76632.26
10	9.42	1.66	50.40	3.43	17.65	11.62	1.46	75820.20
11	10.26	1.70	56.82	3.30	18.33	11.44	1.42	76986.43
12	5.75	6.24	52.34	3.38	18.29	11.88	1.41	73448.30
13	10.64	3.40	55.30	3.33	18.94	11.30	1.42	77170.40
14	11.08	7.81	52.64	3.51	16.98	11.75	1.42	74947.20
15	8.37	3.86	54.51	3.36	17.21	11.89	1.41	74095.69
16	10.60	2.08	53.75	3.42	16.86	11.85	1.46	74373.50
17	10.54	1.16	58.03	3.36	17.99	11.74	1.47	74068.42
18	7.39	4.30	61.46	3.48	17.45	12.21	1.46	71249.07
19	11.71	5.33	60.31	3.37	17.99	12.28	1.48	70938.65
20	11.07	4.09	48.98	3.30	18.63	11.73	1.46	74267.35
21	8.33	6.18	63.19	3.40	18.45	11.96	1.45	72695.97
22	10.93	4.54	48.77	3.22	18.73	11.24	1.43	77649.42
23	10.75	4.44	56.25	3.25	18.75	11.37	1.44	76986.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.87	3.66	56.50	3.35	18.43	11.67	1.45	75065.66
最大值	11.71	7.81	66.17	3.51	20.31	12.28	1.56	80990.70
發生時間	19	14	6	14	1	19		5
最小值	4.87	1.16	46.48	3.05	16.86	11.20	1.39	70938.65
發生時間	3	17	8	1	16	8		19
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	2.38 %	0.01 %	-0.12 %	0.09 %		0.33	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.31	4.43	60.99	2.51	15.59	11.02	1.40	63195.86
1	10.11	2.99	58.70	2.15	17.68	10.78	1.39	63685.84
2	9.25	3.70	57.72	1.84	17.98	10.07	1.39	65188.61
3	9.22	5.91	57.80	2.44	15.37	10.61	1.40	63043.36
4	13.74	5.52	66.65	2.75	15.32	10.99	1.39	62708.59
5	9.72	6.76	60.96	2.86	16.37	10.96	1.39	62156.27
6	11.31	6.17	61.49	2.55	18.21	10.13	1.44	65803.80
7	10.19	0.56	61.99	2.54	16.20	10.89	1.45	65649.98
8	11.21	3.99	57.69	2.56	16.76	10.51	1.45	66258.41
9	9.70	0.75	54.68	2.37	16.57	10.60	1.42	65423.62
10	8.65	1.12	65.99	2.21	16.10	10.85	1.38	64567.33
11	7.88	3.02	51.29	2.30	15.30	10.90	1.38	62964.58
12	5.43	3.81	67.80	2.43	14.64	11.28	1.40	61414.05
13	10.02	4.55	56.54	3.07	14.35	11.01	1.41	63405.02
14	12.85	5.54	70.60	3.27	14.90	11.05	1.39	64135.66
15	10.68	6.29	67.15	2.99	14.11	11.19	1.38	63342.29
16	9.38	6.07	60.12	2.81	14.48	10.87	1.37	62516.96
17	9.46	1.69	61.82	2.70	14.29	10.95	1.38	61360.76
18	9.74	2.13	60.52	2.47	15.70	10.90	1.42	62623.10
19	9.45	5.35	59.69	2.63	14.61	11.00	1.43	63414.07
20	11.61	4.33	54.58	2.61	15.91	10.64	1.43	65683.10
21	9.64	5.08	65.39	2.37	15.89	10.89	1.42	64377.90
22	10.46	1.35	56.08	2.29	16.57	10.65	1.42	64673.51
23	11.11	6.50	56.77	2.48	16.29	10.80	1.41	62949.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.05	4.07	60.54	2.55	15.80	10.81	1.40	63772.58
最大值	13.74	6.76	70.60	3.27	18.21	11.28	1.46	66258.41
發生時間	4	5	14	14	6	12		8
最小值	5.43	0.56	51.29	1.84	14.11	10.07	1.36	61360.76
發生時間	12	7	11	2	15	2		17
零點偏移(率)	-0.05 %	-0.13 %	-0.08 %	-0.01 %		-0.04	0.00	0.00 %
全幅偏移(率)	0.13 %	0.42 %	0.11 %	0.15 %		0.21	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.16	3.42	67.12	3.25	13.41	11.37	1.73	81081.93
1	7.51	2.89	70.58	2.47	16.28	10.99	1.74	84624.85
2	7.12	0.59	58.50	2.22	16.69	10.75	1.73	85113.76
3	6.37	0.70	65.89	2.41	15.57	10.95	1.73	84291.94
4	7.48	3.16	60.87	2.31	15.94	10.94	1.75	85579.46
5	8.07	6.73	60.33	2.61	16.19	10.75	1.75	86266.15
6	9.03	5.67	62.38	2.65	16.28	10.67	1.76	87160.69
7	5.47	3.75	62.25	2.12	15.96	10.71	1.73	89553.45
8	8.55	1.92	59.61	2.36	15.09	10.98	1.73	84450.38
9	6.50	2.75	60.76	2.21	15.41	10.91	1.72	85112.49
10	5.43	4.00	55.03	2.21	14.94	10.72	1.69	84699.44
11	10.76	6.37	62.00	4.20	14.63	10.80	1.71	84458.83
12	8.35	5.12	59.39	3.48	14.14	11.45	1.72	82354.00
13	12.48	9.35	69.85	3.64	14.32	10.94	1.71	84665.24
14	6.67	3.12	65.17	3.15	13.19	11.13	1.72	79881.16
15	7.32	3.63	63.97	3.14	13.31	11.03	1.71	80276.60
16	11.48	3.48	60.59	3.40	13.13	11.07	1.69	81268.61
17	12.78	1.71	58.80	3.37	13.28	11.14	1.71	80290.43
18	6.17	3.74	62.14	2.39	14.38	11.20	1.73	82789.47
19	10.28	12.82	67.40	2.89	14.11	11.28	1.75	83898.42
20	8.77	10.80	62.87	2.80	14.07	11.27	1.74	83856.28
21	9.82	1.52	56.10	2.31	15.43	11.02	1.74	86389.05
22	11.16	6.45	50.62	2.15	15.94	10.57	1.73	84518.79
23	7.16	3.38	50.61	2.52	15.12	10.57	1.72	81618.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.54	4.46	61.37	2.76	14.87	10.97	1.73	83925.00
最大值	12.78	12.82	70.58	4.20	16.69	11.45	1.77	89553.45
發生時間	17	19	1	11	2	12		7
最小值	5.43	0.59	50.61	2.12	13.13	10.57	1.67	79881.16
發生時間	10	2	23	7	16	22		14
零點偏移(率)	-0.01 %	-0.03 %	-0.08 %	-0.06 %		0.02	0.00	0.00 %
全幅偏移(率)	0.19 %	0.26 %	-0.20 %	0.02 %		0.48	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								