

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.80	12.35	56.52	2.00	16.60	11.95	1.00	71233.70
1	8.06	11.87	52.59	2.04	18.04	11.38	1.00	74585.54
2	7.18	11.42	55.44	1.58	17.20	11.62	1.00	72971.57
3	9.18	11.08	57.58	1.64	17.57	11.56	0.99	72763.80
4	8.10	11.20	58.60	1.57	17.27	11.53	0.99	72353.77
5	9.54	12.08	49.05	1.60	16.66	11.69	1.02	71516.06
6	6.99	11.06	59.77	1.57	16.89	12.11	1.04	68426.42
7	2.34	9.42	60.34	0.88	17.66	11.97	1.03	68959.99
8	4.84	9.75	62.99	0.79	18.52	11.80	1.02	69774.84
9	4.44	9.54	54.63	1.17	17.71	11.90	1.05	69698.91
10	3.12	9.52	62.27	0.78	18.44	11.88	1.02	69720.22
11	6.24	11.90	50.89	1.78	17.04	11.82	1.03	70893.36
12	6.24	5.91	51.62	2.12	15.80	12.03	1.05	70094.40
13	7.54	6.22	56.37	1.66	16.36	11.90	1.05	70987.13
14	8.62	6.18	52.36	2.15	15.97	12.13	1.02	69497.99
15	4.54	6.70	58.75	1.31	16.86	11.89	1.04	70761.87
16	7.03	8.71	51.63	1.34	17.30	11.42	1.05	74217.36
17	7.67	3.83	44.87	2.54	15.93	11.93	1.02	71147.05
18	9.23	4.73	50.39	2.04	16.85	11.65	1.02	73331.47
19	9.15	10.95	48.75	2.72	15.97	11.93	1.04	71167.89
20	8.69	7.13	59.48	1.68	18.05	11.28	1.05	74788.01
21	9.99	9.48	48.74	2.02	16.97	11.70	1.05	73093.09
22	9.59	8.00	46.66	2.85	15.86	12.04	1.02	70612.40
23	9.81	7.06	51.79	2.35	16.70	11.75	1.02	72467.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.33	9.00	54.25	1.76	17.01	11.79	1.03	71461.02
最大值	9.99	12.35	62.99	2.85	18.52	12.13	1.06	74788.01
發生時間	21	0	8	22	8	14		20
最小值	2.34	3.83	44.87	0.78	15.80	11.28	0.99	68426.42
發生時間	7	17	17	10	12	20		6
零點偏移(率)	-0.30 %	0.00 %	-0.01 %	0.00 %		0.02		0.00 %
全幅偏移(率)	0.00 %	0.68 %	0.24 %	0.36 %		0.10		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.03	8.77	60.28	1.91	15.61	11.88	1.01	75180.37
1	4.08	6.82	54.51	1.79	17.41	11.34	1.01	78064.01
2	4.69	5.63	62.58	1.45	16.28	11.50	1.02	77424.27
3	6.37	9.83	46.96	1.29	18.28	10.19	1.02	86356.59
4	6.87	9.08	51.43	1.45	18.10	10.95	1.02	80471.37
5	3.48	8.51	49.77	1.57	17.99	10.74	1.02	81960.17
6	0.37	5.20	62.37	0.51	18.40	11.65	1.02	68762.78
7	3.25	4.84	52.66	0.38	20.85	10.12	1.03	83877.68
8	4.15	6.78	54.83	0.79	19.11	11.05	1.02	78390.03
9	4.14	8.26	54.62	0.99	18.41	11.26	1.02	78008.15
10	2.92	9.24	47.46	1.82	17.98	10.69	1.03	81990.46
11	1.81	10.23	45.42	2.25	17.20	10.44	1.03	84154.46
12	5.63	3.99	52.85	2.80	15.99	10.72	1.02	83636.85
13	2.19	2.63	51.78	2.20	16.54	10.83	1.02	82399.67
14	2.97	2.63	58.35	0.95	18.91	10.44	1.02	83631.77
15	4.51	3.66	39.69	1.92	18.31	10.32	1.09	85051.77
16	7.48	5.36	47.61	2.11	17.77	10.24	1.04	85794.86
17	7.69	2.56	54.45	1.99	17.31	10.60	1.02	84084.14
18	7.79	9.08	48.17	1.82	18.19	10.29	0.99	86013.17
19	4.88	6.36	46.51	1.71	18.81	10.18	0.99	85691.39
20	5.30	4.34	44.85	1.73	18.21	10.19	0.99	86554.80
21	6.57	11.59	46.61	2.76	17.29	10.32	0.99	86398.62
22	8.78	6.28	49.60	2.27	17.92	10.29	0.99	85147.81
23	8.78	4.51	48.90	2.39	17.40	10.50	0.99	84755.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.95	6.51	51.34	1.70	17.84	10.70	1.02	82241.71
最大值	8.78	11.59	62.58	2.80	20.85	11.88	1.16	86554.80
發生時間	22	21	2	12	7	0		20
最小值	0.37	2.56	39.69	0.38	15.61	10.12	0.99	68762.78
發生時間	6	17	15	7	0	7		6
零點偏移(率)	-0.37 %	-0.02 %	-0.02 %	-0.00 %		0.03		-0.20 %
全幅偏移(率)	0.41 %	1.14 %	-0.01 %	0.18 %		-0.08		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.30	7.28	54.76	1.55	15.82	11.00	0.96	75292.98
1	3.73	11.21	47.25	1.22	17.57	10.75	0.96	76383.45
2	6.47	9.40	49.75	1.52	16.39	10.42	0.97	79315.95
3	8.00	6.20	49.58	2.12	14.85	10.78	0.96	77438.41
4	7.60	6.32	51.82	2.36	14.38	11.04	0.97	76130.12
5	7.92	8.41	53.63	2.37	14.83	10.98	0.97	73856.06
6	8.73	9.31	47.14	2.15	15.56	10.66	0.97	75647.08
7	7.79	6.52	45.71	1.48	17.22	10.21	0.98	77524.20
8	8.00	6.72	46.94	1.59	16.75	10.20	1.01	80457.99
9	6.29	7.31	48.70	1.53	15.55	10.81	0.97	76822.19
10	9.31	9.74	54.89	1.75	16.04	10.66	0.99	77918.93
11	8.36	11.43	53.57	2.12	14.64	10.93	1.01	76289.78
12	7.35	4.27	50.72	1.77	14.88	11.09	1.00	74225.69
13	10.93	7.22	54.46	3.01	13.60	11.30	0.98	75237.45
14	6.28	3.12	55.02	2.42	13.86	11.33	0.96	73602.50
15	4.91	2.31	52.53	1.83	15.26	10.98	0.97	75461.21
16	8.18	2.61	57.12	1.57	16.22	10.88	1.01	79807.30
17	8.59	4.35	49.59	1.95	14.78	11.17	0.98	79794.56
18	8.01	4.23	53.29	1.76	15.31	11.05	0.96	78746.00
19	8.94	6.36	63.20	1.49	16.32	11.29	1.00	76620.74
20	5.78	12.43	62.56	1.51	16.81	11.46	1.02	78272.39
21	6.20	13.66	46.60	2.48	14.16	11.12	0.99	75972.57
22	7.13	5.12	52.53	2.83	14.13	11.33	0.98	73050.05
23	8.16	4.06	51.15	1.98	15.33	11.16	0.98	78064.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.46	7.07	52.19	1.93	15.43	10.94	0.98	76747.15
最大值	10.93	13.66	63.20	3.01	17.57	11.46	1.03	80457.99
發生時間	13	21	19	13	1	20		8
最小值	3.73	2.31	45.71	1.22	13.60	10.20	0.94	73050.05
發生時間	1	15	7	1	13	8		22
零點偏移(率)	-0.75 %	-0.02 %	-0.01 %	-0.03 %		0.01		0.00 %
全幅偏移(率)	0.04 %	1.02 %	-0.44 %	0.23 %		0.22		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								