

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.89	5.66	51.13	1.75	20.80	10.83	1.37	78481.17
1	14.76	6.92	58.24	2.29	19.24	11.53	1.38	74179.85
2	16.96	7.41	50.55	2.45	18.71	11.19	1.38	77682.27
3	13.20	8.32	67.87	2.52	18.62	11.43	1.38	76158.52
4	8.87	9.36	52.71	2.15	17.95	11.69	1.38	74362.11
5	10.73	2.52	58.60	2.06	20.42	10.95	1.40	75862.71
6	10.81	3.85	52.28	2.10	19.42	11.11	1.39	77314.79
7	10.14	4.05	66.03	2.27	19.49	11.45	1.40	74377.93
8	10.14	5.12	53.51	2.06	19.39	11.31	1.40	75889.65
9	11.10	6.39	61.94	1.96	20.10	11.01	1.39	77709.91
10	11.46	5.88	51.74	2.29	18.88	11.09	1.38	76867.11
11	11.19	4.77	62.77	2.39	18.78	11.41	1.40	75369.23
12	9.58	1.79	53.74	2.27	18.58	11.34	1.42	76222.28
13	10.28	4.53	65.37	2.18	18.66	11.37	1.44	75998.99
14	9.99	3.32	64.63	2.10	19.49	11.24	1.44	76379.06
15	4.64	3.15	68.73	2.05	19.19	11.49	1.45	74192.11
16	6.05	3.13	53.18	2.11	19.34	11.39	1.43	75063.00
17	9.01	3.52	62.28	2.10	19.19	11.21	1.39	77174.60
18	10.82	5.50	48.79	2.18	18.92	11.09	1.41	78331.26
19	8.91	5.06	58.27	2.25	19.13	11.83	1.45	72112.97
20	10.14	4.17	51.34	2.07	19.67	11.17	1.44	77332.83
21	10.21	6.29	62.02	2.27	18.65	11.57	1.42	74589.57
22	10.92	3.78	56.63	2.16	19.78	11.06	1.41	77522.70
23	6.68	3.67	63.54	1.91	19.74	11.12	1.41	77090.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.40	4.92	58.16	2.16	19.26	11.29	1.41	76094.40
最大值	16.96	9.36	68.73	2.52	20.80	11.83	1.50	78481.17
發生時間	2	4	15	3	0	19		0
最小值	4.64	1.79	48.79	1.75	17.95	10.83	1.36	72112.97
發生時間	15	12	18	0	4	0		19
零點偏移(率)	-0.04 %	0.00 %	-0.01 %	0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	0.00 %	0.16 %	-0.15 %	0.44 %		0.40	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.40	3.14	54.04	2.51	17.15	10.24	1.28	62395.92
1	12.41	2.91	69.40	2.37	17.59	10.07	1.30	66258.45
2	12.00	4.39	67.62	2.42	16.59	10.10	1.29	62658.71
3	10.10	2.92	59.45	1.99	17.59	9.92	1.28	65620.36
4	11.32	6.22	60.45	2.19	16.81	10.58	1.28	65190.65
5	9.78	6.67	66.38	2.11	17.54	10.24	1.29	66618.67
6	12.19	2.33	62.16	2.92	15.64	10.67	1.29	63407.87
7	10.51	4.29	62.13	2.34	16.36	10.66	1.29	63391.15
8	10.65	2.00	63.04	2.25	17.29	10.44	1.30	65567.04
9	11.60	4.00	60.42	3.07	15.55	10.51	1.30	63704.38
10	10.74	4.43	56.31	3.13	14.65	10.70	1.30	60726.99
11	11.53	4.05	66.79	2.42	15.53	11.07	1.33	63372.80
12	3.50	0.90	64.64	1.84	16.76	10.70	1.34	62221.29
13	7.73	3.59	52.67	2.02	16.33	10.82	1.35	65277.23
14	9.26	2.40	54.73	2.04	16.39	10.79	1.35	65848.04
15	9.34	2.69	50.55	2.22	15.61	11.12	1.35	64619.32
16	10.34	7.44	53.79	2.54	15.11	11.22	1.33	63811.20
17	9.60	6.68	44.01	2.67	14.41	11.36	1.31	63289.98
18	9.41	3.13	48.34	1.96	17.23	10.51	1.28	66630.42
19	7.83	2.94	46.64	2.05	16.59	10.82	1.31	65386.92
20	6.37	6.14	49.51	2.24	15.03	10.99	1.34	64805.96
21	9.18	4.24	46.74	2.38	15.04	11.13	1.36	63930.42
22	10.66	2.58	54.43	2.25	16.42	10.54	1.36	67404.21
23	9.22	2.08	64.03	2.08	16.46	10.79	1.35	64710.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.82	3.84	57.43	2.33	16.24	10.67	1.32	64452.01
最大值	12.41	7.44	69.40	3.13	17.59	11.36	1.37	67404.21
發生時間	1	16	1	10	1	17		22
最小值	3.50	0.90	44.01	1.84	14.41	9.92	1.27	60726.99
發生時間	12	12	17	12	17	3		10
零點偏移(率)	-0.01 %	-0.00 %	-0.03 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	1.80 %	0.18 %	-0.09 %	0.34 %		0.12	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.77	6.82	56.85	3.11	15.59	10.19	1.79	80704.77
1	12.46	6.74	53.09	2.62	17.07	9.56	1.80	83143.78
2	15.00	8.65	63.66	4.61	14.10	9.97	1.80	79158.76
3	11.05	4.98	58.00	4.50	13.23	10.74	1.80	77368.62
4	10.51	1.19	61.48	2.37	15.69	10.39	1.80	80646.96
5	10.71	8.90	58.66	2.48	15.48	10.44	1.80	83304.31
6	8.92	5.52	59.82	2.65	14.77	10.83	1.80	80677.55
7	11.99	3.37	64.75	2.89	17.60	10.18	1.82	88102.67
8	11.12	5.86	57.92	2.41	15.66	10.66	1.81	85441.67
9	9.79	7.62	59.37	2.65	15.07	10.52	1.79	80762.21
10	9.01	3.23	56.29	3.06	14.07	10.27	1.80	79582.27
11	12.75	5.24	58.15	3.10	14.21	10.50	1.80	76774.41
12	8.99	1.46	60.54	2.72	14.37	10.52	1.80	78521.25
13	5.74	5.95	61.22	2.27	15.73	10.44	1.80	81826.34
14	6.12	0.66	65.34	2.34	16.13	10.84	1.80	83526.23
15	7.96	1.39	47.57	2.38	15.72	11.04	1.80	84667.97
16	8.73	2.12	48.92	2.78	14.80	11.21	1.80	83704.27
17	7.32	2.37	48.21	2.80	14.44	11.18	1.80	84327.69
18	6.33	5.99	50.22	2.79	15.08	11.05	1.80	85311.27
19	8.94	5.54	50.64	2.71	15.03	11.23	1.80	86302.57
20	9.58	3.72	48.04	2.47	15.44	10.98	1.79	87870.96
21	8.22	10.92	51.30	3.00	14.17	11.59	1.80	82191.01
22	9.24	5.01	58.18	2.54	15.39	11.09	1.80	86118.03
23	9.04	4.19	65.72	2.38	15.89	10.92	1.81	88303.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.64	4.89	56.83	2.82	15.20	10.68	1.80	82847.48
最大值	15.00	10.92	65.72	4.61	17.60	11.59	1.83	88303.89
發生時間	2	21	23	2	7	21		23
最小值	5.74	0.66	47.57	2.27	13.23	9.56	1.77	76774.41
發生時間	13	14	15	13	3	1		11
零點偏移(率)	-0.01 %	-0.00 %	0.00 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	1.98 %	0.52 %	-0.73 %	0.39 %		0.26	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								