

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月24日

報表日期: 115年07月24日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.07	11.54	58.88	1.47	19.46	10.96	1.19	82497.11
1	10.30	12.88	56.36	1.44	22.47	9.86	1.19	87416.46
2	9.73	10.84	43.45	3.56	19.81	10.31	1.20	86944.24
3	10.91	10.91	53.72	4.10	19.03	10.71	1.20	85394.21
4	14.62	11.06	54.40	4.56	17.47	10.99	1.20	84487.38
5	12.40	12.54	50.01	3.51	19.24	10.75	1.18	84336.63
6	6.56	12.51	57.29	2.76	18.39	10.95	1.19	83877.08
7	9.27	12.44	55.30	3.21	18.35	10.80	1.19	85284.50
8	9.79	12.47	51.14	3.42	19.03	10.51	1.18	86989.03
9	9.10	13.50	39.06	2.84	19.29	10.88	1.18	83624.28
10	9.47	12.76	41.11	2.36	20.03	10.60	1.18	85085.88
11	8.63	12.94	39.34	2.57	18.15	11.34	1.18	81002.22
12	9.44	13.21	39.03	2.45	16.52	11.72	1.18	79342.97
13	8.99	13.36	41.35	2.47	16.81	11.61	1.18	79938.64
14	8.75	12.96	41.08	3.01	16.88	11.42	1.18	81699.66
15	4.92	13.44	38.42	2.53	15.51	12.02	1.18	77746.23
16	8.51	12.92	43.33	2.29	17.05	11.45	1.18	81353.63
17	9.92	12.92	43.26	2.24	17.30	11.02	1.18	84254.11
18	9.98	12.88	46.40	2.13	16.51	11.25	1.18	83116.32
19	8.89	12.53	45.88	1.85	16.96	11.14	1.18	83733.44
20	9.34	12.59	48.67	1.77	18.20	10.71	1.18	85885.76
21	8.84	12.75	50.69	1.81	17.32	10.97	1.18	84725.53
22	9.59	12.50	51.87	1.67	17.17	11.13	1.18	83057.28
23	11.27	12.18	56.62	1.80	17.92	11.11	1.18	83248.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.39	12.53	47.78	2.58	18.12	11.01	1.18	83543.37
最 大 值	14.62	13.50	58.88	4.56	22.47	12.02	1.21	87416.46
發生時間	4	9	0	4	1	15		1
最 小 值	4.92	10.84	38.42	1.44	15.51	9.86	1.18	77746.23
發生時間	15	2	15	1	15	1		15
零點偏移(率)	0.00 %	0.01 %	-0.02 %	-0.01 %		-0.04	-0.01	0.00 %
全幅偏移(率)	0.88 %	0.58 %	1.94 %	0.29 %		-0.12	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月24日

報表日期: 115年07月24日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.39	14.28	60.04	1.51	19.94	10.29	1.10	85867.62
1	4.04	11.31	42.05	0.99	21.03	9.69	0.93	89343.15
2	12.89	12.03	40.67	1.63	19.75	10.28	0.94	86150.40
3	7.05	12.39	38.92	1.66	18.39	10.92	0.94	82898.51
4	11.88	12.60	42.19	1.40	18.82	11.07	0.93	80773.05
5	9.67	12.02	45.95	1.20	20.17	10.39	0.94	84653.35
6	12.99	12.44	55.41	2.56	17.87	10.94	0.94	85528.02
7	8.08	11.96	49.06	1.77	19.38	10.37	0.94	85744.12
8	10.96	12.10	54.97	2.08	19.43	10.09	0.94	87485.58
9	8.86	12.24	58.47	1.22	18.91	10.77	0.95	82984.69
10	9.33	12.24	40.62	1.42	19.68	10.44	0.94	84931.81
11	11.79	12.50	54.91	2.44	17.40	10.78	0.94	84111.29
12	8.41	12.49	59.50	0.99	17.80	11.13	0.95	81259.37
13	8.08	12.68	62.96	1.19	17.16	11.35	0.95	79925.74
14	8.66	12.54	52.97	1.71	16.48	11.32	0.94	80997.85
15	11.92	12.47	56.71	2.56	15.25	11.35	0.94	82115.34
16	8.80	12.64	47.63	2.39	17.92	11.17	0.94	80316.50
17	10.98	13.10	52.60	2.45	17.35	11.04	0.94	82533.69
18	7.40	12.57	45.23	2.00	17.84	10.84	0.94	83416.03
19	11.43	12.97	40.43	2.09	17.49	10.92	0.94	83109.61
20	7.20	12.32	42.37	1.79	17.33	10.88	0.94	83365.91
21	9.51	11.98	46.46	1.57	18.94	10.52	0.94	85214.90
22	11.99	12.23	51.36	1.83	18.11	10.75	0.94	83677.62
23	8.90	12.13	56.41	1.01	19.22	10.62	0.94	83814.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.34	12.43	49.91	1.73	18.40	10.75	0.95	83759.11
最 大 值	12.99	14.28	62.96	2.56	21.03	11.35	1.54	89343.15
發生時間	6	0	13	6	1	13		1
最 小 值	3.39	11.31	38.92	0.99	15.25	9.69	0.92	79925.74
發生時間	0	1	3	1	15	1		13
零點偏移(率)	-0.15 %	-0.08 %	-0.05 %	-0.01 %		-0.06	-0.01	-0.10 %
全幅偏移(率)	0.62 %	-0.16 %	0.29 %	0.50 %		-0.32	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月24日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	4.89	12.07	55.57	1.43	20.15	10.38	1.31	78046.50
1	2.23	12.15	59.41	1.16	21.56	10.26	1.31	79943.47
2	5.31	11.82	56.39	1.45	20.59	10.12	1.31	81607.11
3	3.19	11.84	57.50	1.40	19.01	10.17	1.30	81687.11
4	8.25	11.76	54.20	1.52	18.36	10.38	1.30	81007.65
5	3.59	11.87	57.82	1.50	18.74	10.35	1.27	79332.86
6	6.49	11.53	50.24	1.51	19.51	9.98	1.28	81943.28
7	3.52	11.95	52.15	2.69	18.58	10.42	1.31	78288.38
8	6.55	11.54	58.90	2.76	19.21	10.05	1.29	79602.38
9	3.02	11.73	39.65	2.25	19.50	10.06	1.29	77725.85
10	1.55	11.31	39.35	2.09	18.37	9.90	1.31	79063.07
11	6.28	11.54	41.87	2.49	18.85	9.98	1.28	80873.91
12	3.76	11.60	42.61	2.20	18.56	10.18	1.27	79111.29
13	2.71	11.66	42.48	2.14	18.96	10.20	1.30	78560.67
14	1.29	11.60	40.09	2.03	19.23	9.97	1.27	80301.78
15	2.25	11.62	44.31	2.12	18.61	10.18	1.29	78729.27
16	2.04	11.66	45.93	1.98	18.30	10.24	1.30	79420.58
17	1.92	11.77	56.91	1.62	18.70	10.34	1.29	79266.20
18	2.03	11.70	54.42	1.33	18.08	10.25	1.27	79147.44
19	1.53	12.08	56.86	1.39	19.14	10.06	1.26	81894.14
20	3.08	12.13	54.66	1.44	18.81	10.14	1.26	81765.23
21	2.62	12.14	56.19	1.44	18.83	10.16	1.25	82362.08
22	4.33	11.67	54.02	1.52	18.29	10.17	1.25	82531.61
23	4.07	11.70	63.77	1.80	19.59	10.14	1.28	79880.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.60	11.77	51.47	1.80	19.06	10.17	1.28	80087.17
最 大 值	8.25	12.15	63.77	2.76	21.56	10.42	1.34	82531.61
發生時間	4	1	23	8	1	7		22
最 小 值	1.29	11.31	39.35	1.16	18.08	9.90	1.25	77725.85
發生時間	14	10	10	1	18	10		9
零點偏移(率)	-0.08 %	-0.05 %	-0.07 %	-0.03 %		-0.04	-0.01	0.10 %
全幅偏移(率)	1.08 %	0.02 %	0.30 %	-1.08 %		0.21	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								