

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.64	9.86	52.68	0.93	18.04	11.11	1.10	73008.12
1	0.76	10.34	57.34	0.98	18.88	11.55	1.10	71641.65
2	0.25	10.31	55.41	1.04	18.33	11.30	1.10	73796.47
3	1.87	10.15	66.54	0.81	18.46	11.10	1.10	75643.10
4	5.79	12.45	51.28	1.32	17.65	11.38	1.10	73746.31
5	2.73	10.69	49.44	0.95	17.84	11.07	1.10	73197.53
6	4.91	10.41	49.33	1.36	17.73	11.30	1.08	74629.27
7	2.25	7.02	63.01	0.70	18.30	11.30	1.08	74323.22
8	1.98	6.88	49.11	0.75	18.09	11.09	1.11	74594.59
9	2.72	8.07	49.15	1.20	16.86	11.44	1.13	73011.80
10	7.72	8.57	47.49	1.75	17.21	11.30	1.11	73596.02
11	8.09	6.85	61.96	0.90	17.91	11.37	1.08	72829.51
12	7.12	6.97	52.83	1.05	16.86	11.70	1.10	70553.24
13	9.12	7.61	55.79	1.05	17.31	11.57	1.12	71245.76
14	8.69	7.78	59.34	1.27	17.98	11.38	1.12	72932.01
15	9.51	7.08	55.59	1.17	17.79	11.10	1.12	75540.06
16	9.53	7.31	60.77	1.01	18.24	11.13	1.11	74734.09
17	8.21	7.04	57.37	0.86	19.09	10.73	1.10	77388.55
18	8.07	7.55	51.93	0.82	18.69	10.71	1.12	78108.16
19	6.48	11.06	51.59	1.46	17.36	11.21	1.10	75363.00
20	5.81	10.58	53.75	1.08	17.57	11.32	1.10	74377.09
21	8.56	10.38	53.88	1.35	18.07	10.90	1.10	76809.66
22	7.27	11.33	63.17	0.76	18.82	11.35	1.10	72838.74
23	2.91	12.23	62.61	0.71	18.11	12.02	1.10	68258.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.46	9.10	55.47	1.05	17.97	11.27	1.10	73840.26
最大值	9.53	12.45	66.54	1.75	19.09	12.02	1.14	78108.16
發生時間	16	4	3	10	17	23		18
最小值	0.25	6.85	47.49	0.70	16.86	10.71	1.07	68258.23
發生時間	2	11	10	7	9	18		23
零點偏移(率)	-0.04 %	-0.03 %	-0.18 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.01 %	1.14 %	0.30 %	0.53 %		0.10		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.09	6.43	56.10	1.48	17.30	10.50	1.01	83844.52
1	0.57	7.55	51.72	1.89	18.13	10.19	1.01	85244.56
2	3.81	7.19	51.98	2.32	16.74	10.33	1.02	85974.36
3	4.24	9.74	51.56	2.29	16.09	10.48	1.02	85121.09
4	3.54	6.71	54.57	1.78	17.94	10.11	1.03	86130.95
5	1.13	7.31	47.14	1.47	18.45	9.75	1.05	88465.50
6	0.89	5.28	68.72	1.37	18.01	10.11	1.05	84148.34
7	0.77	4.67	44.15	1.66	17.26	10.32	1.05	85181.42
8	4.74	10.06	44.74	1.98	17.22	9.97	1.04	87266.87
9	8.54	10.03	52.53	2.31	17.15	10.27	1.04	84454.39
10	6.73	5.25	48.70	2.36	16.74	10.06	1.05	86749.59
11	4.42	5.53	53.16	2.60	15.44	10.66	1.04	83506.97
12	5.73	2.48	57.30	1.64	16.59	10.40	1.02	84620.08
13	4.05	2.84	60.24	1.85	16.63	10.45	1.03	84027.72
14	10.39	4.39	58.31	2.81	16.16	10.69	1.04	81711.26
15	8.68	3.56	57.27	2.42	16.53	10.48	1.02	83493.88
16	8.45	4.17	56.58	2.62	16.42	10.31	1.02	85771.85
17	8.81	5.14	55.11	2.46	16.74	10.16	1.03	86397.79
18	5.75	3.86	55.75	1.38	17.69	10.19	1.04	85223.87
19	8.59	5.91	53.84	2.01	16.73	10.24	1.03	85373.57
20	8.22	6.27	52.06	1.83	17.21	10.12	1.04	86207.53
21	8.72	4.40	63.76	1.33	17.60	10.30	1.04	84521.82
22	9.45	7.99	59.69	1.06	18.32	10.18	1.04	84635.34
23	7.13	7.35	61.64	0.79	18.43	10.41	1.03	82919.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.56	6.00	54.86	1.90	17.15	10.28	1.03	85041.38
最大值	10.39	10.06	68.72	2.81	18.45	10.69	1.06	88465.50
發生時間	14	8	6	14	5	14		5
最小值	0.09	2.48	44.15	0.79	15.44	9.75	1.00	81711.26
發生時間	0	12	7	23	11	5		14
零點偏移(率)	-0.01 %	-0.01 %	-0.13 %	-0.02 %		0.04		-0.20 %
全幅偏移(率)	0.00 %	-0.40 %	-0.23 %	0.00 %		-0.10		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.48	5.23	46.48	1.12	15.89	10.38	0.98	78420.22
1	1.44	4.28	42.75	1.48	14.47	11.03	0.98	73347.71
2	3.82	5.43	50.80	1.27	16.60	10.18	0.98	77374.33
3	5.02	7.45	50.85	1.52	16.60	9.67	0.97	78635.53
4	4.52	5.39	59.65	2.41	13.76	11.15	0.97	73048.11
5	6.66	5.25	55.72	1.35	16.15	10.97	0.97	79187.10
6	5.15	5.09	47.60	1.58	15.54	10.71	0.97	80746.14
7	6.05	3.86	53.99	1.20	16.36	10.83	1.01	82523.01
8	3.71	3.76	65.81	0.91	16.99	10.57	1.03	80303.17
9	5.06	4.17	52.26	1.26	15.67	10.77	1.02	79049.91
10	4.12	11.07	44.39	1.45	15.51	10.73	1.03	78353.60
11	7.00	7.41	49.71	1.79	14.90	10.98	1.01	74060.31
12	7.77	3.44	54.43	1.70	15.26	10.95	1.05	74657.88
13	4.49	4.06	52.02	1.16	15.88	10.45	1.01	78155.05
14	4.10	6.12	45.86	0.91	15.74	10.91	0.99	75723.61
15	4.65	4.52	47.47	0.98	16.46	10.73	1.03	77762.57
16	7.57	3.93	52.90	1.10	16.63	10.48	1.03	81226.87
17	7.30	3.98	60.42	1.05	17.89	9.92	0.99	84439.35
18	5.23	4.29	54.31	1.12	16.60	9.91	1.00	83158.02
19	4.53	4.12	43.09	1.09	16.17	10.50	0.99	79494.03
20	3.25	4.38	49.38	0.86	16.74	10.33	0.99	79588.17
21	4.01	5.43	43.59	1.15	15.65	10.42	0.99	78393.28
22	3.05	5.47	57.39	0.94	17.55	10.33	0.99	80576.73
23	2.88	6.63	48.86	0.75	17.47	10.16	0.99	79202.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.70	5.20	51.24	1.26	16.10	10.54	1.00	78642.81
最大值	7.77	11.07	65.81	2.41	17.89	11.15	1.05	84439.35
發生時間	12	10	8	4	17	4		17
最小值	1.44	3.44	42.75	0.75	13.76	9.67	0.97	73048.11
發生時間	1	12	1	23	4	3		4
零點偏移(率)	-0.01 %	-0.04 %	-0.04 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	-0.36 %	0.04 %	-0.51 %	-0.01 %		0.14		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								