

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月22日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.72	7.06	43.97	3.25	14.89	12.34	1.34	75718.69
1	3.26	10.24	63.49	3.56	15.30	12.95	1.34	70441.73
2	0.79	9.95	55.88	3.09	14.70	12.79	1.34	72139.90
3	1.34	10.04	59.97	3.41	14.09	12.91	1.34	71369.11
4	3.20	11.20	63.90	3.92	13.81	13.42	1.34	67406.93
5	0.73	9.18	58.19	3.29	14.16	13.13	1.35	63442.49
6	1.83	8.53	58.53	3.08	14.65	12.76	1.36	72754.03
7	1.78	8.72	65.70	2.04	15.61	12.93	1.36	70335.55
8	3.93	8.05	47.88	3.08	14.60	12.43	1.35	75437.83
9	6.07	7.78	54.50	3.34	14.80	12.05	1.34	78496.46
10	7.40	7.67	59.95	3.83	13.98	12.21	1.34	78112.09
11	9.05	8.16	61.38	2.94	14.66	12.31	1.35	76129.84
12	8.75	7.92	61.37	1.47	15.88	12.09	1.36	77535.46
13	7.23	11.13	60.20	1.42	17.19	11.73	1.36	79062.38
14	8.98	10.27	52.41	2.97	15.30	12.00	1.35	78549.68
15	6.05	5.81	60.85	2.17	15.98	12.07	1.36	77159.96
16	5.26	6.64	54.27	3.17	14.50	12.14	1.35	77264.75
17	7.13	6.44	57.73	2.59	15.78	11.97	1.36	78215.40
18	7.78	6.70	58.16	3.57	14.26	12.16	1.36	77017.71
19	5.11	6.61	63.40	2.32	15.52	12.03	1.35	77719.94
20	5.80	6.37	64.75	2.06	16.78	11.68	1.34	79997.53
21	4.57	7.34	56.93	2.74	15.65	11.80	1.34	80121.95
22	5.78	6.56	58.00	3.02	15.23	12.10	1.34	77563.70
23	8.91	6.64	60.49	2.91	15.32	12.25	1.34	76409.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.19	8.13	58.41	2.89	15.11	12.34	1.35	75350.11
最 大 值	9.05	11.20	65.70	3.92	17.19	13.42	1.37	80121.95
發生時間	11	4	7	4	13	4		21
最 小 值	0.73	5.81	43.97	1.42	13.81	11.68	1.33	63442.49
發生時間	5	15	0	13	4	20		5
零點偏移(率)	-0.07 %	0.00 %	-0.00 %	-0.01 %		-0.04		0.10 %
全幅偏移(率)	0.00 %	0.72 %	0.14 %	-0.02 %		-0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月22日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.17	8.03	58.98	1.87	17.90	11.08	1.02	81740.67
1	8.12	10.39	53.45	2.66	18.31	11.13	1.01	78968.98
2	8.36	8.53	58.74	2.23	17.92	11.52	1.02	74126.84
3	9.12	7.40	53.82	1.61	19.88	10.11	1.02	86704.50
4	9.99	6.95	52.59	1.20	19.88	10.25	1.02	84430.17
5	9.21	7.67	56.27	1.79	18.70	10.64	1.02	83211.30
6	5.72	7.25	48.24	2.61	16.98	10.86	1.00	89813.72
7	9.75	7.02	52.98	2.42	17.45	10.90	1.02	82737.50
8	9.20	6.79	58.86	2.15	18.07	10.76	1.02	83693.21
9	8.78	8.83	63.06	1.84	18.66	10.59	1.02	84311.34
10	8.86	7.46	46.18	2.07	17.31	10.85	1.02	80133.35
11	7.77	7.39	56.98	2.25	17.36	11.12	1.02	81049.65
12	11.88	8.42	58.34	2.19	18.08	10.71	1.02	83218.28
13	7.87	7.55	51.42	2.22	17.01	10.68	1.02	79037.78
14	9.08	6.95	53.79	1.68	17.97	10.57	1.02	81290.96
15	7.80	7.09	58.38	1.94	16.95	11.09	1.02	79704.61
16	10.11	11.44	58.08	2.74	17.31	10.63	1.02	85119.11
17	8.83	10.72	57.46	3.31	16.18	11.06	1.02	81875.76
18	8.71	7.53	60.13	2.58	17.27	11.11	1.02	81783.58
19	8.82	7.52	51.82	2.56	17.36	10.95	1.02	82551.45
20	10.85	7.30	51.02	3.02	16.94	10.83	1.02	84013.13
21	9.64	8.96	58.73	2.36	18.28	10.39	1.02	85876.07
22	7.43	8.56	57.61	1.82	18.23	10.52	1.01	85439.84
23	9.61	8.03	58.07	1.53	19.16	10.33	1.02	85511.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.86	8.07	55.62	2.19	17.88	10.78	1.02	82764.30
最 大 值	11.88	11.44	63.06	3.31	19.88	11.52	1.03	89813.72
發生時間	12	16	9	17	3	2		6
最 小 值	5.72	6.79	46.18	1.20	16.18	10.11	0.99	74126.84
發生時間	6	8	10	4	17	3		2
零點偏移(率)	-0.14 %	-0.00 %	-0.08 %	-0.08 %		-0.07		-0.20 %
全幅偏移(率)	0.14 %	0.24 %	0.76 %	0.38 %		-0.45		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月22日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.71	7.13	64.13	2.97	17.75	9.80	1.42	76604.88
1	5.89	10.89	60.00	3.12	19.10	9.11	1.43	79684.63
2	10.46	10.18	52.29	3.18	15.78	9.75	1.41	76903.28
3	5.15	7.77	60.50	2.87	18.05	9.16	1.38	81029.93
4	5.75	7.26	58.65	2.92	18.37	9.62	1.39	80546.06
5	5.67	7.46	61.73	2.99	18.60	9.48	1.43	82130.87
6	4.16	9.56	58.34	2.82	18.08	9.42	1.42	78432.04
7	5.35	7.69	57.64	3.15	18.80	8.89	1.38	80099.25
8	4.93	7.99	55.52	3.01	19.16	8.80	1.37	80712.39
9	5.81	10.79	50.03	2.89	17.92	9.27	1.39	78822.73
10	5.20	8.07	50.20	2.62	16.88	9.08	1.41	74812.63
11	0.60	7.25	57.04	2.43	18.53	9.16	1.40	73271.18
12	0.55	9.11	54.44	2.40	17.89	9.10	1.38	74463.22
13	2.03	12.55	51.32	2.59	19.39	8.32	1.37	79184.42
14	2.54	4.85	50.12	1.57	16.61	9.21	1.38	74124.87
15	6.07	5.09	55.08	2.73	17.08	9.27	1.39	73834.49
16	1.09	6.86	53.94	2.42	17.56	8.97	1.38	76031.53
17	3.50	6.82	62.57	2.63	17.37	9.33	1.38	78413.11
18	4.35	7.93	62.88	2.86	16.93	9.42	1.40	76653.31
19	3.44	5.36	61.14	2.58	17.42	9.39	1.42	77151.56
20	4.25	8.11	58.47	2.74	17.99	8.96	1.41	80994.69
21	6.70	5.78	53.20	2.92	17.38	8.93	1.41	78737.79
22	12.28	5.06	61.80	3.17	17.50	9.17	1.39	76402.63
23	11.78	9.02	50.47	4.27	19.13	8.49	1.39	77583.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.22	7.86	56.73	2.83	17.89	9.17	1.40	77776.02
最 大 值	12.28	12.55	64.13	4.27	19.39	9.80	1.46	82130.87
發生時間	22	13	0	23	13	0		5
最 小 值	0.55	4.85	50.03	1.57	15.78	8.32	1.36	73271.18
發生時間	12	14	9	14	2	13		11
零點偏移(率)	-0.56 %	-0.00 %	-0.09 %	-0.06 %		-0.05		-0.20 %
全幅偏移(率)	0.20 %	0.21 %	-0.31 %	0.00 %		0.15		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								