

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.56	1.71	51.14	3.21	19.52	10.02	1.39	76718.78
1	8.09	1.97	45.90	3.31	18.05	11.00	1.39	70057.16
2	9.81	1.84	58.11	3.83	17.07	11.35	1.38	69660.71
3	8.21	1.76	65.18	3.40	18.24	11.00	1.38	72598.59
4	9.81	3.11	41.37	3.92	18.47	10.38	1.37	74026.18
5	4.96	3.07	62.29	2.77	18.36	10.70	1.36	73819.29
6	10.61	1.69	56.11	3.51	17.46	11.00	1.34	73382.00
7	9.17	1.65	54.47	3.26	18.10	10.76	1.34	73490.74
8	9.56	1.63	57.31	2.90	19.27	10.58	1.33	74253.70
9	8.65	1.87	51.38	3.12	20.23	9.70	1.35	75824.27
10	8.48	2.01	40.95	3.78	16.45	11.13	1.36	69112.79
11	9.09	2.59	45.90	3.75	16.33	10.70	1.32	71445.32
12	9.11	1.64	55.11	3.45	17.17	10.73	1.34	70565.69
13	10.34	1.72	50.99	3.63	17.03	10.83	1.34	70841.74
14	8.27	1.97	51.45	3.15	17.80	10.69	1.32	71643.15
15	8.03	1.70	47.80	3.25	17.22	10.93	1.37	70736.53
16	8.34	1.71	44.94	3.20	18.09	10.53	1.37	73036.82
17	8.42	1.73	49.27	2.98	17.78	10.70	1.34	72727.38
18	9.22	1.69	56.85	3.34	17.18	11.05	1.33	69968.80
19	10.84	2.15	55.07	3.68	19.20	10.08	1.33	74543.68
20	9.75	2.43	35.61	3.99	17.06	10.73	1.34	70590.98
21	8.35	2.02	48.80	3.18	17.68	10.79	1.33	70873.91
22	8.30	1.89	49.18	3.10	17.73	10.92	1.33	69666.35
23	10.39	2.14	58.51	2.99	19.66	10.03	1.33	74140.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.93	1.99	51.40	3.36	17.96	10.68	1.35	72238.54
最大值	10.84	3.11	65.18	3.99	20.23	11.35	1.39	76718.78
發生時間	19	4	3	20	9	2		0
最小值	4.96	1.63	35.61	2.77	16.33	9.70	1.30	69112.79
發生時間	5	8	20	5	11	9		10
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	0.00 %		0.07	0.00	0.00 %
全幅偏移(率)	1.60 %	1.02 %	0.13 %	0.47 %		0.21	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.53	3.25	40.16	1.22	19.48	9.32	1.38	86067.32
1	8.09	2.27	52.31	1.58	19.58	9.77	1.38	82050.53
2	7.43	1.66	58.67	1.59	18.88	9.79	1.38	83740.86
3	9.12	1.82	48.82	1.96	18.37	9.89	1.40	84910.25
4	10.05	2.02	52.73	2.20	18.50	9.73	1.39	85289.48
5	8.60	3.56	62.16	1.69	18.57	9.94	1.39	84699.79
6	6.47	3.31	64.67	1.25	18.50	10.63	1.37	79539.16
7	7.62	1.79	61.80	1.36	19.23	10.07	1.38	82301.93
8	6.39	1.76	45.88	1.34	19.68	9.50	1.38	82000.23
9	9.79	3.42	46.46	2.18	17.67	9.48	1.38	80742.84
10	8.06	4.80	50.45	1.79	16.84	9.60	1.38	82163.37
11	7.53	2.29	58.97	1.63	16.98	10.09	1.38	80645.35
12	5.49	2.34	54.04	1.68	17.06	10.08	1.37	80037.66
13	15.30	9.28	60.08	6.64	16.96	10.11	1.37	75747.21
14	12.08	2.08	56.06	7.46	17.89	9.81	1.38	80933.33
15	6.36	2.07	49.30	2.13	17.49	9.82	1.39	80193.77
16	6.26	1.59	59.43	1.31	17.77	10.19	1.38	79265.93
17	4.70	2.94	55.67	1.27	18.40	10.00	1.38	77266.46
18	8.52	4.23	52.33	1.20	20.24	9.17	1.37	81317.88
19	10.66	4.63	40.92	2.21	18.34	9.17	1.36	79530.11
20	9.35	4.28	45.41	1.71	18.44	9.37	1.38	82092.73
21	10.40	1.72	59.85	1.25	19.00	9.81	1.38	86836.82
22	9.66	1.77	58.36	1.38	19.33	9.71	1.38	84924.59
23	10.19	1.73	60.87	1.35	19.46	9.72	1.38	87368.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.44	2.94	53.97	2.06	18.44	9.78	1.38	82069.41
最大值	15.30	9.28	64.67	7.46	20.24	10.63	1.42	87368.24
發生時間	13	13	6	14	18	6		23
最小值	4.53	1.59	40.16	1.20	16.84	9.17	1.35	75747.21
發生時間	0	16	0	18	10	18		13
零點偏移(率)	-0.09 %	-0.00 %	-0.00 %	-0.04 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.01 %	0.13 %	0.05 %	0.16 %		0.02	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.60	3.43	58.42	2.31	17.81	10.34	1.31	81139.75
1	6.85	3.78	53.33	2.59	18.28	10.24	1.31	85444.20
2	6.57	2.42	59.64	2.73	18.53	10.22	1.31	85627.51
3	6.10	3.19	48.74	2.48	18.07	10.19	1.30	83413.62
4	7.41	2.58	57.14	2.63	16.89	10.42	1.30	83426.92
5	8.45	2.23	59.62	3.05	15.79	10.65	1.30	81584.27
6	9.13	3.64	56.94	3.21	15.72	10.82	1.30	81544.52
7	7.94	3.84	57.51	2.39	16.49	10.55	1.32	89755.73
8	8.88	3.05	57.64	2.58	16.74	10.71	1.30	80673.63
9	8.79	2.00	53.95	2.37	17.81	10.21	1.32	83032.33
10	9.35	5.90	58.03	2.50	16.22	10.45	1.31	80895.25
11	9.13	6.11	50.76	3.29	14.17	11.04	1.31	77181.08
12	8.57	1.93	62.20	2.54	16.54	10.62	1.37	81569.81
13	15.58	2.70	59.50	3.57	16.67	10.58	1.34	81751.72
14	12.43	2.33	60.32	8.43	17.14	10.59	1.29	80375.25
15	7.70	2.30	55.96	3.24	14.96	10.98	1.30	77143.47
16	8.73	3.47	56.45	2.54	16.62	10.49	1.30	81238.78
17	6.40	4.72	59.22	2.27	17.25	10.56	1.30	79816.21
18	9.53	3.28	49.70	2.70	17.23	10.11	1.30	80072.21
19	8.25	6.73	52.17	2.82	16.03	10.28	1.30	81796.31
20	9.82	3.41	56.95	2.92	15.52	10.72	1.31	81181.81
21	10.46	10.80	55.16	3.71	13.95	10.93	1.30	79499.73
22	8.24	2.42	60.87	3.15	14.86	11.03	1.30	78467.52
23	10.19	2.09	54.55	2.40	17.11	10.43	1.30	83249.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.63	3.68	56.45	3.02	16.52	10.55	1.31	81661.72
最大值	15.58	10.80	62.20	8.43	18.53	11.04	1.38	89755.73
發生時間	13	21	12	14	2	11		7
最小值	2.60	1.93	48.74	2.27	13.95	10.11	1.28	77143.47
發生時間	0	12	3	17	21	18		15
零點偏移(率)	-0.21 %	-0.01 %	-0.09 %	-0.07 %		0.02	0.00	0.00 %
全幅偏移(率)	3.17 %	1.04 %	-0.01 %	0.56 %		0.46	0.02	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								