

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月09日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.60	4.71	51.07	3.53	12.77	13.18	1.06	71595.56
1	10.02	5.60	64.81	2.67	13.87	12.20	1.05	79285.95
2	9.25	5.84	56.03	3.90	12.11	12.29	1.06	79647.39
3	9.01	5.70	53.99	3.61	12.37	12.67	1.06	76202.50
4	9.74	5.49	58.94	3.60	12.56	12.70	1.05	76193.53
5	14.17	6.88	45.05	3.50	11.67	12.40	1.01	76730.72
6	12.21	5.34	51.10	3.14	11.94	12.64	1.01	77216.04
7	8.49	6.99	57.48	3.06	11.70	13.08	1.02	73391.88
8	9.13	6.80	57.92	2.92	11.97	13.05	1.01	73508.76
9	10.57	5.61	55.05	3.21	11.56	12.58	0.99	78067.06
10	12.51	5.84	49.79	3.22	12.01	12.62	0.99	77782.38
11	10.78	10.36	51.25	3.60	11.16	12.96	1.00	74971.72
12	10.32	1.58	60.56	2.90	11.86	12.97	1.02	74628.98
13	9.84	1.89	55.75	1.96	13.32	12.17	1.03	80036.82
14	9.45	2.41	41.35	2.76	12.65	12.37	1.00	78861.99
15	8.71	2.49	44.00	2.10	13.36	12.28	1.00	79582.68
16	10.79	3.04	42.46	3.18	12.14	12.47	0.98	78978.00
17	9.36	4.18	57.59	2.86	12.41	13.05	1.00	73136.14
18	11.20	2.32	54.82	2.17	13.44	12.14	1.00	80168.88
19	6.95	4.28	51.31	2.48	13.01	12.72	1.02	75050.71
20	6.67	6.02	57.57	2.52	12.45	13.31	1.04	70787.24
21	6.81	2.38	50.19	2.19	13.47	12.26	1.03	79373.27
22	8.34	2.41	53.48	2.33	14.03	12.18	1.03	79522.11
23	9.86	2.18	47.51	2.36	13.81	11.93	1.02	81722.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.53	4.60	52.88	2.91	12.57	12.59	1.02	76935.11
最 大 值	14.17	10.36	64.81	3.90	14.03	13.31	1.09	81722.36
發生時間	5	11	1	2	22	20		23
最 小 值	4.60	1.58	41.35	1.96	11.16	11.93	0.98	70787.24
發生時間	0	12	14	13	11	23		20
零點偏移(率)	0.00 %	0.00 %	-0.00 %	-0.00 %		-0.03		0.20 %
全幅偏移(率)	0.02 %	0.04 %	0.04 %	0.11 %		0.01		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 113年02月09日

[illegible]

