

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.67	7.32	51.80	1.45	17.18	11.60	1.00	82354.05
1	7.16	6.85	49.33	1.69	18.14	11.38	1.01	83957.37
2	8.45	7.14	54.26	1.30	17.50	11.41	1.02	83201.25
3	8.90	7.08	57.63	1.67	16.46	11.64	1.00	82479.06
4	7.70	6.80	61.96	1.11	17.55	11.41	0.98	83539.46
5	9.68	7.10	56.49	1.38	17.59	11.41	0.97	82162.91
6	7.74	7.03	58.55	1.06	17.09	11.81	0.98	80433.33
7	5.91	7.43	62.00	0.87	17.77	11.99	0.99	78418.02
8	6.39	6.79	57.97	0.86	17.95	11.50	0.99	82334.92
9	7.04	6.57	49.42	1.89	16.23	11.72	0.96	81422.51
10	5.81	6.77	56.15	1.19	17.25	11.68	0.95	80776.90
11	4.30	6.97	63.22	0.71	17.23	11.62	0.99	81252.27
12	9.15	7.50	54.45	1.64	16.83	11.63	0.97	81581.46
13	7.19	7.32	58.10	0.65	18.27	11.48	0.97	81702.15
14	5.56	7.22	62.24	0.66	18.29	11.43	0.97	82394.06
15	9.60	7.15	45.82	1.57	16.82	11.48	0.97	83195.48
16	8.58	6.88	68.81	1.12	17.76	11.41	0.97	82771.65
17	1.28	7.24	67.22	0.74	17.09	12.03	0.98	78445.68
18	0.16	9.49	55.38	0.58	17.58	12.46	1.01	74308.20
19	3.19	7.28	52.38	0.59	19.05	10.92	0.99	85993.68
20	9.29	7.51	53.78	1.12	18.57	11.08	0.99	85378.62
21	8.37	7.60	55.42	0.99	17.99	11.56	0.98	81721.45
22	8.46	7.81	60.11	0.87	17.97	11.94	0.98	78620.74
23	6.21	8.29	61.03	0.99	17.37	11.87	0.99	79487.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.78	7.30	57.23	1.11	17.56	11.60	0.98	81580.51
最大值	9.68	9.49	68.81	1.89	19.05	12.46	1.04	85993.68
發生時間	5	18	16	9	19	18		19
最小值	0.16	6.57	45.82	0.58	16.23	10.92	0.94	74308.20
發生時間	18	9	15	18	9	19		18
零點偏移(率)	-0.01 %	-0.00 %	-0.00 %	0.00 %		-0.09		0.00 %
全幅偏移(率)	0.00 %	0.38 %	-0.26 %	-0.00 %		-0.06		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.60	4.22	52.47	2.40	15.56	11.55	1.02	79235.94
1	1.40	4.29	49.51	1.57	18.25	11.20	1.02	79610.51
2	5.13	3.90	53.09	2.24	17.10	11.29	1.02	79559.63
3	9.02	4.35	47.92	2.88	16.49	11.46	1.00	78728.43
4	7.02	4.16	58.57	1.83	17.61	11.48	0.99	77945.27
5	7.10	4.48	56.06	1.72	18.36	10.91	0.99	81325.48
6	2.84	5.43	52.96	1.22	18.10	11.13	1.02	82805.29
7	6.12	4.95	50.92	1.96	17.43	11.53	1.04	77364.72
8	6.27	4.32	69.30	1.48	18.14	11.44	1.02	76935.94
9	6.31	3.91	47.07	1.83	18.02	10.97	1.02	80437.43
10	7.52	4.93	56.09	2.69	15.51	11.74	1.03	76480.45
11	8.66	5.14	66.40	2.54	16.14	11.54	1.04	77959.39
12	4.29	4.66	56.71	1.95	16.46	11.28	1.02	79249.35
13	2.66	4.53	67.24	1.35	16.81	11.72	1.03	75960.33
14	1.15	5.63	53.53	1.84	16.66	12.14	1.02	72679.16
15	3.82	5.15	51.37	2.01	17.12	11.25	1.02	79630.75
16	9.45	4.93	58.05	2.25	16.68	11.18	1.02	80337.99
17	9.87	5.17	63.69	2.51	17.24	11.08	1.02	81018.57
18	9.00	5.17	63.51	1.35	18.95	10.82	1.02	81367.43
19	9.92	5.94	44.06	1.49	19.34	10.17	1.02	86330.48
20	9.35	7.87	43.46	1.91	17.93	10.61	1.03	83857.35
21	9.90	4.72	55.28	1.90	17.41	11.02	1.05	81316.75
22	9.90	4.90	50.77	2.23	17.27	11.17	1.04	79863.26
23	6.12	5.09	59.78	1.74	17.61	11.62	1.05	76252.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.52	4.91	55.33	1.95	17.34	11.26	1.02	79427.20
最大值	9.92	7.87	69.30	2.88	19.34	12.14	1.06	86330.48
發生時間	19	20	8	3	19	14		19
最小值	1.15	3.90	43.46	1.22	15.51	10.17	0.99	72679.16
發生時間	14	2	20	6	10	19		14
零點偏移(率)	-0.09 %	0.00 %	-0.01 %	-0.00 %		-0.07		-0.10 %
全幅偏移(率)	0.14 %	0.19 %	0.03 %	0.01 %		-0.24		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.00	5.88	53.15	0.69	16.77	11.07	1.00	78499.51
1	1.26	4.56	55.55	0.33	19.30	10.55	0.99	80449.67
2	3.19	4.86	49.01	0.69	17.49	10.49	0.99	80434.69
3	2.00	4.98	46.60	0.25	18.59	10.38	0.99	79699.80
4	1.25	4.47	53.29	0.30	17.65	10.64	0.99	77518.52
5	2.75	3.80	50.07	0.26	19.86	10.02	1.00	82991.39
6	1.41	2.46	46.96	0.22	19.00	10.04	0.99	81566.69
7	1.74	6.09	56.36	0.19	18.89	10.91	1.01	79281.31
8	1.23	7.95	42.53	0.18	20.09	10.04	1.01	82825.48
9	1.26	6.42	44.63	0.17	19.70	10.23	1.02	82306.15
10	1.19	5.90	51.85	0.21	18.16	10.58	1.00	80531.20
11	2.06	6.22	55.20	0.80	16.36	11.10	1.02	76522.96
12	6.76	7.45	50.56	1.55	16.70	10.77	1.01	80506.83
13	2.93	6.91	48.05	0.55	15.61	11.00	1.01	77580.83
14	1.21	5.54	54.01	0.38	16.29	11.06	0.99	76966.72
15	1.78	8.08	51.30	0.52	16.00	10.76	1.00	78306.41
16	1.17	1.20	51.33	0.27	18.15	10.27	0.99	79069.37
17	1.17	1.36	53.50	0.22	18.56	10.41	1.00	82373.22
18	2.24	5.11	43.57	0.21	20.11	9.61	1.01	86987.64
19	1.23	2.44	50.28	0.19	19.63	10.09	1.02	83433.60
20	6.63	5.63	46.58	0.48	18.88	9.97	1.03	85992.53
21	2.10	9.70	51.11	0.19	19.02	10.19	1.03	83586.04
22	6.30	5.13	49.60	0.51	17.26	10.79	1.03	79959.04
23	4.62	4.64	57.96	0.29	18.24	10.65	1.01	78575.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.48	5.28	50.54	0.40	18.18	10.48	1.01	80665.23
最大值	6.76	9.70	57.96	1.55	20.11	11.10	1.04	86987.64
發生時間	12	21	23	12	18	11		18
最小值	1.17	1.20	42.53	0.17	15.61	9.61	0.99	76522.96
發生時間	16	16	8	9	13	18		11
零點偏移(率)	-0.13 %	0.00 %	-0.03 %	-0.00 %		-0.15		0.00 %
全幅偏移(率)	0.02 %	0.09 %	0.41 %	-0.04 %		-0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								