

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月07日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.63	3.91	56.15	2.36	16.48	11.67	1.29	78945.10
1	3.26	3.33	64.65	1.37	17.38	11.89	1.28	77246.91
2	6.01	3.26	59.33	2.34	17.27	11.57	1.28	80330.66
3	5.89	9.61	65.65	2.90	16.45	11.74	1.27	79804.71
4	7.11	3.63	61.98	2.85	16.42	11.55	1.28	81247.76
5	3.27	1.74	62.36	2.88	17.36	11.20	1.25	88382.82
6	5.46	2.63	58.94	2.85	18.11	11.03	1.25	83931.27
7	9.84	3.05	54.68	2.57	15.97	11.53	1.27	81315.98
8	4.13	2.42	58.82	3.29	17.02	11.38	1.28	82017.74
9	3.47	4.16	60.61	2.71	17.20	11.38	1.25	81358.19
10	4.36	3.05	58.46	3.62	16.54	11.38	1.27	81903.75
11	6.38	2.88	51.53	3.22	15.96	11.80	1.26	79235.60
12	5.93	4.00	64.80	2.83	15.51	11.73	1.26	80192.45
13	6.38	4.36	64.56	2.76	15.58	11.71	1.26	80517.18
14	11.06	11.61	61.12	3.55	13.87	12.18	1.26	76454.25
15	9.62	5.01	61.81	2.15	14.07	11.94	1.26	76222.83
16	10.17	2.51	61.54	2.27	14.78	11.95	1.28	75698.74
17	9.42	4.80	57.43	3.20	14.30	12.03	1.27	76643.05
18	3.32	3.18	57.54	1.41	15.00	11.97	1.27	76172.96
19	3.83	3.11	66.28	1.55	17.49	11.57	1.28	79844.57
20	1.02	3.31	58.80	3.67	15.06	11.69	1.28	80957.63
21	0.83	2.97	65.98	2.54	15.74	11.97	1.28	78170.91
22	2.40	4.04	61.19	2.45	16.82	11.61	1.27	80149.03
23	2.83	4.21	63.43	2.91	16.43	11.62	1.28	79943.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.48	4.03	60.74	2.68	16.12	11.67	1.27	79861.98
最 大 值	11.06	11.61	66.28	3.67	18.11	12.18	1.29	88382.82
發生時間	14	14	19	20	6	14		5
最 小 值	0.83	1.74	51.53	1.37	13.87	11.03	1.25	75698.74
發生時間	21	5	11	1	14	6		16
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	0.00 %		-0.03		0.10 %
全幅偏移(率)	0.00 %	0.70 %	-0.43 %	1.01 %		0.07		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年06月07日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.25	3.39	59.06	1.48	19.81	9.80	1.06	88493.83
1	9.14	3.22	57.10	1.85	20.90	9.69	1.06	87146.58
2	5.25	2.75	55.49	1.24	18.86	10.50	1.06	80978.58
3	6.86	2.84	49.87	1.42	18.88	10.13	1.06	83234.83
4	9.16	3.18	56.37	2.27	17.68	10.54	1.06	79193.45
5	6.86	4.66	62.49	1.58	18.83	10.78	1.06	79978.30
6	2.58	2.14	52.42	2.52	18.07	10.24	1.05	87175.45
7	2.41	2.21	56.65	1.93	17.84	10.85	1.05	81676.49
8	8.76	3.25	57.14	2.44	17.88	10.58	1.05	83556.81
9	5.27	3.08	59.13	2.97	17.28	10.97	1.05	79167.37
10	4.75	3.04	54.08	1.85	19.19	9.79	1.06	85777.47
11	4.21	3.59	51.74	2.12	18.20	10.10	1.05	82862.23
12	5.95	3.16	57.25	2.29	18.71	10.37	1.06	83728.30
13	0.70	4.91	54.77	2.98	16.59	10.74	1.04	80100.48
14	0.24	13.27	61.57	3.27	15.35	11.42	1.04	75833.99
15	1.56	3.91	63.08	2.80	16.77	11.05	1.04	80339.46
16	14.85	2.68	62.48	4.46	16.76	10.97	1.05	81536.27
17	7.60	3.59	67.02	2.23	17.09	10.76	1.05	82652.78
18	3.93	4.48	64.61	2.01	18.20	10.56	1.05	83763.68
19	4.00	2.46	61.54	1.20	19.23	10.29	1.05	85219.93
20	2.87	2.43	62.16	2.31	17.71	10.50	1.05	84550.83
21	7.92	4.43	64.41	1.93	18.66	10.33	1.06	84678.70
22	2.33	3.23	61.97	1.31	18.13	10.89	1.06	78956.43
23	0.95	3.44	68.18	1.60	18.03	11.17	1.06	79097.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.31	3.72	59.19	2.17	18.11	10.54	1.05	82487.50
最 大 值	14.85	13.27	68.18	4.46	20.90	11.42	1.07	88493.83
發生時間	16	14	23	16	1	14		0
最 小 值	0.24	2.14	49.87	1.20	15.35	9.69	1.02	75833.99
發生時間	14	6	3	19	14	1		14
零點偏移(率)	-0.11 %	0.01 %	-0.01 %	-0.06 %		-0.06		-0.10 %
全幅偏移(率)	1.88 %	0.34 %	-0.39 %	0.56 %		-0.30		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年06月07日

報表日期: 114年06月07日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.83	3.61	65.15	2.68	19.39	9.44	1.42	81620.37
1	1.92	9.32	62.56	2.59	20.66	9.75	1.43	79890.92
2	9.96	11.05	65.56	3.05	18.78	10.06	1.46	77759.11
3	5.29	10.62	67.89	2.82	19.72	9.56	1.47	77698.00
4	6.42	7.79	54.42	2.84	17.80	10.19	1.47	76429.06
5	4.32	2.08	53.26	2.53	17.45	9.55	1.47	82337.77
6	8.48	3.04	60.34	2.88	17.86	9.69	1.48	85607.25
7	4.50	0.64	56.23	3.28	18.62	9.63	1.45	83406.28
8	6.34	4.02	58.21	3.16	18.71	9.48	1.47	84462.59
9	5.81	3.13	61.94	3.28	18.97	9.74	1.43	81367.51
10	10.45	4.08	54.88	3.44	17.77	9.59	1.46	82869.25
11	4.71	3.55	54.28	3.23	19.48	9.22	1.48	85747.36
12	0.69	14.53	53.67	3.15	20.79	8.73	1.47	83074.73
13	6.28	6.49	52.18	4.02	16.68	9.29	1.45	77916.12
14	11.11	3.88	56.97	1.89	16.49	9.72	1.42	73914.21
15	5.17	5.92	65.28	1.50	16.54	9.72	1.42	78524.00
16	8.29	7.51	55.71	1.60	17.51	9.40	1.41	79187.54
17	5.56	4.69	60.05	2.32	17.25	9.49	1.42	77652.96
18	2.78	2.49	67.09	2.97	19.40	9.34	1.42	78583.46
19	1.61	6.45	59.64	2.74	18.58	9.30	1.43	85302.03
20	1.72	5.81	65.27	2.84	16.58	10.07	1.43	82566.27
21	0.47	2.52	66.81	2.87	17.98	9.81	1.43	78846.43
22	0.67	3.00	63.39	2.76	18.98	9.30	1.43	83994.14
23	4.05	9.57	62.64	3.13	19.76	9.00	1.43	84538.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.14	5.66	60.14	2.82	18.41	9.54	1.44	80970.65
最 大 值	11.11	14.53	67.89	4.02	20.79	10.19	1.49	85747.36
發生時間	14	12	3	13	12	4		11
最 小 值	0.47	0.64	52.18	1.50	16.49	8.73	1.38	73914.21
發生時間	21	7	13	15	14	12		14
零點偏移(率)	-0.05 %	-0.00 %	-0.23 %	-0.05 %		-0.03		-0.10 %
全幅偏移(率)	0.02 %	0.60 %	-1.13 %	0.31 %		0.45		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								