

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月19日

| 項目      | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 9.85     | 12.35    | 41.25    | 0.83     | 18.81    | 10.82    | 1.05     | 75555.14  |
| 1       | 8.76     | 10.53    | 51.52    | 0.84     | 19.72    | 10.94    | 1.05     | 75002.13  |
| 2       | 7.30     | 8.18     | 40.22    | 1.13     | 18.00    | 11.02    | 1.06     | 74189.78  |
| 3       | 6.74     | 6.58     | 47.77    | 1.21     | 17.30    | 11.38    | 1.06     | 72311.79  |
| 4       | 10.01    | 11.15    | 54.47    | 1.28     | 16.71    | 11.30    | 1.05     | 74417.65  |
| 5       | 1.88     | 5.80     | 62.82    | 0.55     | 18.36    | 11.34    | 1.05     | 73635.34  |
| 6       | 7.52     | 7.83     | 51.70    | 0.74     | 18.44    | 10.87    | 1.05     | 76135.79  |
| 7       | 8.26     | 7.91     | 51.61    | 0.82     | 17.61    | 11.05    | 1.05     | 74093.58  |
| 8       | 9.31     | 13.39    | 43.52    | 1.56     | 16.27    | 11.13    | 1.05     | 73693.33  |
| 9       | 7.00     | 7.71     | 44.13    | 1.21     | 16.81    | 11.39    | 1.05     | 72281.19  |
| 10      | 7.87     | 6.04     | 38.98    | 1.23     | 16.62    | 11.33    | 1.02     | 73565.80  |
| 11      | 8.80     | 6.62     | 41.58    | 1.81     | 16.21    | 11.52    | 1.04     | 71897.61  |
| 12      | 5.32     | 7.41     | 56.06    | 0.83     | 17.10    | 11.84    | 1.05     | 69965.99  |
| 13      | 7.74     | 7.74     | 55.36    | 0.95     | 18.10    | 11.06    | 1.05     | 74177.46  |
| 14      | 5.82     | 8.20     | 45.55    | 0.94     | 17.61    | 11.04    | 1.05     | 73565.33  |
| 15      | 0.96     | 6.07     | 45.99    | 0.45     | 18.37    | 10.96    | 1.06     | 73799.87  |
| 16      | 7.86     | 6.63     | 59.74    | 0.59     | 17.96    | 11.22    | 1.05     | 74112.42  |
| 17      | 1.24     | 7.01     | 66.03    | 0.32     | 18.80    | 11.12    | 1.05     | 74457.54  |
| 18      | 0.41     | 5.89     | 47.62    | 0.49     | 19.58    | 10.58    | 1.02     | 77856.13  |
| 19      | 2.35     | 5.65     | 50.24    | 0.59     | 18.79    | 10.80    | 1.02     | 76406.47  |
| 20      | 5.41     | 6.07     | 55.75    | 0.56     | 18.62    | 10.71    | 1.04     | 77147.12  |
| 21      | 8.50     | 6.56     | 52.58    | 0.74     | 17.77    | 11.35    | 1.05     | 73177.13  |
| 22      | 5.96     | 5.82     | 62.90    | 0.52     | 18.96    | 11.26    | 1.03     | 73036.15  |
| 23      | 4.84     | 7.24     | 61.25    | 0.28     | 19.47    | 11.05    | 1.02     | 73615.12  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 6.24     | 7.68     | 51.19    | 0.85     | 18.00    | 11.13    | 1.04     | 74087.33  |
| 最大值     | 10.01    | 13.39    | 66.03    | 1.81     | 19.72    | 11.84    | 1.09     | 77856.13  |
| 發生時間    | 4        | 8        | 17       | 11       | 1        | 12       |          | 18        |
| 最小值     | 0.41     | 5.65     | 38.98    | 0.28     | 16.21    | 10.58    | 1.00     | 69965.99  |
| 發生時間    | 18       | 19       | 10       | 23       | 11       | 18       |          | 12        |
| 零點偏移(率) | -0.04 %  | -0.01 %  | -0.00 %  | -0.01 %  |          | -0.10    |          | 0.00 %    |
| 全幅偏移(率) | 0.01 %   | 2.14 %   | 1.11 %   | 1.11 %   |          | 0.11     |          | 0.10 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月19日

| 項目      | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 8.71     | 5.78     | 60.89    | 1.53     | 17.53    | 10.21    | 1.05     | 85966.57  |
| 1       | 4.46     | 3.84     | 58.76    | 1.33     | 18.80    | 9.93     | 1.04     | 86570.82  |
| 2       | 5.24     | 3.47     | 49.74    | 1.89     | 15.65    | 10.45    | 1.03     | 85466.42  |
| 3       | 7.55     | 3.28     | 65.42    | 2.06     | 15.16    | 10.87    | 1.02     | 82957.17  |
| 4       | 6.13     | 8.62     | 51.42    | 1.59     | 17.37    | 10.25    | 1.02     | 85410.95  |
| 5       | 7.30     | 5.42     | 57.96    | 1.46     | 18.41    | 9.64     | 1.02     | 89626.55  |
| 6       | 7.96     | 5.29     | 52.50    | 2.62     | 16.08    | 10.62    | 0.99     | 85808.31  |
| 7       | 5.16     | 8.79     | 52.16    | 2.39     | 16.39    | 10.61    | 0.99     | 83504.55  |
| 8       | 7.38     | 10.21    | 55.47    | 2.49     | 16.71    | 10.29    | 1.01     | 86416.02  |
| 9       | 9.32     | 6.83     | 51.25    | 2.27     | 16.25    | 10.44    | 1.03     | 85226.52  |
| 10      | 5.98     | 5.20     | 52.97    | 2.39     | 15.67    | 10.83    | 1.02     | 82011.79  |
| 11      | 1.67     | 5.63     | 54.18    | 1.15     | 18.40    | 9.93     | 1.02     | 86620.63  |
| 12      | 3.74     | 3.13     | 52.59    | 1.19     | 18.47    | 10.17    | 1.02     | 84624.06  |
| 13      | 3.56     | 4.67     | 47.10    | 1.75     | 17.74    | 10.08    | 1.01     | 85984.78  |
| 14      | 5.79     | 3.96     | 60.46    | 1.15     | 18.83    | 10.10    | 1.02     | 84674.85  |
| 15      | 6.48     | 4.96     | 51.36    | 1.99     | 17.46    | 10.43    | 1.01     | 83575.29  |
| 16      | 1.16     | 4.50     | 48.80    | 1.72     | 18.44    | 9.95     | 1.00     | 86726.06  |
| 17      | 0.11     | 5.42     | 53.87    | 2.15     | 18.38    | 9.84     | 1.00     | 87531.58  |
| 18      | 2.06     | 7.10     | 44.35    | 2.19     | 18.00    | 9.68     | 1.02     | 88514.79  |
| 19      | 0.69     | 6.27     | 47.20    | 1.22     | 18.88    | 9.72     | 1.02     | 87353.30  |
| 20      | 4.45     | 4.32     | 53.69    | 1.65     | 18.32    | 9.84     | 1.03     | 87820.60  |
| 21      | 6.26     | 3.95     | 52.89    | 1.26     | 19.86    | 9.78     | 1.04     | 85911.98  |
| 22      | 6.36     | 7.54     | 46.88    | 1.70     | 19.72    | 9.54     | 1.04     | 87925.76  |
| 23      | 7.44     | 1.83     | 51.75    | 0.96     | 20.43    | 9.48     | 1.05     | 87659.92  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 5.21     | 5.42     | 53.07    | 1.75     | 17.79    | 10.11    | 1.02     | 85995.39  |
| 最大值     | 9.32     | 10.21    | 65.42    | 2.62     | 20.43    | 10.87    | 1.05     | 89626.55  |
| 發生時間    | 9        | 8        | 3        | 6        | 23       | 3        |          | 5         |
| 最小值     | 0.11     | 1.83     | 44.35    | 0.96     | 15.16    | 9.48     | 0.99     | 82011.79  |
| 發生時間    | 17       | 23       | 18       | 23       | 3        | 23       |          | 10        |
| 零點偏移(率) | -0.07 %  | 0.00 %   | -0.01 %  | 0.00 %   |          | 0.03     |          | -0.20 %   |
| 全幅偏移(率) | 0.04 %   | 1.04 %   | 0.24 %   | 0.61 %   |          | 0.10     |          | -0.10 %   |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月19日

| 項目      | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 9.57     | 8.72     | 46.25    | 0.86     | 16.28    | 10.54    | 1.02     | 84403.64  |
| 1       | 8.99     | 10.28    | 41.84    | 1.02     | 16.98    | 10.42    | 1.02     | 82071.82  |
| 2       | 9.82     | 4.33     | 55.88    | 1.17     | 17.47    | 10.07    | 1.02     | 84338.11  |
| 3       | 8.92     | 8.63     | 53.00    | 1.84     | 14.27    | 11.13    | 1.03     | 78943.29  |
| 4       | 10.08    | 8.05     | 47.94    | 1.85     | 13.86    | 11.04    | 1.04     | 79994.82  |
| 5       | 9.18     | 2.91     | 56.33    | 1.86     | 14.16    | 11.13    | 1.02     | 76957.14  |
| 6       | 8.57     | 8.13     | 60.72    | 1.25     | 17.37    | 10.13    | 1.02     | 84479.18  |
| 7       | 6.82     | 3.67     | 49.23    | 1.17     | 15.78    | 10.18    | 1.05     | 84216.32  |
| 8       | 8.40     | 9.21     | 42.68    | 1.17     | 14.84    | 10.74    | 1.04     | 77065.93  |
| 9       | 8.98     | 4.49     | 44.28    | 1.77     | 15.52    | 10.50    | 1.05     | 77846.67  |
| 10      | 8.98     | 7.49     | 54.50    | 1.14     | 16.32    | 10.07    | 1.04     | 78287.23  |
| 11      | 7.83     | 3.86     | 58.65    | 2.15     | 13.73    | 10.80    | 1.06     | 71210.52  |
| 12      | 5.67     | 6.97     | 48.07    | 1.13     | 15.18    | 11.09    | 1.02     | 69939.04  |
| 13      | 0.02     | 5.80     | 58.04    | 0.30     | 16.59    | 11.10    | 1.02     | 72473.42  |
| 14      | 0.89     | 16.45    | 35.87    | 0.69     | 15.65    | 10.48    | 1.02     | 78496.76  |
| 15      | 7.40     | 5.16     | 43.05    | 0.91     | 15.75    | 10.55    | 1.02     | 77452.73  |
| 16      | 6.62     | 4.19     | 58.74    | 0.56     | 17.22    | 10.04    | 1.06     | 80364.68  |
| 17      | 8.68     | 8.33     | 46.12    | 1.25     | 15.31    | 10.44    | 1.06     | 81363.53  |
| 18      | 6.88     | 3.06     | 56.02    | 0.74     | 17.04    | 10.54    | 1.04     | 81357.29  |
| 19      | 6.66     | 6.10     | 43.76    | 0.89     | 15.66    | 10.76    | 1.02     | 79326.12  |
| 20      | 8.00     | 4.97     | 53.75    | 0.96     | 16.10    | 10.92    | 1.03     | 82524.82  |
| 21      | 7.59     | 4.91     | 48.03    | 0.78     | 16.61    | 10.65    | 1.03     | 84235.93  |
| 22      | 8.85     | 5.00     | 58.54    | 0.92     | 15.90    | 11.13    | 1.05     | 83143.44  |
| 23      | 8.13     | 5.72     | 43.86    | 0.69     | 16.71    | 10.62    | 1.05     | 82717.16  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 7.56     | 6.52     | 50.21    | 1.13     | 15.85    | 10.63    | 1.03     | 79717.07  |
| 最大值     | 10.08    | 16.45    | 60.72    | 2.15     | 17.47    | 11.13    | 1.07     | 84479.18  |
| 發生時間    | 4        | 14       | 6        | 11       | 2        | 3        |          | 6         |
| 最小值     | 0.02     | 2.91     | 35.87    | 0.30     | 13.73    | 10.04    | 1.00     | 69939.04  |
| 發生時間    | 13       | 5        | 14       | 13       | 11       | 16       |          | 12        |
| 零點偏移(率) | -0.02 %  | 0.00 %   | -0.00 %  | -0.00 %  |          | 0.00     |          | 0.00 %    |
| 全幅偏移(率) | 0.02 %   | -0.01 %  | -0.23 %  | 0.19 %   |          | 0.41     |          | 0.00 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |