

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.22	1.78	67.23	0.98	18.76	11.62	1.03	79573.71
1	7.88	2.89	46.37	2.00	17.28	11.60	1.02	81230.26
2	8.66	2.74	45.22	3.00	16.47	11.70	1.04	81044.14
3	8.96	3.02	53.11	1.69	17.40	11.79	1.05	79580.06
4	7.31	3.35	49.84	2.04	16.70	11.79	1.04	80229.75
5	7.89	2.61	50.65	1.39	18.05	11.50	1.02	77021.44
6	8.54	2.58	53.80	2.06	17.60	11.51	1.03	82047.14
7	7.83	2.40	62.80	1.57	18.66	11.43	1.02	81632.46
8	6.70	2.64	50.75	1.77	17.29	11.45	1.02	82300.58
9	8.32	2.73	60.78	1.83	18.22	11.33	1.03	82522.57
10	2.67	3.14	65.54	1.00	18.47	11.99	1.05	77130.31
11	0.13	3.71	68.66	0.75	19.16	12.27	1.06	73831.90
12	2.70	3.54	44.09	1.16	19.50	10.65	1.03	87225.21
13	7.44	3.48	55.91	2.00	18.53	10.94	1.02	85587.85
14	3.57	4.67	53.07	2.46	16.06	11.49	1.02	79950.54
15	1.72	7.93	48.82	3.30	14.00	11.90	1.02	75816.22
16	3.72	3.95	62.60	2.59	16.37	11.84	1.02	77141.68
17	5.79	1.39	44.29	2.26	16.89	11.41	1.02	82375.64
18	6.24	2.02	43.23	3.09	15.40	11.92	1.02	79443.86
19	7.30	1.86	49.11	2.77	16.61	11.90	1.03	78112.54
20	4.29	1.32	60.15	0.95	19.32	11.41	1.03	80197.55
21	5.73	1.21	68.37	0.96	19.50	11.01	1.05	84118.66
22	7.86	1.79	57.85	1.49	18.29	11.31	1.06	82579.87
23	7.01	4.93	41.74	2.11	17.06	11.40	1.04	80759.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.02	2.99	54.33	1.88	17.57	11.55	1.03	80477.23
最 大 值	8.96	7.93	68.66	3.30	19.50	12.27	1.07	87225.21
發生時間	3	15	11	15	12	11		12
最 小 值	0.13	1.21	41.74	0.75	14.00	10.65	1.02	73831.90
發生時間	11	21	23	11	15	12		11
零點偏移(率)	-0.41 %	-0.01 %	-0.29 %	-0.01 %		-0.08		0.00 %
全幅偏移(率)	0.00 %	-0.43 %	-0.42 %	0.16 %		0.03		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月27日

[illegible]

報表日期: 113年07月27日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.18	2.84	53.00	0.22	16.76	11.45	0.94	76259.36
1	10.29	3.69	51.52	0.69	16.24	11.53	0.95	75393.25
2	7.98	2.73	54.46	0.45	16.76	11.24	0.94	77585.06
3	11.35	2.50	58.78	0.51	16.87	11.14	0.93	78795.11
4	7.98	2.55	53.04	0.66	16.30	11.22	0.95	78244.32
5	9.51	2.51	57.38	0.52	16.52	11.25	0.93	77814.61
6	11.01	2.99	59.13	0.48	16.91	11.15	0.92	78534.38
7	8.34	3.51	48.80	0.39	17.35	11.78	0.98	74113.94
8	8.19	2.80	40.41	0.48	16.81	11.12	0.99	78854.24
9	10.97	2.50	42.74	0.52	17.21	10.99	0.98	79328.60
10	9.21	4.80	40.52	0.65	15.93	11.35	0.94	76807.53
11	9.87	3.12	47.85	0.97	15.25	11.48	0.95	77090.96
12	8.79	3.05	50.11	0.88	15.33	11.53	0.98	76391.99
13	10.02	3.07	50.06	0.67	16.29	11.17	0.93	78182.53
14	11.69	2.94	51.84	0.73	16.27	11.37	0.92	77200.74
15	9.56	2.91	54.61	0.60	16.62	11.25	0.92	77718.49
16	13.20	2.69	52.14	0.55	16.54	11.28	0.97	76992.93
17	8.88	2.51	50.74	0.53	16.08	11.42	0.99	76373.70
18	8.66	2.71	48.74	0.63	16.23	11.29	0.99	77483.29
19	9.81	2.56	53.74	0.30	18.20	10.80	0.99	79283.67
20	4.69	2.55	50.26	0.32	17.07	11.15	0.98	77807.83
21	4.97	2.60	50.85	0.48	16.73	11.24	0.94	78055.49
22	9.73	2.64	52.45	0.32	17.32	11.14	0.92	77743.52
23	7.65	3.81	49.42	0.99	14.74	11.71	0.97	75226.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.19	2.94	50.94	0.56	16.51	11.29	0.95	77386.74
最 大 值	13.20	4.80	59.13	0.99	18.20	11.78	1.01	79328.60
發生時間	16	10	6	23	19	7		9
最 小 值	4.69	2.50	40.41	0.22	14.74	10.80	0.92	74113.94
發生時間	20	3	8	0	23	19		7
零點偏移(率)	-0.29 %	-0.00 %	-0.05 %	-0.01 %		-0.11		0.00 %
全幅偏移(率)	0.62 %	-0.79 %	-0.52 %	0.07 %		0.25		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								