

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.66	13.54	63.19	1.05	18.77	11.62	1.26	77437.09
1	12.70	13.02	49.60	1.30	19.79	11.08	1.25	80817.05
2	6.19	12.71	51.08	1.14	20.18	10.83	1.25	83083.99
3	15.06	12.19	51.36	1.47	19.98	10.40	1.25	86217.53
4	5.40	12.09	48.99	1.18	20.17	10.27	1.25	87401.90
5	13.33	11.26	56.13	1.79	18.73	10.89	1.22	81646.01
6	8.45	11.66	58.71	1.55	18.64	11.17	1.21	81267.34
7	10.68	11.27	54.19	2.77	19.41	10.34	1.21	86877.75
8	9.69	11.73	58.23	1.97	18.65	10.69	1.23	84700.87
9	7.83	12.39	51.31	1.72	18.86	10.67	1.20	84795.04
10	10.41	13.23	51.53	1.80	18.72	10.60	1.20	85398.96
11	6.13	13.30	56.20	2.14	16.93	11.39	1.20	80517.58
12	7.53	13.31	54.90	2.44	15.97	11.58	1.20	80209.08
13	10.78	13.10	53.10	2.84	16.84	11.37	1.21	81420.32
14	6.85	12.79	55.74	2.32	18.34	11.01	1.20	82393.96
15	10.14	13.36	50.46	2.89	17.57	11.10	1.20	82472.15
16	8.08	13.15	57.79	2.71	15.79	11.47	1.19	81420.32
17	9.94	12.53	56.46	2.67	17.63	11.05	1.18	83402.64
18	10.57	12.75	59.08	2.13	18.08	11.28	1.18	80679.64
19	6.87	12.68	56.41	1.81	18.23	11.21	1.19	81598.12
20	9.43	12.53	60.85	1.94	18.24	11.10	1.20	82137.74
21	14.12	12.72	62.00	2.33	18.67	11.12	1.19	81564.60
22	5.75	12.65	51.25	1.93	17.35	11.27	1.18	81563.38
23	12.43	12.78	68.18	1.88	17.99	11.32	1.19	80863.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.50	12.61	55.70	1.99	18.31	11.03	1.21	82495.26
最大值	15.06	13.54	68.18	2.89	20.18	11.62	1.27	87401.90
發生時間	3	0	23	15	2	0		4
最小值	5.40	11.26	48.99	1.05	15.79	10.27	1.18	77437.09
發生時間	4	5	4	0	16	4		0
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	0.00 %		0.00	-0.01	0.10 %
全幅偏移(率)	-0.76 %	-0.56 %	0.36 %	-0.35 %		0.07	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.77	14.45	52.18	0.98	22.06	10.12	0.94	86182.83
1	6.46	12.20	48.18	0.79	20.89	10.43	0.94	84590.51
2	9.93	12.88	48.71	0.58	20.58	11.01	0.94	80230.03
3	10.56	12.39	45.62	0.58	21.16	10.51	0.94	83969.99
4	9.16	12.54	46.32	0.87	20.33	10.73	0.94	82941.09
5	10.31	12.31	49.10	0.52	20.81	10.66	0.94	83163.75
6	9.12	12.07	47.84	2.13	19.91	10.34	0.97	87589.70
7	10.83	12.04	50.72	1.26	20.71	10.35	0.99	85480.42
8	11.91	12.90	47.66	1.77	20.38	10.38	0.99	85357.03
9	6.14	14.30	52.34	1.94	19.97	10.49	1.01	84123.23
10	10.78	13.25	50.20	2.02	19.24	10.43	1.00	85686.51
11	8.36	13.84	53.66	2.56	17.90	10.83	0.99	83585.11
12	12.44	13.24	50.07	2.55	17.25	11.02	1.01	82075.23
13	4.89	13.21	48.24	1.44	18.38	11.01	1.02	81624.54
14	11.26	12.94	53.13	1.81	19.69	10.83	1.00	82329.60
15	9.09	12.74	50.40	1.85	18.32	11.05	0.99	82720.54
16	10.50	12.26	52.13	1.09	19.15	10.74	0.99	83517.29
17	6.05	12.04	54.75	0.46	20.95	10.29	0.98	85082.67
18	11.45	12.64	38.30	0.67	21.49	10.07	0.98	85991.06
19	8.19	12.83	40.13	1.02	19.88	10.13	0.99	86824.81
20	14.35	13.55	49.77	1.36	19.65	10.22	1.00	86534.09
21	7.77	12.71	39.34	0.80	20.43	10.07	0.99	86976.06
22	9.98	12.65	55.14	0.97	19.93	10.80	0.99	81201.64
23	8.24	12.82	46.38	0.37	20.79	10.78	0.99	81037.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.61	12.87	48.76	1.27	19.99	10.55	0.98	84117.31
最大值	14.35	14.45	55.14	2.56	22.06	11.05	1.02	87589.70
發生時間	20	0	22	11	0	15		6
最小值	4.89	12.04	38.30	0.37	17.25	10.07	0.94	80230.03
發生時間	13	7	18	23	12	18		2
零點偏移(率)	-0.08 %	0.00 %	-0.02 %	0.00 %		-0.01	-0.01	-0.10 %
全幅偏移(率)	-1.30 %	-1.72 %	1.00 %	0.30 %		0.04	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.10	11.15	50.40	1.25	21.50	8.74	1.31	74542.88
1	5.97	10.78	52.32	1.41	20.70	8.93	1.31	77034.73
2	5.40	10.98	47.12	1.37	20.78	8.58	1.31	75495.52
3	4.57	11.03	50.60	1.45	20.36	9.07	1.31	73456.79
4	5.08	11.64	43.04	1.55	20.58	9.03	1.29	72548.43
5	3.55	10.68	46.34	1.44	19.69	9.02	1.28	72999.01
6	7.22	10.79	44.80	1.57	20.23	8.78	1.28	73544.77
7	9.44	10.99	49.09	1.97	18.34	9.30	1.35	74930.91
8	13.79	11.62	48.33	3.46	19.29	9.22	1.34	75270.39
9	4.96	11.94	50.14	2.91	19.60	9.17	1.32	72663.40
10	12.43	12.37	47.65	3.39	19.67	8.97	1.34	74071.94
11	7.16	11.77	48.29	2.97	19.65	8.83	1.35	74561.01
12	9.01	11.63	50.33	3.11	19.03	8.86	1.31	74121.35
13	9.56	10.98	58.74	3.25	19.02	9.14	1.31	72919.62
14	8.30	10.71	51.78	3.10	20.72	8.64	1.31	76149.36
15	7.94	10.88	50.35	3.26	19.18	9.05	1.31	73596.45
16	7.71	11.02	56.05	3.21	19.59	9.41	1.34	70513.23
17	9.60	11.13	55.71	3.25	19.37	9.55	1.36	69180.73
18	6.86	11.93	45.67	3.09	18.86	9.05	1.36	73932.32
19	8.16	11.27	52.75	3.23	19.46	9.30	1.33	71044.26
20	14.46	10.91	60.05	3.77	18.92	9.37	1.30	70920.60
21	5.09	11.20	55.39	2.98	18.06	9.80	1.32	70988.20
22	5.74	11.54	57.44	3.00	18.74	10.00	1.34	63558.36
23	11.37	7.61	37.15	2.21	21.69	7.60	1.31	80368.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.77	11.11	50.40	2.59	19.71	9.06	1.32	73267.18
最大值	14.46	12.37	60.05	3.77	21.69	10.00	1.37	80368.05
發生時間	20	10	20	20	23	22		23
最小值	3.10	7.61	37.15	1.25	18.06	7.60	1.27	63558.36
發生時間	0	23	23	0	21	23		22
零點偏移(率)	-0.12 %	-0.00 %	-0.01 %	-0.00 %		-0.02	-0.01	-0.10 %
全幅偏移(率)	-2.58 %	-0.25 %	0.38 %	0.01 %		0.28	0.04	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								