

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.17	3.21	56.49	3.15	15.25	12.63	1.40	69371.91
1	11.94	5.91	51.72	2.27	16.66	11.77	1.41	74800.21
2	11.93	11.67	43.31	2.49	16.13	11.66	1.42	76103.39
3	12.39	13.03	40.30	2.80	15.46	11.75	1.42	75844.63
4	10.56	8.13	57.20	2.21	16.87	11.76	1.43	75111.00
5	9.62	7.76	57.92	2.01	16.07	12.19	1.47	73286.23
6	10.15	11.33	48.94	1.73	16.39	12.05	1.46	73026.01
7	10.66	6.00	48.10	1.58	16.93	11.91	1.46	73352.46
8	8.81	5.18	47.12	1.81	16.25	12.10	1.46	72054.57
9	11.75	1.86	51.55	1.64	16.87	11.77	1.46	74999.70
10	9.52	3.67	44.62	1.53	16.77	11.49	1.44	76481.41
11	7.58	4.16	51.34	1.84	15.77	12.26	1.51	71231.55
12	1.22	6.08	54.52	2.17	15.83	13.59	1.62	61466.63
13	0.46	2.99	47.01	1.86	16.50	13.30	1.61	62945.39
14	0.08	6.37	55.99	1.97	16.54	13.59	1.80	60908.26
15	0.12	3.55	45.43	1.47	17.53	12.04	1.52	72620.11
16	6.14	0.35	42.25	1.30	18.58	11.06	1.43	79430.29
17	9.83	3.67	52.50	1.43	18.77	11.61	1.44	74381.02
18	8.39	1.15	55.38	0.76	20.76	11.03	1.46	77189.36
19	10.17	2.43	45.79	1.10	19.31	11.34	1.46	76264.15
20	9.02	2.64	45.61	0.94	20.13	11.00	1.46	77972.77
21	9.97	2.65	43.29	1.02	19.68	10.91	1.43	78456.54
22	4.65	2.37	61.75	0.91	20.16	11.42	1.44	74306.53
23	0.83	1.57	67.90	0.77	20.65	11.25	1.48	74583.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.71	4.91	50.67	1.70	17.49	11.90	1.48	73174.49
最大值	12.39	13.03	67.90	3.15	20.76	13.59	2.00	79430.29
發生時間	3	3	23	0	18	12		16
最小值	0.08	0.35	40.30	0.76	15.25	10.91	1.39	60908.26
發生時間	14	16	3	18	0	21		14
零點偏移(率)	-0.01 %	-0.01 %	-0.27 %	0.00 %		0.04	0.00	0.00 %
全幅偏移(率)	-2.10 %	-0.24 %	0.69 %	-0.35 %		0.60	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.84	4.18	53.62	2.15	12.96	11.04	1.38	64021.35
1	10.69	5.50	51.84	1.98	14.39	10.87	1.38	63809.09
2	10.61	8.44	55.83	1.97	14.24	10.35	1.37	63626.75
3	11.97	3.35	58.06	2.20	13.91	10.33	1.38	63395.54
4	11.07	3.83	50.83	2.21	14.12	10.40	1.38	62504.03
5	11.04	4.83	46.23	2.17	14.25	10.41	1.38	63258.53
6	11.59	3.38	39.74	2.24	13.41	10.43	1.34	67190.05
7	10.72	10.23	43.56	2.01	15.11	10.25	1.34	62315.07
8	10.02	2.71	38.59	2.14	14.06	10.47	1.34	61875.07
9	9.37	5.44	48.96	2.13	13.63	10.73	1.36	60815.51
10	10.29	1.26	41.32	2.22	13.51	10.86	1.38	58100.05
11	7.53	2.97	50.21	2.07	13.69	11.19	1.39	55357.98
12	8.22	2.78	60.95	1.76	14.93	10.82	1.38	65052.57
13	3.53	2.86	69.97	2.27	14.27	12.67	1.45	55004.40
14	1.01	3.75	41.44	1.77	16.13	11.46	1.41	62235.65
15	8.59	2.11	53.17	1.89	15.48	10.74	1.34	65956.61
16	5.28	5.12	55.71	1.53	16.47	10.68	1.35	65786.49
17	5.57	0.88	55.50	1.38	17.09	10.66	1.35	66794.88
18	3.91	0.98	52.28	1.26	17.79	10.79	1.35	64682.63
19	5.64	3.41	46.95	1.57	16.42	10.63	1.35	66409.98
20	9.17	2.42	47.51	1.95	16.02	10.75	1.35	65983.98
21	8.39	8.51	43.79	1.86	15.87	10.76	1.34	63195.35
22	2.63	1.18	48.25	1.31	17.84	10.48	1.35	62984.34
23	0.10	1.11	60.71	0.97	18.65	10.54	1.38	66290.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.82	3.80	50.63	1.88	15.18	10.76	1.37	63193.60
最大值	11.97	10.23	69.97	2.27	18.65	12.67	1.57	67190.05
發生時間	3	7	13	13	23	13		6
最小值	0.10	0.88	38.59	0.97	12.96	10.25	1.33	55004.40
發生時間	23	17	8	23	0	7		13
零點偏移(率)	-0.53 %	-0.09 %	-0.24 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.81 %	-0.10 %	0.73 %	-0.35 %		0.33	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.03	4.30	57.28	2.40	13.09	11.39	1.72	84854.11
1	9.21	2.54	64.02	1.61	15.17	11.23	1.72	86316.16
2	10.92	2.86	56.93	2.63	12.31	11.15	1.71	86168.15
3	12.92	3.09	56.51	3.00	12.06	11.49	1.70	86474.88
4	11.97	3.92	58.88	2.81	12.62	11.69	1.69	86049.55
5	11.86	3.74	59.80	2.48	13.00	11.72	1.71	86949.05
6	10.32	2.57	63.14	2.19	13.37	11.43	1.70	82927.74
7	9.80	10.13	71.31	2.15	13.18	10.82	1.74	91816.32
8	9.88	4.17	63.84	2.26	12.54	11.10	1.75	83316.45
9	12.76	2.16	63.08	2.31	12.36	11.20	1.80	85287.49
10	10.31	1.57	53.32	2.10	12.56	11.39	1.81	83100.57
11	7.64	1.56	52.87	1.85	12.85	11.53	1.77	81357.56
12	8.18	2.12	60.75	1.34	14.31	11.41	1.82	84579.29
13	3.99	1.46	67.47	1.01	14.96	11.70	1.86	82864.77
14	3.19	1.12	56.68	0.57	15.97	11.02	1.83	87671.35
15	3.97	1.45	61.19	1.30	14.20	11.59	1.80	85061.54
16	6.37	1.02	62.13	0.76	15.76	11.21	1.80	86171.78
17	3.19	1.13	67.15	0.62	16.39	11.39	1.81	84529.81
18	3.63	1.32	56.83	0.37	17.47	10.71	1.82	89342.63
19	4.93	2.92	58.44	0.84	15.45	11.24	1.83	86026.58
20	8.40	8.71	55.87	1.61	13.99	11.41	1.81	85520.38
21	5.35	2.13	57.65	0.87	15.76	11.19	1.80	86503.15
22	1.06	2.06	62.20	0.66	16.04	11.44	1.80	84037.23
23	0.34	3.90	59.82	0.48	16.90	11.01	1.81	87105.79
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.55	3.00	60.30	1.59	14.26	11.31	1.77	85584.68
最大值	12.92	10.13	71.31	3.00	17.47	11.72	1.90	91816.32
發生時間	3	7	7	3	18	5		7
最小值	0.34	1.02	52.87	0.37	12.06	10.71	1.67	81357.56
發生時間	23	16	11	18	3	18		11
零點偏移(率)	-0.05 %	0.00 %	-0.18 %	-0.01 %		0.00	0.00	0.00 %
全幅偏移(率)	2.58 %	0.32 %	0.87 %	-0.21 %		0.44	0.02	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								