

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.90	5.05	48.48	3.03	16.37	11.89	1.46	72071.32
1	10.69	1.66	47.09	3.04	16.26	11.93	1.46	72083.11
2	9.47	1.77	47.66	2.94	16.22	12.02	1.46	70738.79
3	13.74	2.11	47.88	3.72	15.09	12.10	1.46	71648.44
4	11.25	2.82	51.83	3.79	14.53	12.29	1.46	70538.02
5	12.42	5.37	67.17	3.68	15.43	12.54	1.46	73195.50
6	11.08	3.89	54.94	3.14	16.27	11.82	1.46	73322.67
7	8.96	4.23	66.24	2.49	17.23	12.13	1.46	69762.07
8	9.89	3.83	46.72	2.71	16.09	12.02	1.46	71677.11
9	10.22	3.79	54.42	2.92	16.24	11.92	1.46	71816.23
10	10.21	3.16	54.15	2.25	16.63	9.70	1.51	89549.33
11	8.89	4.95	35.75	2.41	16.26	9.95	1.50	88920.55
12	10.27	5.52	36.82	2.95	15.07	9.98	1.49	88586.75
13	4.81	2.82	45.41	2.15	15.73	10.04	1.52	87131.64
14	6.56	2.70	43.34	2.05	16.09	9.84	1.51	88411.69
15	7.47	3.82	42.35	2.44	15.03	10.36	1.52	86147.97
16	0.43	4.58	63.16	2.48	16.07	12.13	1.56	71014.23
17	0.71	6.43	53.80	2.70	15.66	12.65	1.48	67019.77
18	2.34	6.16	48.50	2.55	15.75	12.00	1.47	71778.96
19	2.99	3.71	59.43	2.54	15.77	12.03	1.46	70910.02
20	4.70	5.21	50.01	3.07	14.87	12.27	1.46	70245.48
21	4.41	3.39	59.07	2.08	17.26	11.81	1.46	72102.77
22	5.77	3.58	61.61	2.32	16.47	12.09	1.43	70550.63
23	6.51	3.39	57.10	2.10	17.37	11.78	1.43	72658.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.65	3.91	51.79	2.73	15.99	11.55	1.47	75495.08
最大值	13.74	6.43	67.17	3.79	17.37	12.65	1.64	89549.33
發生時間	3	17	5	4	23	17		10
最小值	0.43	1.66	35.75	2.05	14.53	9.70	1.43	67019.77
發生時間	16	1	11	14	4	10		17
零點偏移(率)	-0.01 %	-0.01 %	-0.04 %	-0.01 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.78 %	0.31 %	-0.48 %	0.24 %		0.13	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.84	4.79	45.90	2.96	18.78	9.83	1.46	85866.52
1	12.13	2.78	48.72	2.60	18.35	10.05	1.46	83793.30
2	10.39	4.83	47.95	2.82	17.26	10.23	1.47	80312.46
3	9.81	2.66	50.15	3.17	15.81	10.51	1.50	79786.55
4	9.41	2.06	49.73	2.58	18.37	9.92	1.50	83328.18
5	8.60	3.56	51.07	2.22	19.01	10.24	1.50	82161.17
6	9.05	6.04	60.10	2.01	20.43	9.57	1.49	84362.68
7	9.95	4.18	50.34	2.34	20.10	9.53	1.49	86947.53
8	10.12	7.96	46.89	2.73	17.88	10.12	1.49	84251.24
9	8.63	7.19	56.20	3.44	15.49	10.12	1.50	79509.13
10	8.61	3.88	40.93	2.61	16.53	10.12	1.46	79281.60
11	7.63	4.38	39.09	2.68	15.88	10.18	1.45	78568.23
12	7.17	3.69	42.73	2.28	16.33	10.11	1.46	78845.36
13	8.45	10.50	56.86	3.25	13.80	10.48	1.46	77390.09
14	7.69	6.93	49.96	2.40	15.16	10.29	1.45	80387.35
15	10.53	4.17	51.98	2.78	15.00	10.17	1.48	80691.39
16	11.06	4.96	49.16	2.56	16.53	9.83	1.49	83964.09
17	9.94	1.27	58.35	2.89	14.58	10.58	1.50	82949.43
18	7.24	1.31	58.94	2.05	17.22	10.39	1.50	82121.08
19	7.10	4.62	44.38	1.56	19.08	9.91	1.50	85702.61
20	8.29	2.24	35.31	2.02	17.40	10.33	1.49	81317.87
21	9.89	1.56	44.47	2.21	17.23	10.33	1.46	81178.69
22	8.46	1.22	55.07	1.53	18.47	10.33	1.46	83613.50
23	4.22	2.20	56.99	0.97	19.53	10.52	1.46	81793.16
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.97	4.12	49.64	2.44	17.26	10.15	1.48	82005.13
最大值	12.13	10.50	60.10	3.44	20.43	10.58	1.51	86947.53
發生時間	1	13	6	9	6	17		7
最小值	4.22	1.22	35.31	0.97	13.80	9.53	1.44	77390.09
發生時間	23	22	20	23	13	7		13
零點偏移(率)	0.00 %	-0.01 %	0.00 %	0.00 %		-0.08	0.00	0.00 %
全幅偏移(率)	1.60 %	0.43 %	-0.40 %	0.37 %		-0.08	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.78	5.14	55.53	2.22	18.53	9.99	1.43	87832.86
1	10.18	5.52	44.00	2.23	16.17	10.46	1.42	83751.28
2	11.15	3.03	55.62	2.28	18.94	10.13	1.43	86464.30
3	11.66	5.33	52.51	2.67	17.08	10.23	1.41	85963.50
4	8.75	1.71	67.30	2.19	18.02	10.12	1.42	85954.10
5	9.63	9.85	59.97	2.04	18.55	9.94	1.41	89014.07
6	12.04	7.57	47.56	2.87	19.76	9.05	1.43	94444.02
7	4.15	10.14	60.90	2.27	15.26	11.11	1.39	91282.66
8	4.05	5.75	55.35	1.62	19.16	9.96	1.38	80905.02
9	5.29	4.39	51.40	2.21	19.05	9.14	1.38	84186.74
10	9.50	3.85	52.11	3.11	16.79	9.77	1.40	82592.07
11	10.17	3.59	52.09	2.68	15.62	10.24	1.39	80857.91
12	9.92	5.19	44.06	2.54	15.00	10.37	1.38	76074.99
13	11.21	3.54	49.74	2.38	15.70	10.93	1.38	78110.29
14	10.56	2.64	54.61	2.18	15.34	10.96	1.40	79859.30
15	7.08	3.25	62.45	2.57	14.18	11.73	1.38	74080.09
16	4.63	2.09	58.10	2.11	15.34	11.20	1.38	79857.11
17	7.03	2.34	59.60	2.20	15.71	10.82	1.40	84385.05
18	8.17	4.04	54.62	2.75	14.02	11.35	1.38	81072.67
19	3.65	2.17	71.20	1.93	15.93	11.58	1.39	78444.20
20	3.61	2.32	52.34	1.59	16.22	10.85	1.39	84464.67
21	8.27	2.30	53.24	1.83	16.10	10.87	1.39	85125.20
22	7.97	2.00	57.81	1.65	16.96	10.83	1.41	84329.22
23	4.93	5.37	62.48	1.53	17.75	11.12	1.42	84512.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.06	4.30	55.61	2.24	16.72	10.53	1.40	83481.82
最大值	12.04	10.14	71.20	3.11	19.76	11.73	1.44	94444.02
發生時間	6	7	19	10	6	15		6
最小值	3.61	1.71	44.00	1.53	14.02	9.05	1.38	74080.09
發生時間	20	4	1	23	18	6		15
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.25 %	0.03 %	-0.56 %	0.01 %		0.01	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								