

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.63	13.09	59.12	1.13	16.98	11.29	1.05	81878.83
1	10.38	14.22	51.20	2.29	17.12	11.62	1.04	79492.24
2	11.19	13.55	44.36	2.19	16.56	11.97	1.04	77005.03
3	10.79	12.66	37.59	3.08	15.66	11.51	1.05	82521.90
4	9.08	13.12	52.33	2.98	14.75	12.46	1.04	74724.43
5	9.90	12.01	47.03	3.70	14.56	11.43	1.06	80038.29
6	10.52	12.09	42.28	3.24	14.20	11.74	1.06	81218.14
7	10.09	12.19	45.48	2.76	15.76	11.60	1.04	81124.79
8	9.76	12.41	54.14	3.77	14.05	11.99	1.06	79460.80
9	11.50	12.53	58.33	1.99	15.95	12.07	1.08	76612.36
10	10.02	11.40	44.70	1.99	16.94	11.00	1.08	84858.05
11	12.83	12.13	45.78	2.25	15.69	11.68	1.05	80147.72
12	11.16	11.79	59.18	1.87	16.49	11.44	1.04	81559.02
13	9.53	11.42	52.77	4.33	15.40	11.32	1.05	83174.13
14	10.79	13.04	53.08	3.84	16.08	11.36	1.06	82432.89
15	9.92	13.45	55.52	3.21	15.22	11.59	1.09	81294.25
16	12.09	12.54	52.99	3.10	14.14	11.69	1.09	80567.86
17	9.53	11.94	46.60	2.81	14.97	11.69	1.09	80497.90
18	9.36	11.86	44.47	2.57	15.73	11.62	1.09	80372.23
19	9.79	12.01	61.66	2.33	16.27	11.69	1.09	79299.49
20	9.08	11.87	48.56	3.03	14.69	11.69	1.08	80563.22
21	9.50	12.12	36.30	2.36	16.29	11.62	1.07	80064.70
22	9.51	12.92	51.38	1.86	16.50	11.51	1.07	80740.24
23	11.11	12.41	46.83	2.09	15.82	11.32	1.06	82231.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.34	12.45	49.65	2.70	15.66	11.62	1.06	80495.01
最大值	12.83	14.22	61.66	4.33	17.12	12.46	1.09	84858.05
發生時間	11	1	19	13	1	4		10
最小值	9.08	11.40	36.30	1.13	14.05	11.00	1.03	74724.43
發生時間	4	10	21	0	8	10		4
零點偏移(率)	-0.07 %	-0.01 %	-0.01 %	-0.01 %		-0.16	-0.01	0.40 %
全幅偏移(率)	1.62 %	2.56 %	0.45 %	0.49 %		-0.01	0.04	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.81	12.33	48.58	1.71	16.66	11.00	0.99	76963.86
1	12.60	12.69	53.57	2.42	16.74	11.20	0.99	76074.49
2	8.83	13.16	47.33	2.37	14.27	11.05	1.00	74298.94
3	9.98	13.04	46.94	2.33	14.62	10.85	1.01	74600.31
4	10.90	11.99	47.05	2.10	16.18	10.73	1.02	77425.30
5	9.82	12.16	50.67	2.53	17.11	10.58	1.02	78792.94
6	7.24	12.23	49.67	2.75	15.47	11.04	1.02	74780.20
7	9.11	12.72	50.22	1.93	15.45	11.10	1.02	71803.12
8	10.42	12.15	47.32	1.95	16.53	10.58	1.02	75196.21
9	14.74	12.17	58.32	2.39	16.50	10.88	1.03	81325.12
10	7.99	11.98	30.87	2.44	15.74	10.94	1.02	76119.25
11	11.45	11.74	55.69	2.14	15.95	10.72	1.01	77461.65
12	10.41	11.56	55.65	2.48	16.23	10.40	1.02	80122.95
13	13.51	11.85	58.54	2.40	15.73	10.81	1.02	79448.99
14	13.50	12.34	65.66	2.68	15.67	11.25	1.03	80837.57
15	9.35	12.45	59.52	3.67	14.69	11.50	1.05	78940.58
16	15.36	12.36	36.80	3.11	14.48	11.33	1.04	75492.49
17	10.04	11.78	37.07	2.04	16.09	10.75	1.04	79197.12
18	8.61	11.88	34.63	2.03	16.47	10.76	1.04	78320.64
19	8.70	11.50	52.04	2.70	17.61	10.32	1.04	81060.08
20	9.55	11.73	44.85	2.76	16.23	10.66	1.02	77409.70
21	4.50	11.42	41.54	0.94	16.60	10.37	1.02	79310.45
22	10.04	11.35	55.10	1.77	16.69	10.24	1.02	78117.08
23	6.86	11.46	50.74	1.53	16.77	10.22	1.02	77755.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.14	12.09	49.10	2.30	16.02	10.80	1.02	77535.61
最大值	15.36	13.16	65.66	3.67	17.61	11.50	1.06	81325.12
發生時間	16	2	14	15	19	15		9
最小值	4.50	11.35	30.87	0.94	14.27	10.22	0.98	71803.12
發生時間	21	22	10	21	2	23		7
零點偏移(率)	-0.10 %	-0.04 %	-0.05 %	-0.01 %		-0.06	-0.01	0.00 %
全幅偏移(率)	-0.96 %	0.41 %	0.42 %	-0.35 %		-0.04	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.85	11.46	51.97	1.66	16.83	10.08	1.40	74404.85
1	9.13	11.65	50.68	1.90	17.75	10.06	1.41	75121.46
2	9.77	11.95	48.74	2.20	14.98	10.40	1.40	72246.30
3	9.30	11.97	53.27	2.53	14.58	10.42	1.39	74112.90
4	9.70	12.32	55.32	2.89	14.24	10.68	1.41	72268.75
5	9.13	11.70	58.10	1.97	16.93	10.27	1.40	76584.70
6	8.67	12.40	49.36	2.62	15.02	10.35	1.39	74148.02
7	8.60	11.56	47.07	1.95	15.38	10.15	1.40	71614.90
8	13.58	11.43	50.56	2.72	15.67	10.23	1.42	74044.64
9	10.47	11.42	50.79	2.32	15.39	10.35	1.43	72800.70
10	13.31	11.50	51.22	2.44	15.76	10.35	1.43	73499.77
11	10.63	11.28	54.81	2.42	15.07	10.26	1.43	75711.45
12	10.35	12.02	54.67	2.80	14.31	10.41	1.43	74368.12
13	13.22	11.55	47.73	2.54	15.35	10.19	1.43	75854.98
14	11.89	12.94	36.10	2.52	17.59	8.71	1.42	74209.40
15	9.70	11.36	47.82	2.28	17.04	8.81	1.41	73877.51
16	9.63	12.10	51.89	2.06	16.08	9.16	1.41	72608.92
17	9.75	12.37	58.30	2.04	17.23	9.15	1.41	72046.30
18	9.06	11.65	51.35	2.09	18.62	8.88	1.41	73588.10
19	10.29	12.48	52.40	1.87	18.26	9.18	1.42	74925.60
20	10.08	11.98	55.88	1.62	16.15	9.81	1.43	74936.97
21	9.05	12.09	60.89	1.83	15.64	9.95	1.42	74998.51
22	9.76	11.98	48.49	1.87	15.78	9.90	1.43	74302.36
23	10.24	11.38	42.86	2.05	15.68	9.80	1.43	74393.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.17	11.86	51.26	2.22	16.06	9.90	1.41	74027.87
最大值	13.58	12.94	60.89	2.89	18.62	10.68	1.43	76584.70
發生時間	8	14	21	4	18	4		5
最小值	8.60	11.28	36.10	1.62	14.24	8.71	1.36	71614.90
發生時間	7	11	14	20	4	14		7
零點偏移(率)	-0.11 %	0.01 %	-0.03 %	-0.02 %		-0.07	-0.01	0.10 %
全幅偏移(率)	-1.01 %	-0.25 %	0.33 %	-0.11 %		0.22	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								