

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.75	1.51	64.73	3.20	19.21	11.49	1.43	74574.15
1	9.07	2.92	46.82	3.15	19.56	11.52	1.43	74368.92
2	8.33	3.04	54.50	2.86	20.10	11.15	1.43	76419.42
3	9.27	1.92	55.13	2.88	19.55	11.10	1.43	77407.83
4	9.65	2.61	51.67	3.41	18.11	11.65	1.43	74264.20
5	8.45	3.75	60.17	3.07	20.10	11.29	1.44	74400.88
6	8.98	3.06	55.39	3.17	19.29	11.37	1.45	75128.39
7	10.50	1.85	49.25	3.37	18.56	11.63	1.44	73663.83
8	11.12	3.51	50.57	3.40	18.51	11.74	1.42	73123.58
9	10.98	2.55	46.74	3.37	18.10	11.71	1.45	74275.76
10	8.42	2.47	51.06	3.25	18.46	11.74	1.46	73646.48
11	8.86	5.68	49.55	3.43	17.46	11.95	1.46	72806.30
12	6.79	5.80	61.76	3.60	17.50	12.65	1.44	67514.97
13	4.20	2.89	57.86	3.31	18.45	11.83	1.43	73420.93
14	9.77	2.46	45.36	3.35	18.68	11.38	1.41	75833.78
15	9.22	3.64	46.87	3.39	17.63	11.67	1.41	74568.12
16	9.43	3.69	48.01	3.54	17.23	12.04	1.41	72304.50
17	10.89	1.02	54.46	3.39	18.03	11.84	1.40	73165.40
18	10.24	1.24	55.59	3.37	18.37	11.82	1.41	73055.93
19	9.02	6.34	47.63	3.30	17.92	11.80	1.41	72400.39
20	9.29	2.81	61.31	3.11	19.69	11.53	1.41	73770.49
21	6.97	2.42	59.62	3.11	19.59	11.66	1.41	73087.43
22	3.48	2.42	56.27	3.05	19.65	11.47	1.41	74640.95
23	3.48	6.80	65.22	3.35	18.40	12.35	1.41	68420.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.46	3.18	53.98	3.27	18.67	11.68	1.43	73594.29
最大值	11.12	6.80	65.22	3.60	20.10	12.65	1.51	77407.83
發生時間	8	23	23	12	2	12		3
最小值	3.48	1.02	45.36	2.86	17.23	11.10	1.40	67514.97
發生時間	22	17	14	2	16	3		12
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	-0.37 %	0.21 %	-0.43 %	0.23 %		0.17	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.83	2.57	65.32	2.01	17.63	10.16	1.33	66991.12
1	10.22	1.69	50.59	2.30	17.14	10.75	1.32	64411.20
2	10.06	1.50	50.62	2.57	16.43	10.63	1.31	64547.53
3	10.27	1.05	56.02	2.23	17.37	10.37	1.31	66835.03
4	9.93	1.72	50.57	2.53	15.81	10.78	1.31	64130.53
5	9.83	3.33	59.70	2.47	16.27	10.64	1.31	65078.09
6	7.58	6.36	57.52	2.31	16.65	10.56	1.33	62276.50
7	10.17	2.52	55.17	2.50	16.44	10.78	1.33	65326.21
8	9.09	1.73	59.41	2.60	15.29	10.91	1.33	63327.82
9	10.05	0.91	60.70	2.35	16.06	10.81	1.33	64639.40
10	8.67	6.37	55.99	2.60	14.77	10.76	1.32	63808.29
11	9.13	7.53	55.04	2.71	14.86	10.66	1.28	61838.61
12	11.34	2.40	57.02	4.37	15.00	10.56	1.26	63252.56
13	8.82	6.42	53.17	3.67	14.22	10.70	1.26	62824.09
14	4.55	8.43	60.28	4.83	14.85	11.03	1.29	64761.21
15	7.83	10.98	66.25	3.08	14.73	10.74	1.30	63502.19
16	10.41	3.74	57.46	3.10	13.82	11.25	1.28	61730.39
17	10.15	2.77	57.18	2.91	14.20	11.24	1.26	62093.41
18	10.11	1.05	56.84	2.68	15.50	10.79	1.26	62260.69
19	10.37	2.45	59.03	2.61	16.85	10.55	1.27	62385.93
20	10.56	10.81	50.64	3.08	14.86	10.76	1.28	63535.40
21	11.11	2.44	66.44	2.87	15.67	10.80	1.28	64988.02
22	9.96	2.29	53.12	2.29	16.28	10.76	1.29	64846.02
23	9.60	5.72	60.45	2.50	15.77	10.67	1.29	62244.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.53	4.03	57.27	2.80	15.69	10.74	1.30	63818.10
最大值	11.34	10.98	66.44	4.83	17.63	11.25	1.33	66991.12
發生時間	12	15	21	14	0	16		0
最小值	4.55	0.91	50.57	2.01	13.82	10.16	1.25	61730.39
發生時間	14	9	4	0	16	0		16
零點偏移(率)	0.00 %	-0.02 %	0.00 %	0.00 %		-0.08	0.00	0.00 %
全幅偏移(率)	0.22 %	0.50 %	-0.37 %	0.15 %		-0.09	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.45	2.83	58.43	2.74	16.20	10.68	1.67	85235.75
1	7.27	1.80	62.54	2.33	16.13	10.72	1.67	83897.12
2	7.62	2.46	64.13	2.78	15.23	11.04	1.67	80993.42
3	8.29	5.16	54.93	4.44	15.82	10.37	1.68	84666.95
4	8.13	8.29	50.63	3.41	14.30	10.65	1.67	79583.17
5	7.30	1.66	53.88	3.13	13.92	10.76	1.67	77642.79
6	7.87	4.84	53.61	3.17	13.80	10.59	1.67	75572.15
7	2.84	1.81	62.90	2.64	13.46	11.08	1.69	79111.13
8	8.79	1.31	61.68	2.74	15.00	10.92	1.70	82741.98
9	8.20	1.47	57.44	2.46	15.18	11.10	1.71	84927.06
10	9.38	2.16	62.15	2.67	14.97	11.03	1.72	83836.16
11	9.99	7.05	60.68	3.04	13.96	11.19	1.72	81484.71
12	8.70	13.16	54.35	3.39	13.53	10.98	1.72	81612.44
13	10.40	2.40	55.10	4.03	14.02	10.92	1.72	81286.86
14	6.83	3.08	58.49	2.89	14.25	11.04	1.72	81445.66
15	11.23	8.41	56.90	3.23	13.81	11.21	1.72	81604.03
16	7.79	2.03	59.92	2.62	14.44	11.16	1.72	81951.38
17	8.62	2.21	58.22	2.83	14.28	11.14	1.72	81148.79
18	11.86	3.18	59.97	2.76	14.55	10.94	1.72	81167.29
19	8.25	1.30	53.63	2.24	16.06	10.63	1.72	81828.99
20	6.14	5.51	50.80	2.37	14.62	10.69	1.72	81757.13
21	6.92	1.66	57.28	2.41	15.29	10.72	1.72	81225.46
22	8.67	3.87	53.45	2.41	15.91	10.51	1.72	83028.08
23	13.72	12.06	53.35	4.35	14.07	10.77	1.72	80431.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.51	4.15	57.27	2.96	14.70	10.87	1.70	81590.82
最大值	13.72	13.16	64.13	4.44	16.20	11.21	1.73	85235.75
發生時間	23	12	2	3	0	15		0
最小值	2.84	1.30	50.63	2.24	13.46	10.37	1.66	75572.15
發生時間	7	19	4	19	7	3		6
零點偏移(率)	-0.01 %	0.00 %	-0.03 %	-0.01 %		0.01	0.00	0.00 %
全幅偏移(率)	0.35 %	0.14 %	-0.25 %	0.01 %		0.27	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								