

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月22日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.63	8.87	52.84	1.76	15.68	11.76	1.29	70985.18
1	9.43	8.80	60.27	1.77	17.37	11.52	1.29	71974.72
2	8.46	8.78	56.60	2.25	16.06	11.71	1.29	71037.08
3	6.62	8.89	51.16	3.17	13.22	12.11	1.29	69425.33
4	7.26	9.05	63.53	3.00	13.69	12.19	1.29	69043.04
5	10.80	11.34	55.83	3.94	14.11	12.14	1.27	67580.53
6	8.69	11.45	52.83	2.97	14.00	12.08	1.27	69125.71
7	8.29	11.42	55.69	2.92	14.00	12.11	1.27	68756.71
8	7.01	8.55	56.50	2.82	13.63	12.14	1.27	68944.05
9	7.98	6.16	63.35	2.67	14.57	12.07	1.27	68919.98
10	6.57	6.07	56.83	2.90	14.51	11.81	1.26	70691.27
11	1.51	6.22	59.87	2.70	13.31	12.28	1.26	68368.47
12	4.95	6.98	54.90	3.22	12.86	12.31	1.25	68432.71
13	1.45	6.81	65.37	2.54	14.02	12.53	1.25	65844.17
14	4.46	6.02	65.28	2.08	16.33	11.36	1.25	73223.98
15	5.43	6.27	59.26	3.25	13.80	12.12	1.25	68874.14
16	8.54	8.18	58.56	3.02	15.23	11.75	1.25	70692.85
17	8.99	8.32	57.79	2.49	15.61	11.63	1.26	71675.84
18	10.97	10.10	57.14	3.21	14.52	11.69	1.25	72959.05
19	8.18	6.63	57.17	3.13	13.98	11.91	1.25	71153.13
20	8.68	6.79	55.95	3.09	13.93	11.94	1.24	70748.92
21	10.38	7.14	56.14	3.32	14.22	12.05	1.25	69035.95
22	7.54	7.55	64.75	2.91	14.59	12.04	1.25	69275.68
23	8.37	9.91	52.02	2.62	14.75	11.97	1.25	69742.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.47	8.18	57.90	2.82	14.50	11.97	1.26	69854.63
最 大 值	10.97	11.45	65.37	3.94	17.37	12.53	1.29	73223.98
發生時間	18	6	13	5	1	13		14
最 小 值	1.45	6.02	51.16	1.76	12.86	11.36	1.23	65844.17
發生時間	13	14	3	0	12	14		13
零點偏移(率)	-0.08 %	-0.02 %	-0.03 %	0.00 %		0.01		0.10 %
全幅偏移(率)	0.00 %	0.00 %	-0.01 %	0.00 %		0.37		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月22日

報表日期: 114年08月22日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.68	8.85	60.04	1.59	16.08	11.58	0.99	76756.09
1	1.34	8.35	59.28	1.43	18.65	10.98	0.98	80558.98
2	1.44	8.97	55.81	2.10	16.56	10.89	0.98	76412.69
3	1.75	8.21	57.89	2.82	15.58	10.87	0.98	77355.73
4	1.67	7.13	56.95	2.06	15.90	10.72	0.98	79665.51
5	0.09	7.28	67.16	1.97	16.57	10.84	0.99	81363.04
6	3.67	9.75	64.37	2.28	15.86	10.90	0.97	81174.81
7	3.66	10.48	46.34	2.02	16.00	11.19	0.95	77899.41
8	3.38	9.06	43.22	2.62	15.74	11.19	0.98	76655.98
9	3.11	6.76	41.45	3.27	15.50	11.13	0.97	77135.39
10	3.01	5.89	44.38	3.14	15.91	11.13	0.97	77503.47
11	2.79	7.90	51.39	3.26	16.03	10.96	0.97	79405.89
12	2.66	7.75	47.98	2.40	15.63	11.02	0.95	75833.13
13	2.46	5.63	47.51	1.40	15.37	11.08	0.94	73675.73
14	2.17	5.16	40.87	1.24	15.80	10.64	0.94	76930.17
15	2.49	7.65	46.39	1.77	14.49	11.61	0.94	75601.92
16	2.43	8.70	45.04	1.55	15.00	10.74	0.94	78802.06
17	2.70	6.34	50.12	1.41	15.76	10.98	0.94	80250.37
18	3.08	7.25	50.39	2.31	15.19	10.87	0.94	80581.34
19	3.55	7.57	56.05	2.19	16.01	10.91	0.94	79865.93
20	3.86	6.41	58.78	2.67	15.63	11.08	0.94	82585.88
21	3.93	6.48	58.26	2.38	16.20	10.93	0.95	82685.93
22	3.75	6.63	61.16	1.19	17.65	10.84	0.94	79606.09
23	3.36	8.61	57.11	1.70	17.06	11.31	0.95	77288.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.67	7.62	52.83	2.12	16.01	11.02	0.96	78566.41
最 大 值	3.93	10.48	67.16	3.27	18.65	11.61	1.00	82685.93
發生時間	21	7	5	9	1	15		21
最 小 值	0.09	5.16	40.87	1.19	14.49	10.64	0.93	73675.73
發生時間	5	14	14	22	15	14		13
零點偏移(率)	-0.12 %	-0.01 %	-0.04 %	-0.00 %		-0.06		-0.10 %
全幅偏移(率)	0.14 %	-0.47 %	-0.39 %	0.35 %		0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月22日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.49	8.76	57.39	2.42	15.40	11.17	1.48	67200.89
1	0.34	9.37	54.46	2.37	20.83	9.09	1.46	80409.37
2	6.86	7.84	49.99	2.58	16.86	9.25	1.43	76921.41
3	8.56	10.68	63.71	2.78	16.62	9.30	1.43	75867.77
4	5.60	10.81	62.44	2.56	16.24	9.28	1.42	75020.12
5	7.04	11.30	59.80	2.72	17.77	8.91	1.43	75257.61
6	5.90	11.69	60.18	2.49	19.12	8.76	1.43	76310.47
7	0.01	13.48	57.20	3.05	14.15	9.78	1.43	71453.22
8	0.72	5.51	53.47	2.54	15.77	9.68	1.42	74253.55
9	3.17	6.51	58.34	2.80	15.58	9.93	1.43	74809.24
10	4.30	6.53	59.15	3.06	15.35	9.99	1.41	75220.80
11	5.64	6.57	60.13	3.06	15.65	10.01	1.44	75741.34
12	5.32	6.61	58.44	2.87	15.93	10.02	1.41	75313.08
13	6.40	6.90	60.64	3.54	14.61	10.19	1.40	73133.86
14	11.52	6.67	58.63	3.73	14.85	10.00	1.43	74934.48
15	6.25	6.66	57.78	3.17	15.12	10.20	1.43	73133.51
16	6.37	6.93	54.99	3.21	15.62	9.75	1.41	77153.04
17	9.28	6.87	62.38	2.88	17.85	9.33	1.39	80524.73
18	8.05	8.15	59.12	2.72	16.79	9.50	1.44	79952.13
19	10.93	12.19	57.13	3.83	15.03	9.67	1.40	78316.03
20	8.37	10.02	55.04	3.10	16.21	9.42	1.40	76125.13
21	9.00	10.68	55.63	3.13	16.38	9.28	1.43	77309.14
22	8.51	9.80	58.12	3.24	16.23	9.76	1.44	75040.56
23	7.25	7.74	60.74	2.77	16.85	10.17	1.42	74203.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.08	8.68	58.12	2.94	16.28	9.68	1.43	75566.85
最 大 值	11.52	13.48	63.71	3.83	20.83	11.17	1.48	80524.73
發生時間	14	7	3	19	1	0		17
最 小 值	0.01	5.51	49.99	2.37	14.15	8.76	1.38	67200.89
發生時間	7	8	2	1	7	6		0
零點偏移(率)	-0.12 %	-0.00 %	-0.04 %	-0.00 %		-0.02		-0.10 %
全幅偏移(率)	0.89 %	0.89 %	0.02 %	0.14 %		0.34		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								