

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月13日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.82 | 10.03 | 60.93 | 1.30 | 18.47 | 11.03 | 1.10 | 76387.82 |
| 1 | 9.29 | 10.30 | 57.55 | 1.38 | 19.37 | 10.92 | 1.10 | 77094.85 |
| 2 | 8.61 | 10.50 | 48.86 | 1.54 | 18.22 | 10.79 | 1.10 | 78045.42 |
| 3 | 8.32 | 10.74 | 67.20 | 0.97 | 18.04 | 11.43 | 1.10 | 74161.24 |
| 4 | 8.80 | 10.53 | 54.24 | 1.42 | 17.84 | 11.01 | 1.09 | 77430.57 |
| 5 | 6.22 | 9.99 | 56.80 | 1.36 | 16.92 | 11.16 | 1.10 | 77708.01 |
| 6 | 10.14 | 10.40 | 59.06 | 1.98 | 16.43 | 11.47 | 1.10 | 75021.10 |
| 7 | 8.91 | 11.70 | 57.25 | 2.22 | 16.22 | 11.47 | 1.10 | 74788.10 |
| 8 | 4.67 | 13.16 | 61.30 | 0.78 | 19.10 | 10.97 | 1.12 | 71844.15 |
| 9 | 3.58 | 6.75 | 57.06 | 1.00 | 20.31 | 9.80 | 1.11 | 77225.22 |
| 10 | 9.08 | 5.14 | 47.70 | 1.48 | 18.28 | 10.61 | 1.11 | 79217.05 |
| 11 | 9.38 | 5.54 | 48.42 | 1.93 | 17.54 | 10.97 | 1.10 | 76922.43 |
| 12 | 9.16 | 8.11 | 54.52 | 1.42 | 17.92 | 11.11 | 1.10 | 74150.41 |
| 13 | 9.32 | 7.54 | 52.34 | 1.11 | 17.70 | 10.95 | 1.11 | 75469.97 |
| 14 | 8.71 | 7.27 | 64.47 | 1.11 | 17.32 | 11.40 | 1.12 | 73220.79 |
| 15 | 9.72 | 7.34 | 62.33 | 1.47 | 17.84 | 11.24 | 1.10 | 75410.30 |
| 16 | 9.58 | 9.47 | 54.20 | 1.90 | 17.26 | 11.54 | 1.10 | 73480.68 |
| 17 | 8.73 | 6.32 | 61.18 | 1.51 | 18.08 | 11.29 | 1.12 | 74917.90 |
| 18 | 9.45 | 7.15 | 49.00 | 1.52 | 16.99 | 11.57 | 1.12 | 73952.38 |
| 19 | 10.90 | 8.16 | 52.91 | 1.73 | 17.41 | 11.21 | 1.12 | 76555.92 |
| 20 | 8.94 | 7.91 | 60.43 | 1.48 | 17.57 | 11.58 | 1.12 | 73388.71 |
| 21 | 7.60 | 6.78 | 56.74 | 0.60 | 19.02 | 11.02 | 1.14 | 76559.66 |
| 22 | 7.91 | 7.02 | 50.45 | 1.13 | 18.38 | 11.28 | 1.13 | 74961.01 |
| 23 | 7.29 | 7.20 | 51.06 | 1.33 | 17.94 | 11.72 | 1.14 | 71916.07 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 8.46 | 8.54 | 56.08 | 1.40 | 17.92 | 11.15 | 1.11 | 75409.57 |
| 最大值 | 10.90 | 13.16 | 67.20 | 2.22 | 20.31 | 11.72 | 1.27 | 79217.05 |
| 發生時間 | 19 | 8 | 3 | 7 | 9 | 23 | | 10 |
| 最小值 | 3.58 | 5.14 | 47.70 | 0.60 | 16.22 | 9.80 | 1.08 | 71844.15 |
| 發生時間 | 9 | 10 | 10 | 21 | 7 | 9 | | 8 |
| 零點偏移(率) | -0.12 % | 0.00 % | -0.01 % | -0.00 % | | 0.02 | | 0.00 % |
| 全幅偏移(率) | 0.02 % | -0.02 % | -0.14 % | -0.02 % | | 0.23 | | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月13日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 3.54 | 5.37 | 63.67 | 1.27 | 17.75 | 11.02 | 1.06 | 79484.80 |
| 1 | 1.67 | 5.72 | 48.00 | 1.83 | 19.06 | 10.21 | 1.06 | 85215.51 |
| 2 | 1.54 | 5.50 | 59.54 | 1.15 | 18.99 | 10.25 | 1.07 | 84508.99 |
| 3 | 2.97 | 7.86 | 47.09 | 1.97 | 17.20 | 10.29 | 1.07 | 86560.07 |
| 4 | 6.41 | 7.20 | 62.69 | 3.05 | 15.02 | 10.74 | 1.07 | 84561.63 |
| 5 | 9.27 | 6.38 | 58.87 | 3.84 | 14.71 | 10.54 | 1.07 | 86285.72 |
| 6 | 8.37 | 3.26 | 53.09 | 4.65 | 14.77 | 10.47 | 1.06 | 82802.73 |
| 7 | 7.08 | 3.32 | 60.57 | 2.16 | 16.88 | 10.74 | 1.05 | 82975.75 |
| 8 | 8.85 | 4.69 | 53.82 | 1.84 | 17.38 | 10.36 | 1.05 | 84866.84 |
| 9 | 8.24 | 4.17 | 51.82 | 1.37 | 18.62 | 9.82 | 1.04 | 88023.30 |
| 10 | 6.20 | 7.24 | 56.89 | 1.91 | 16.32 | 10.44 | 1.04 | 84609.76 |
| 11 | 7.78 | 4.20 | 57.78 | 1.18 | 18.53 | 9.94 | 1.06 | 87902.16 |
| 12 | 8.22 | 6.60 | 58.18 | 2.63 | 16.24 | 10.45 | 1.05 | 85082.79 |
| 13 | 9.33 | 7.01 | 57.17 | 2.55 | 15.88 | 10.59 | 1.06 | 85034.97 |
| 14 | 8.64 | 5.17 | 63.44 | 2.99 | 14.88 | 10.79 | 1.05 | 84536.67 |
| 15 | 6.70 | 5.52 | 61.37 | 3.07 | 14.50 | 10.84 | 1.05 | 83875.66 |
| 16 | 9.00 | 2.75 | 56.14 | 1.98 | 15.68 | 10.65 | 1.05 | 84881.82 |
| 17 | 8.02 | 1.92 | 57.48 | 1.62 | 16.72 | 10.35 | 1.05 | 86258.92 |
| 18 | 5.51 | 2.69 | 52.42 | 2.73 | 15.35 | 10.95 | 1.03 | 82296.04 |
| 19 | 6.54 | 3.33 | 55.81 | 1.83 | 17.04 | 10.90 | 1.03 | 80885.65 |
| 20 | 6.70 | 2.58 | 56.52 | 1.25 | 18.14 | 10.45 | 1.05 | 84488.84 |
| 21 | 9.82 | 3.13 | 43.87 | 1.95 | 17.29 | 9.97 | 1.05 | 87829.82 |
| 22 | 8.59 | 2.71 | 59.63 | 1.44 | 17.97 | 10.48 | 1.06 | 83746.11 |
| 23 | 8.58 | 2.55 | 45.96 | 1.45 | 18.06 | 10.26 | 1.06 | 85101.28 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 6.98 | 4.62 | 55.91 | 2.15 | 16.79 | 10.48 | 1.05 | 84658.99 |
| 最大值 | 9.82 | 7.86 | 63.67 | 4.65 | 19.06 | 11.02 | 1.08 | 88023.30 |
| 發生時間 | 21 | 3 | 0 | 6 | 1 | 0 | | 9 |
| 最小值 | 1.54 | 1.92 | 43.87 | 1.15 | 14.50 | 9.82 | 1.02 | 79484.80 |
| 發生時間 | 2 | 17 | 21 | 2 | 15 | 9 | | 0 |
| 零點偏移(率) | -0.01 % | -0.01 % | -0.05 % | -0.05 % | | 0.04 | | -0.20 % |
| 全幅偏移(率) | -0.02 % | 2.42 % | 0.12 % | 0.43 % | | -0.08 | | -0.10 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月13日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 4.29 | 6.03 | 49.59 | 1.17 | 15.44 | 11.02 | 0.97 | 80544.58 |
| 1 | 1.71 | 7.79 | 56.50 | 1.31 | 15.75 | 11.52 | 0.97 | 75948.56 |
| 2 | 2.12 | 4.80 | 52.22 | 1.14 | 15.99 | 10.88 | 0.97 | 77912.04 |
| 3 | 3.26 | 4.62 | 47.22 | 0.85 | 16.75 | 10.37 | 0.97 | 82247.11 |
| 4 | 5.07 | 4.55 | 51.84 | 1.23 | 15.64 | 10.77 | 0.98 | 80816.47 |
| 5 | 2.27 | 5.96 | 54.53 | 2.32 | 13.32 | 11.47 | 0.97 | 72736.16 |
| 6 | 5.86 | 4.36 | 45.94 | 1.34 | 16.61 | 10.14 | 0.97 | 77612.79 |
| 7 | 9.94 | 6.77 | 37.20 | 1.73 | 16.53 | 9.95 | 0.97 | 75798.29 |
| 8 | 8.99 | 5.24 | 53.55 | 1.36 | 15.93 | 10.88 | 0.97 | 79685.49 |
| 9 | 8.67 | 4.19 | 61.39 | 1.19 | 16.26 | 11.46 | 0.98 | 83207.33 |
| 10 | 9.33 | 7.11 | 55.07 | 0.80 | 17.47 | 11.16 | 0.99 | 85513.67 |
| 11 | 3.62 | 8.82 | 48.19 | 0.77 | 16.50 | 11.10 | 0.98 | 85312.28 |
| 12 | 1.02 | 10.84 | 50.61 | 1.42 | 14.72 | 11.60 | 0.97 | 80464.23 |
| 13 | 5.05 | 6.05 | 49.83 | 1.25 | 15.69 | 11.34 | 0.97 | 83110.89 |
| 14 | 9.21 | 3.92 | 51.88 | 1.45 | 15.56 | 11.30 | 0.97 | 82779.01 |
| 15 | 8.33 | 5.83 | 47.64 | 1.94 | 14.60 | 11.21 | 0.98 | 83013.15 |
| 16 | 5.51 | 3.17 | 52.31 | 1.27 | 16.53 | 10.17 | 0.97 | 79988.87 |
| 17 | 9.65 | 0.71 | 63.10 | 1.77 | 14.53 | 10.72 | 0.98 | 74646.15 |
| 18 | 8.52 | 5.88 | 56.34 | 0.94 | 17.21 | 10.60 | 1.00 | 74471.43 |
| 19 | 1.91 | 5.19 | 47.99 | 0.67 | 16.85 | 10.84 | 0.98 | 74705.42 |
| 20 | 6.54 | 6.68 | 46.98 | 0.84 | 18.07 | 10.18 | 0.97 | 83889.24 |
| 21 | 9.53 | 3.76 | 46.57 | 1.11 | 16.50 | 10.43 | 0.98 | 80329.51 |
| 22 | 9.52 | 1.82 | 45.18 | 1.13 | 16.06 | 10.47 | 0.97 | 78844.90 |
| 23 | 9.08 | 5.06 | 52.07 | 1.45 | 15.13 | 11.00 | 0.97 | 72936.90 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 6.21 | 5.38 | 50.99 | 1.27 | 15.98 | 10.86 | 0.97 | 79438.10 |
| 最大值 | 9.94 | 10.84 | 63.10 | 2.32 | 18.07 | 11.60 | 1.01 | 85513.67 |
| 發生時間 | 7 | 12 | 17 | 5 | 20 | 12 | | 10 |
| 最小值 | 1.02 | 0.71 | 37.20 | 0.67 | 13.32 | 9.95 | 0.95 | 72736.16 |
| 發生時間 | 12 | 17 | 7 | 19 | 5 | 7 | | 5 |
| 零點偏移(率) | -0.04 % | -0.07 % | -0.05 % | -0.01 % | | 0.00 | | 0.00 % |
| 全幅偏移(率) | 0.05 % | 1.22 % | -0.42 % | 0.35 % | | 0.47 | | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |