

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月19日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.84	1.64	40.73	1.70	16.37	11.89	1.02	78232.32
1	1.85	2.84	41.65	1.09	18.74	11.42	1.02	79982.84
2	4.40	2.78	39.86	1.56	17.27	11.55	1.00	80380.83
3	4.58	2.91	43.28	1.68	17.11	11.79	1.01	80024.09
4	3.62	3.51	51.99	0.69	17.61	11.18	1.00	82028.41
5	3.48	2.62	56.38	1.41	16.00	11.73	1.02	76328.28
6	2.10	2.54	45.56	1.56	16.14	11.73	1.02	76846.47
7	2.69	2.57	41.40	1.64	16.03	11.92	1.02	78272.81
8	2.29	2.75	47.10	1.03	17.10	11.55	1.04	81799.63
9	0.83	4.15	58.12	0.57	17.92	11.33	1.04	78794.63
10	0.57	7.85	47.82	0.38	19.67	9.90	1.02	85728.12
11	3.29	1.99	44.48	1.50	16.16	10.68	1.02	78864.43
12	3.17	1.62	62.96	1.67	17.16	11.66	1.02	79563.50
13	3.62	3.65	46.00	1.29	16.31	11.74	1.03	80190.44
14	5.83	3.36	45.30	2.04	15.82	11.98	1.02	78760.33
15	3.40	3.82	49.76	1.70	15.50	12.36	1.02	75286.14
16	4.83	3.23	55.74	1.05	17.25	11.64	1.03	80541.84
17	3.85	3.56	59.81	0.76	17.59	11.07	1.05	85273.65
18	2.93	3.49	55.84	0.83	17.47	11.63	1.04	81054.25
19	2.35	4.38	52.67	1.69	16.83	11.72	1.04	80276.51
20	0.92	4.96	52.96	0.71	18.16	11.22	1.04	83801.71
21	0.70	3.52	56.96	0.83	18.07	11.57	1.04	80620.89
22	3.61	3.47	56.48	1.00	17.01	11.46	1.04	82562.32
23	2.96	3.99	46.72	2.47	15.71	11.95	1.03	79251.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.95	3.38	49.98	1.29	17.04	11.53	1.03	80186.07
最 大 值	5.83	7.85	62.96	2.47	19.67	12.36	1.06	85728.12
發生時間	14	10	12	23	10	15		10
最 小 值	0.57	1.62	39.86	0.38	15.50	9.90	0.99	75286.14
發生時間	10	12	2	10	15	10		15
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.00 %		-0.07		0.00 %
全幅偏移(率)	0.10 %	0.37 %	-0.05 %	0.23 %		-0.16		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月19日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.27	2.94	46.41	0.25	18.78	10.48	1.18	79122.84
1	3.25	2.68	46.28	0.53	19.30	10.44	1.19	79071.47
2	7.55	2.72	49.39	0.89	18.76	10.39	1.23	81881.18
3	6.94	2.96	45.42	1.02	16.87	10.60	1.21	80167.37
4	1.62	2.72	45.26	0.48	17.69	9.77	1.21	79624.79
5	2.42	2.37	49.81	1.45	14.83	10.97	1.21	70336.53
6	2.00	2.91	42.33	0.79	15.91	10.97	1.23	71945.24
7	1.07	2.44	52.66	0.65	16.17	10.91	1.17	74374.76
8	7.81	2.45	60.26	0.82	17.24	10.41	1.14	80166.76
9	7.53	2.99	48.75	1.63	14.49	11.68	1.16	76035.06
10	0.37	2.13	56.21	0.30	16.88	10.96	1.18	77906.57
11	2.09	2.20	50.94	0.39	15.91	11.16	1.14	76632.27
12	3.63	2.05	55.21	0.22	16.87	11.04	1.15	75947.87
13	6.95	2.46	44.83	0.66	15.04	11.51	1.16	75667.37
14	5.93	2.28	50.21	1.15	14.31	11.79	1.15	74909.60
15	4.65	2.40	54.72	1.48	14.14	11.77	1.12	69746.15
16	7.62	2.19	51.10	0.76	16.53	10.99	1.13	75513.98
17	0.63	3.55	50.18	0.16	17.97	10.56	1.11	79069.29
18	1.24	2.36	48.08	0.18	17.43	10.52	1.11	79052.71
19	2.78	2.31	50.66	0.42	16.29	10.68	1.10	77184.49
20	1.06	2.11	57.28	0.26	17.37	10.65	1.12	78057.46
21	1.97	2.35	56.99	0.28	18.19	10.53	1.12	78435.64
22	0.33	2.82	54.02	0.30	16.93	10.75	1.14	76254.66
23	2.03	2.67	52.89	0.69	15.45	11.18	1.15	75343.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.49	2.54	50.83	0.66	16.64	10.86	1.16	76768.64
最 大 值	7.81	3.55	60.26	1.63	19.30	11.79	1.23	81881.18
發生時間	8	17	8	9	1	14		2
最 小 值	0.33	2.05	42.33	0.16	14.14	9.77	1.10	69746.15
發生時間	22	12	6	17	15	4		15
零點偏移(率)	-0.11 %	-0.00 %	-0.01 %	0.00 %		-0.11		0.00 %
全幅偏移(率)	0.02 %	-0.02 %	-0.04 %	0.22 %		0.20		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								