

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月04日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.24	14.37	62.30	0.65	16.19	11.55	1.09	82553.55
1	8.42	11.53	45.00	1.31	17.51	11.20	1.07	85065.03
2	9.45	10.12	37.36	1.77	15.27	11.56	1.07	84428.31
3	5.52	12.55	51.46	2.25	13.85	12.13	1.09	80958.74
4	13.15	13.71	52.07	3.16	13.04	12.11	1.07	82033.05
5	9.42	10.39	46.38	1.13	16.38	11.66	1.09	77943.90
6	8.05	13.18	59.57	1.45	15.61	12.05	1.08	79797.29
7	7.55	7.69	53.87	1.25	16.05	11.56	1.06	83780.71
8	8.90	8.40	30.61	2.84	15.22	11.87	1.04	82802.81
9	8.14	7.59	32.01	2.55	14.45	12.45	1.05	79468.90
10	9.88	10.07	56.54	2.30	14.48	11.94	1.05	84358.75
11	9.51	15.85	47.55	3.90	12.82	12.44	1.06	81026.55
12	9.24	10.36	54.70	2.62	14.05	12.35	1.06	80878.44
13	9.00	11.03	51.22	3.24	13.21	12.45	1.05	80388.97
14	7.78	14.33	57.33	2.47	14.23	12.53	1.03	78836.55
15	7.88	11.12	61.07	1.64	15.17	12.04	1.02	82468.16
16	9.24	9.54	58.06	1.80	15.12	11.93	1.02	83375.60
17	10.31	10.14	45.15	2.15	14.73	11.80	1.02	85066.28
18	8.81	11.10	48.82	2.66	13.73	12.17	1.02	82612.87
19	8.95	9.04	56.59	1.56	15.24	11.61	1.02	85111.68
20	9.85	9.30	56.81	1.31	16.04	11.44	1.02	84538.24
21	7.58	9.16	53.44	1.44	15.34	11.60	1.02	83608.51
22	8.23	9.01	54.81	1.18	15.50	11.69	1.02	82648.48
23	8.17	9.58	56.17	0.88	16.13	11.68	1.02	81751.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.59	10.80	51.20	1.98	14.97	11.91	1.05	82312.63
最 大 值	13.15	15.85	62.30	3.90	17.51	12.53	1.15	85111.68
發生時間	4	11	0	11	1	14		19
最 小 值	3.24	7.59	30.61	0.65	12.82	11.20	1.02	77943.90
發生時間	0	9	8	0	11	1		5
零點偏移(率)	-0.03 %	-0.02 %	-0.04 %	-0.01 %		-0.02		0.30 %
全幅偏移(率)	0.02 %	0.46 %	0.08 %	-0.30 %		0.04		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

