

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.43	4.96	44.45	0.85	17.01	11.81	0.98	80624.81
1	5.86	4.96	49.73	0.64	18.03	11.77	0.97	79531.35
2	3.65	4.54	49.86	0.54	17.40	11.86	0.98	79956.72
3	2.64	5.55	49.75	0.79	16.09	12.61	0.98	74688.99
4	4.92	5.77	58.09	0.40	17.30	11.79	0.98	80821.80
5	5.53	6.93	60.66	1.01	17.41	11.68	0.99	80663.89
6	3.80	7.16	52.59	0.38	18.82	11.28	0.99	83640.31
7	6.94	7.66	49.56	0.64	17.91	11.56	1.00	81635.97
8	7.16	8.73	49.80	0.71	17.57	11.66	1.02	81979.95
9	9.71	9.23	45.08	1.13	17.08	12.01	1.02	82103.97
10	6.92	10.34	50.60	0.72	16.99	12.75	0.98	75436.45
11	7.78	9.80	61.62	0.39	17.96	12.25	0.97	79345.28
12	8.44	9.23	43.04	1.10	16.72	12.14	0.98	81089.31
13	8.69	5.10	46.27	1.29	16.40	12.07	0.98	81078.00
14	10.07	2.77	41.74	2.51	14.72	12.14	0.97	79637.52
15	8.18	2.75	43.93	1.74	16.24	11.95	0.98	79868.21
16	2.29	2.78	57.39	0.31	18.43	11.38	1.00	82650.18
17	8.62	2.88	53.55	0.67	18.23	11.03	1.02	85682.39
18	9.91	5.97	51.89	0.66	18.17	10.93	1.02	86582.75
19	12.53	2.45	52.92	0.88	18.28	10.98	1.00	86305.57
20	11.15	2.37	48.15	0.68	18.56	11.00	1.00	85540.27
21	8.72	2.24	42.87	0.62	18.00	11.23	1.00	84512.45
22	9.43	3.83	58.53	0.33	18.44	11.54	1.01	81491.75
23	8.94	5.06	45.02	0.75	17.54	11.49	0.99	82532.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.47	5.54	50.30	0.82	17.47	11.70	0.99	81558.36
最大值	12.53	10.34	61.62	2.51	18.82	12.75	1.02	86582.75
發生時間	19	10	11	14	6	10		18
最小值	2.29	2.24	41.74	0.31	14.72	10.93	0.97	74688.99
發生時間	16	21	14	16	14	18		3
零點偏移(率)	-0.08 %	-0.01 %	-0.03 %	-0.01 %		-0.14		0.00 %
全幅偏移(率)	0.00 %	0.00 %	-0.03 %	0.00 %		-0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.97	4.94	54.84	2.47	15.76	11.74	0.98	76666.10
1	1.11	4.82	51.01	2.04	16.83	11.44	1.00	78126.56
2	1.16	4.89	63.69	2.11	16.21	11.96	1.02	74166.60
3	4.44	4.96	59.89	1.58	17.39	11.62	1.02	76251.51
4	5.51	5.43	48.83	1.74	18.06	11.15	1.02	79467.14
5	3.65	5.94	64.97	2.20	16.79	12.12	1.01	72650.10
6	0.31	5.47	58.99	1.11	16.72	12.74	1.02	72690.21
7	1.50	5.45	41.63	1.51	18.73	10.59	1.02	82939.73
8	2.53	4.75	46.35	2.04	16.96	11.36	1.02	78428.37
9	4.63	2.10	45.54	2.25	16.55	11.48	1.00	77912.78
10	7.98	1.97	53.91	1.77	18.45	10.92	1.00	80341.93
11	8.98	3.12	45.80	2.73	16.57	11.32	1.02	79846.86
12	8.16	3.07	51.35	2.65	16.32	11.55	1.02	77720.65
13	5.62	2.86	46.94	3.23	15.30	11.53	1.02	78521.17
14	5.38	3.77	45.58	3.21	14.12	11.86	1.02	76764.91
15	4.85	3.26	52.62	3.17	15.04	11.91	1.04	75848.77
16	8.53	3.55	45.61	2.95	17.51	11.06	1.03	79921.05
17	1.40	3.28	56.75	0.99	19.29	11.29	1.02	76189.86
18	11.64	7.37	38.40	2.37	18.43	10.28	1.02	85286.62
19	9.52	3.64	54.71	2.54	17.31	10.81	1.02	82037.26
20	10.26	1.65	53.37	2.01	18.23	10.52	1.02	83684.89
21	9.96	2.79	45.43	3.71	16.21	11.21	0.99	80501.30
22	8.70	2.75	53.09	2.36	16.30	12.00	1.01	73875.08
23	9.34	6.26	47.30	2.96	16.68	11.32	1.01	78907.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.96	4.09	51.11	2.32	16.91	11.41	1.01	78281.10
最大值	11.64	7.37	64.97	3.71	19.29	12.74	1.07	85286.62
發生時間	18	18	5	21	17	6		18
最小值	0.31	1.65	38.40	0.99	14.12	10.28	0.97	72650.10
發生時間	6	20	18	17	14	18		5
零點偏移(率)	-0.07 %	-0.04 %	-0.01 %	0.00 %		-0.05		-0.10 %
全幅偏移(率)	0.14 %	0.05 %	0.91 %	0.30 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.47	4.10	45.57	0.47	16.74	10.82	0.99	76624.16
1	4.37	5.20	45.17	0.37	17.96	10.87	0.99	74055.33
2	3.77	5.60	53.11	0.36	16.33	11.43	0.98	73207.71
3	6.08	5.53	43.24	0.43	18.61	10.23	0.99	82253.48
4	4.50	4.68	44.50	0.33	16.95	10.92	0.99	77552.09
5	2.56	4.70	50.37	0.45	17.60	10.96	0.99	76439.83
6	3.56	4.84	43.05	0.33	18.92	10.29	0.99	81870.61
7	1.15	5.18	44.24	0.17	18.88	10.23	0.99	84674.06
8	1.97	8.77	48.87	0.29	17.89	10.39	0.99	80528.46
9	3.55	4.61	51.31	0.35	17.43	10.86	0.99	75222.02
10	1.32	4.41	58.61	0.20	18.77	10.63	0.99	79635.58
11	3.94	4.78	45.11	0.31	18.01	10.46	0.98	81154.99
12	2.36	5.29	51.62	0.45	16.36	11.42	0.99	75037.91
13	2.81	6.09	49.59	0.81	14.74	11.87	0.99	73091.40
14	2.87	9.68	46.17	1.10	15.47	11.19	0.99	77924.71
15	4.11	3.60	47.58	0.63	16.56	10.87	0.98	80526.36
16	10.88	9.60	40.63	0.59	17.93	10.18	0.98	84483.83
17	8.13	2.90	39.76	0.36	18.72	9.99	0.98	80846.69
18	9.31	4.00	40.33	0.59	17.56	9.90	0.99	81474.93
19	8.55	1.54	60.85	0.52	18.18	10.25	0.99	80673.07
20	10.20	1.34	58.45	0.47	17.87	10.37	0.95	80745.56
21	8.94	2.60	56.88	0.51	17.04	10.51	0.98	82710.12
22	7.33	3.82	53.93	0.60	16.77	10.95	0.97	79032.83
23	9.70	5.64	43.47	0.91	15.57	11.10	0.97	76113.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.31	4.94	48.43	0.48	17.37	10.70	0.98	78994.97
最大值	10.88	9.68	60.85	1.10	18.92	11.87	1.00	84674.06
發生時間	16	14	19	14	6	13		7
最小值	1.15	1.34	39.76	0.17	14.74	9.90	0.94	73091.40
發生時間	7	20	17	7	13	18		13
零點偏移(率)	-0.08 %	0.01 %	-0.02 %	0.00 %		-0.18		0.00 %
全幅偏移(率)	1.65 %	-0.05 %	-0.02 %	0.34 %		-0.24		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								