

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.70	12.76	35.69	0.70	20.89	10.61	1.02	77223.65
1	8.97	10.39	41.69	0.95	20.63	10.77	1.02	76086.09
2	9.61	10.79	46.26	1.15	18.88	10.82	1.02	77833.61
3	9.26	6.35	40.28	1.96	16.74	11.24	1.01	71990.52
4	9.84	8.66	41.55	1.68	15.90	11.38	1.02	73303.14
5	6.79	11.35	54.11	2.44	13.90	12.37	1.05	62963.52
6	7.46	6.51	47.13	1.42	17.00	11.26	1.05	72352.35
7	6.44	5.63	37.38	0.95	18.07	10.38	1.03	72975.95
8	8.62	1.40	40.85	1.01	16.44	11.32	1.06	71567.30
9	8.16	7.07	55.78	0.46	18.04	11.20	1.05	75220.07
10	9.86	9.13	47.85	0.86	16.81	11.24	1.03	75485.64
11	7.74	4.31	37.12	1.30	16.48	10.86	1.01	68194.68
12	8.20	4.53	42.57	1.26	15.55	11.40	1.04	71823.01
13	9.11	4.58	47.12	0.72	17.07	11.62	1.05	71646.92
14	10.07	6.59	47.24	1.39	15.65	11.74	1.04	71792.66
15	4.58	5.94	65.40	0.79	17.22	11.84	1.05	70572.91
16	2.86	5.49	54.71	0.32	17.87	11.53	1.05	72875.42
17	0.12	5.80	54.56	0.37	17.81	11.20	1.02	75695.65
18	0.17	6.09	63.49	0.31	18.15	11.24	1.04	75632.54
19	2.68	5.67	58.32	0.35	18.88	11.05	1.05	75881.83
20	9.35	5.61	56.63	0.47	18.68	10.99	1.04	76696.26
21	7.20	9.17	48.05	0.38	19.21	10.86	1.03	76865.60
22	9.27	13.17	45.22	0.89	17.86	11.21	1.03	74999.21
23	6.54	10.86	58.20	0.76	17.63	11.82	1.02	71034.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.19	7.41	48.63	0.95	17.56	11.25	1.03	73363.06
最大值	10.07	13.17	65.40	2.44	20.89	12.37	1.07	77833.61
發生時間	14	22	15	5	0	5		2
最小值	0.12	1.40	35.69	0.31	13.90	10.38	0.99	62963.52
發生時間	17	8	0	18	5	7		5
零點偏移(率)	-0.10 %	-0.03 %	-0.03 %	-0.01 %		-0.16		0.00 %
全幅偏移(率)	0.00 %	0.31 %	-0.10 %	0.09 %		0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.73	9.02	52.92	2.09	18.24	10.37	0.99	83730.00
1	8.88	3.96	59.94	2.27	20.35	10.15	0.99	83127.61
2	9.34	6.68	45.18	2.74	16.49	10.23	0.99	87098.22
3	8.08	10.75	60.35	3.07	15.44	10.55	0.99	85153.67
4	9.03	5.69	55.40	2.23	16.74	10.16	1.01	86539.55
5	9.46	3.88	65.04	2.22	15.98	10.14	1.02	87673.94
6	8.14	2.99	68.08	3.27	14.85	10.93	1.02	85709.78
7	9.25	2.59	61.18	2.09	15.96	10.47	1.02	84596.63
8	9.42	2.01	69.64	2.07	15.86	10.49	1.00	83730.69
9	8.50	7.05	49.64	1.44	16.82	10.22	1.03	82469.60
10	9.97	3.75	57.75	2.03	15.46	10.74	1.04	79474.82
11	7.56	4.38	65.06	1.67	15.94	11.24	1.02	77464.72
12	6.93	4.26	60.60	1.44	16.22	10.88	1.02	81416.16
13	5.52	4.60	50.53	2.16	14.95	10.92	1.01	81488.06
14	6.02	8.99	46.04	1.80	15.98	10.47	1.02	83845.04
15	7.92	5.21	51.93	1.59	15.50	11.27	1.01	77923.67
16	1.26	2.06	68.23	1.23	15.28	11.97	1.02	73244.07
17	1.26	2.33	42.93	0.97	17.27	10.31	1.02	84083.49
18	8.32	8.16	46.22	1.36	17.62	9.66	1.04	88357.35
19	6.55	7.18	55.25	2.13	16.00	10.28	1.03	85090.51
20	8.81	3.21	58.58	1.43	17.84	10.14	1.05	85066.98
21	9.15	5.30	55.36	1.54	17.58	10.07	1.02	85476.51
22	8.79	8.80	49.16	2.10	16.42	10.87	1.02	82596.10
23	8.96	6.19	59.06	1.89	16.93	10.42	1.01	84804.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.74	5.38	56.42	1.95	16.49	10.54	1.02	83340.07
最大值	9.97	10.75	69.64	3.27	20.35	11.97	1.09	88357.35
發生時間	10	3	8	6	1	16		18
最小值	1.26	2.01	42.93	0.97	14.85	9.66	0.99	73244.07
發生時間	16	8	17	17	6	18		16
零點偏移(率)	-0.10 %	-0.11 %	-0.02 %	-0.04 %		0.03		-0.20 %
全幅偏移(率)	-0.02 %	-0.11 %	-0.90 %	0.23 %		-0.19		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.18	6.43	44.01	1.97	16.31	10.40	1.00	75982.99
1	9.82	7.26	42.95	2.41	17.15	9.88	1.00	78665.40
2	9.59	5.78	36.64	2.56	15.10	10.10	0.99	77036.53
3	9.16	2.60	48.64	2.43	15.35	10.33	0.99	74657.30
4	8.02	6.86	53.64	2.67	14.20	10.52	0.99	72261.35
5	9.89	6.62	42.61	3.25	13.83	10.49	0.97	74217.60
6	5.46	6.00	48.57	2.95	12.90	11.22	0.99	69179.04
7	4.07	2.90	51.50	2.31	13.74	10.42	0.99	69867.41
8	8.06	2.37	50.29	2.58	14.44	10.54	1.00	74172.18
9	7.44	9.09	62.24	2.07	15.11	10.21	1.00	77019.93
10	6.21	6.10	63.16	2.75	13.62	10.67	1.00	74265.60
11	4.73	6.21	53.30	2.84	12.24	11.14	0.99	71387.14
12	2.28	2.96	61.37	2.45	12.51	11.61	1.03	71023.49
13	7.48	4.27	50.19	2.47	12.76	11.35	1.02	74202.20
14	5.25	2.29	57.41	1.78	14.13	11.47	1.01	72815.16
15	3.36	4.94	57.86	1.52	14.51	11.23	1.04	74785.35
16	5.28	3.69	59.16	1.45	14.80	11.09	1.05	78032.87
17	3.56	2.60	67.11	1.37	15.26	11.66	1.02	74261.10
18	3.09	3.15	58.18	1.07	16.21	10.78	1.00	82064.50
19	7.86	4.02	56.16	1.30	15.83	10.82	1.01	81517.71
20	6.73	3.29	63.81	1.36	15.66	10.84	1.02	82724.59
21	7.99	5.02	51.48	2.07	14.07	11.24	1.01	79394.29
22	5.99	5.09	60.03	1.16	16.18	11.03	0.99	78226.77
23	7.84	9.31	51.24	1.90	14.67	11.18	0.99	77820.85
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.60	4.95	53.81	2.11	14.61	10.84	1.00	75649.22
最大值	9.89	9.31	67.11	3.25	17.15	11.66	1.05	82724.59
發生時間	5	23	17	5	1	17		20
最小值	2.28	2.29	36.64	1.07	12.24	9.88	0.97	69179.04
發生時間	12	14	2	18	11	1		6
零點偏移(率)	-0.30 %	0.00 %	-0.01 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	-0.23 %	0.06 %	-1.11 %	0.09 %		0.19		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								