

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年07月07日

報表日期: 113年07月07日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.94	4.87	61.83	2.00	18.44	11.67	1.00	79308.58
1	4.29	4.85	62.86	1.60	19.70	11.27	1.01	81830.06
2	7.98	18.37	51.07	3.71	16.82	11.56	1.01	81312.72
3	6.50	2.72	46.57	1.91	18.06	11.63	1.02	80205.43
4	6.61	9.92	48.05	2.49	17.00	11.71	1.02	80534.68
5	4.69	6.03	50.47	1.36	18.78	11.77	1.03	78692.99
6	5.07	5.28	43.55	1.69	19.38	11.01	1.03	83830.99
7	7.48	1.37	41.00	3.19	16.30	11.79	1.05	78365.13
8	7.19	1.32	51.82	2.58	17.38	11.73	1.06	79497.62
9	8.88	1.18	50.61	3.17	16.53	11.87	1.05	79041.73
10	7.38	0.92	50.42	2.92	16.94	11.63	1.07	80729.71
11	7.12	1.30	59.12	1.78	19.37	11.34	1.05	81447.19
12	8.45	3.02	53.55	1.68	19.81	11.02	1.05	83111.27
13	7.22	3.75	58.91	1.51	19.41	11.53	1.04	79620.78
14	7.36	5.21	48.23	2.20	19.24	11.05	1.06	83454.41
15	10.84	8.16	52.97	2.74	18.98	11.18	1.05	82758.03
16	9.42	4.78	54.28	1.95	18.94	11.03	1.06	83870.91
17	7.47	4.76	60.29	1.60	19.01	11.49	1.06	80315.13
18	7.17	4.84	56.14	1.24	19.89	11.00	1.06	83484.15
19	10.29	5.04	54.68	2.27	19.63	10.88	1.06	84445.82
20	9.07	4.69	53.05	2.14	18.84	11.23	1.06	82124.35
21	8.32	4.71	51.81	1.83	19.12	11.24	1.06	82157.30
22	5.90	9.87	59.45	1.06	20.12	11.20	1.05	81415.40
23	7.90	5.20	50.54	1.46	18.79	11.28	1.03	82127.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.44	5.09	52.97	2.09	18.60	11.38	1.04	81403.42
最 大 值	10.84	18.37	62.86	3.71	20.12	11.87	1.08	84445.82
發生時間	15	2	1	2	22	9		19
最 小 值	4.29	0.92	41.00	1.06	16.30	10.88	0.99	78365.13
發生時間	1	10	7	22	7	19		7
零點偏移(率)	-0.22 %	0.00 %	-0.00 %	0.00 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	0.65 %	-0.18 %	0.10 %		-0.09		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年07月07日

[illegible]