

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.29	12.57	53.38	0.70	19.76	11.26	0.99	76594.06
1	10.18	12.58	53.29	1.04	19.88	10.92	0.99	76955.60
2	9.88	11.39	44.52	1.38	17.89	11.00	0.99	78082.41
3	9.62	11.93	46.68	1.54	18.64	11.03	0.99	77704.53
4	8.94	11.93	50.62	1.38	18.19	11.15	0.99	77167.36
5	6.12	12.65	58.77	1.15	20.01	10.95	0.98	77495.89
6	8.84	13.13	55.19	1.18	19.75	11.43	0.99	74641.58
7	9.05	12.23	50.80	0.69	19.83	10.88	0.99	78576.07
8	7.68	11.66	50.58	0.44	20.47	10.68	1.01	78708.84
9	8.78	11.93	39.02	0.86	19.58	10.40	1.01	79892.24
10	5.42	8.11	42.21	0.69	18.52	11.08	1.00	75959.97
11	2.92	9.46	52.95	0.38	19.66	10.95	1.01	74932.24
12	5.32	10.64	51.09	0.44	19.23	11.33	0.98	72435.78
13	10.26	8.96	50.75	0.54	19.73	10.45	0.99	78545.55
14	12.91	11.77	35.17	1.60	19.21	10.72	0.99	76508.17
15	7.79	10.59	56.40	0.28	19.95	11.10	0.99	74005.28
16	9.07	12.30	43.28	0.33	19.65	10.51	0.99	76748.63
17	8.27	6.18	38.92	1.23	17.95	11.50	1.01	71040.16
18	9.38	10.85	32.30	0.62	19.67	10.71	1.01	75813.66
19	9.06	5.94	41.11	0.46	20.62	10.60	0.99	76592.36
20	9.13	7.22	47.14	0.40	20.71	10.40	0.99	79035.85
21	9.99	9.90	38.26	0.83	18.34	11.18	1.00	74368.82
22	9.46	5.50	43.66	0.61	20.90	10.66	1.01	77627.76
23	9.50	11.57	35.98	0.60	19.66	10.94	1.02	76029.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.49	10.46	46.34	0.81	19.49	10.91	1.00	76477.60
最大值	12.91	13.13	58.77	1.60	20.90	11.50	1.03	79892.24
發生時間	14	6	5	14	22	17		9
最小值	2.92	5.50	32.30	0.28	17.89	10.40	0.97	71040.16
發生時間	11	22	18	15	2	9		17
零點偏移(率)	-0.09 %	0.00 %	-0.02 %	-0.03 %		-0.15		0.00 %
全幅偏移(率)	0.00 %	-0.47 %	0.34 %	-0.18 %		0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.26	7.88	55.10	2.93	16.14	10.76	1.00	81555.39
1	9.67	6.58	51.58	3.00	17.59	10.15	0.99	85693.28
2	9.51	7.27	53.13	3.98	16.09	10.53	0.99	84450.48
3	7.89	4.93	54.94	3.16	16.37	10.44	1.00	84930.99
4	8.54	4.78	58.33	2.15	17.34	10.08	1.02	86720.41
5	6.03	5.34	52.52	2.13	18.51	9.78	1.02	87741.93
6	3.30	6.53	58.20	1.89	19.03	10.11	1.02	88337.71
7	8.66	4.76	60.17	1.96	18.45	10.21	1.04	85052.81
8	3.64	5.62	62.00	1.15	18.37	10.07	1.05	85909.06
9	1.52	9.34	43.52	1.60	18.04	9.99	1.01	85891.77
10	2.21	7.00	51.44	2.24	16.50	10.11	1.06	86610.15
11	8.92	5.71	56.55	2.23	17.57	10.28	1.05	83985.23
12	9.08	7.22	55.37	2.97	16.22	10.21	1.05	85189.11
13	8.13	4.05	60.17	2.14	17.80	10.03	1.05	85332.23
14	8.40	3.05	62.51	1.40	19.16	9.97	1.04	84967.11
15	7.31	5.85	52.23	1.99	16.98	9.97	1.03	86830.45
16	9.70	12.31	57.51	2.84	16.50	10.29	1.05	84612.71
17	9.25	3.62	59.36	2.09	16.58	10.11	1.05	86573.79
18	9.74	4.60	54.55	2.30	17.11	10.30	1.04	84510.43
19	7.98	5.59	50.58	2.07	17.33	9.93	1.04	86740.51
20	7.86	9.47	49.11	2.36	16.94	10.19	1.02	85045.48
21	8.96	3.79	55.29	2.35	16.84	10.38	1.00	84796.45
22	9.79	3.88	55.55	2.14	17.44	10.15	0.99	85726.61
23	9.73	4.09	51.38	2.59	17.16	10.27	0.99	85748.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.63	5.97	55.05	2.32	17.34	10.18	1.02	85539.67
最大值	9.79	12.31	62.51	3.98	19.16	10.76	1.08	88337.71
發生時間	22	16	14	2	14	0		6
最小值	1.52	3.05	43.52	1.15	16.09	9.78	0.99	81555.39
發生時間	9	14	9	8	2	5		0
零點偏移(率)	-0.05 %	-0.13 %	-0.02 %	-0.02 %		0.04		-0.10 %
全幅偏移(率)	-0.30 %	0.86 %	-0.68 %	0.23 %		-0.13		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.58	5.15	46.24	1.35	16.36	10.97	1.02	80062.22
1	8.18	11.07	43.19	1.69	17.36	10.47	1.02	81900.59
2	7.40	6.58	40.96	1.69	16.22	10.25	1.02	79509.36
3	9.24	6.58	48.63	2.42	14.61	10.57	1.02	77350.63
4	9.40	6.24	46.40	2.10	14.67	10.67	1.01	76254.09
5	6.97	8.48	49.73	1.85	14.37	10.65	1.01	78084.58
6	9.15	9.47	47.24	2.28	14.17	11.38	1.02	79263.47
7	2.97	5.34	48.17	1.08	16.86	10.26	1.01	80670.80
8	6.91	6.11	52.79	1.81	15.15	10.97	1.01	82000.12
9	5.89	4.54	56.87	1.31	17.02	10.75	1.02	80618.78
10	6.31	9.24	46.05	1.47	16.38	10.37	0.99	78623.94
11	5.39	7.60	51.12	1.22	16.07	10.57	1.00	75561.37
12	5.84	3.50	60.67	1.68	15.86	10.14	0.99	80747.01
13	3.74	9.30	50.73	1.76	15.20	10.80	1.00	78658.02
14	7.13	2.40	50.19	1.35	17.23	10.31	0.99	80566.81
15	6.34	4.89	49.66	1.38	16.39	10.80	0.99	78506.56
16	7.15	2.73	57.53	1.37	18.14	9.93	1.01	83566.18
17	8.83	4.04	64.35	1.97	15.08	10.87	1.02	78225.32
18	7.91	5.37	56.24	1.51	17.90	10.29	1.00	79586.08
19	8.40	6.74	52.90	1.75	16.82	10.29	0.99	79114.81
20	7.54	10.67	50.79	2.14	14.63	10.76	0.99	76084.04
21	8.74	6.01	49.67	2.03	16.00	10.54	0.99	78147.89
22	9.46	5.43	54.85	2.09	16.49	10.36	1.00	79701.38
23	9.12	11.20	41.86	1.79	15.70	10.52	0.99	76302.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.40	6.61	50.70	1.71	16.03	10.56	1.00	79129.46
最大值	9.58	11.20	64.35	2.42	18.14	11.38	1.06	83566.18
發生時間	0	23	17	3	16	6		16
最小值	2.97	2.40	40.96	1.08	14.17	9.93	0.98	75561.37
發生時間	7	14	2	7	6	16		11
零點偏移(率)	-0.02 %	0.00 %	-0.02 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	-0.27 %	0.01 %	-0.72 %	0.16 %		0.25		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								