

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.81	16.40	47.91	2.64	17.14	11.02	1.05	67650.01
1	4.55	18.37	65.57	2.18	18.80	11.59	1.06	64883.99
2	7.58	無效	44.74	2.43	17.95	10.84	1.09	71593.91
3	8.14	16.94	38.29	2.81	16.85	11.32	1.07	67497.91
4	7.54	16.36	68.17	2.45	18.05	11.67	1.08	65521.56
5	9.40	17.17	38.21	2.43	17.67	11.14	1.10	69069.74
6	9.49	17.24	39.44	2.55	16.78	11.23	1.10	68668.58
7	7.02	16.02	57.59	2.03	18.99	11.04	1.10	69331.64
8	9.74	16.48	47.64	2.42	17.38	11.06	1.09	71306.04
9	9.18	17.29	46.10	2.34	17.44	11.16	1.07	70596.27
10	7.60	16.47	54.65	2.29	17.54	11.28	1.09	69619.71
11	8.28	14.71	54.28	1.89	17.42	11.57	1.08	67550.26
12	6.03	12.11	56.68	1.49	17.95	11.64	1.08	67577.00
13	7.66	12.96	49.18	1.69	17.03	11.59	1.09	68766.64
14	8.02	10.13	54.44	1.82	16.36	11.74	1.09	69008.42
15	4.21	12.43	59.38	1.52	17.40	11.95	1.10	67057.25
16	8.56	14.02	46.59	1.91	18.38	10.75	1.07	72982.11
17	9.21	17.64	47.88	2.07	18.48	10.81	1.07	72220.84
18	8.66	18.21	48.70	2.48	16.78	10.96	1.07	72026.64
19	5.05	19.59	51.09	2.30	17.41	11.13	1.08	69575.48
20	10.03	18.38	46.23	2.22	18.07	10.77	1.10	70753.00
21	7.76	17.74	47.76	1.79	19.57	10.72	1.10	70972.13
22	6.42	17.54	56.28	1.78	19.60	10.37	1.10	74010.88
23	8.56	18.87	36.87	2.38	17.25	10.97	1.08	69507.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	23	24	24	24	24	24	24
平均值	7.85	16.22	50.15	2.16	17.76	11.18	1.08	69489.49
最大值	10.03	19.59	68.17	2.81	19.60	11.95	1.10	74010.88
發生時間	20	19	4	3	22	15		22
最小值	4.21	10.13	36.87	1.49	16.36	10.37	1.05	64883.99
發生時間	15	14	23	12	14	22		1
零點偏移(率)	-0.14 %	-0.02 %	-0.02 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.01 %	0.40 %	-0.59 %	0.43 %		0.00		0.30 %
有效比率	100.00 %	95.83%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.18	16.52	62.39	0.57	19.85	8.80	1.18	79596.51
1	2.07	16.38	65.17	0.97	20.04	9.27	1.19	79898.03
2	8.73	無效	54.05	2.10	18.17	9.36	1.19	81924.71
3	8.38	17.79	54.43	1.74	17.93	9.63	1.18	80923.94
4	6.99	無效	58.82	1.46	18.44	9.64	1.18	81023.71
5	6.89	19.16	53.88	1.66	17.90	9.66	1.18	82716.98
6	4.38	15.07	51.23	1.37	17.89	10.00	1.20	78428.66
7	5.33	15.74	53.99	1.61	17.21	9.96	1.22	80626.30
8	4.58	15.96	63.49	1.59	16.98	10.77	1.21	76543.71
9	7.39	無效	56.27	2.00	16.23	10.84	1.20	75585.15
10	3.70	無效	69.89	2.05	15.47	11.66	1.20	69580.14
11	0.51	無效	65.87	1.83	15.86	11.55	1.23	65205.07
12	2.13	無效	53.58	1.72	16.49	10.73	1.22	74982.17
13	4.71	19.68	66.76	1.19	19.51	9.31	1.21	78637.94
14	2.41	16.14	64.56	1.08	18.82	9.12	1.21	77672.18
15	3.99	17.04	46.99	1.43	18.20	9.51	1.20	76113.70
16	6.03	17.69	44.59	1.31	18.95	9.14	1.21	78105.73
17	7.57	13.26	51.58	1.53	17.54	9.45	1.23	78837.05
18	2.47	無效	44.40	0.97	18.24	9.15	1.23	76495.06
19	1.44	15.43	61.33	1.04	17.45	9.04	1.22	80840.25
20	2.97	16.66	59.71	1.17	17.09	9.52	1.21	81587.01
21	5.91	13.85	63.15	1.22	17.90	9.38	1.21	83763.20
22	7.27	16.40	52.57	1.70	16.35	9.96	1.20	78414.52
23	5.08	15.38	61.14	1.04	18.11	9.84	1.20	76428.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	17	24	24	24	24	24	24
平均值	4.63	16.36	57.49	1.43	17.78	9.80	1.20	78080.42
最大值	8.73	19.68	69.89	2.10	20.04	11.66	1.23	83763.20
發生時間	2	13	10	2	1	10		21
最小值	0.18	13.26	44.40	0.57	15.47	8.80	1.18	65205.07
發生時間	0	17	18	0	10	0		11
零點偏移(率)	-0.06 %	-0.01 %	-0.03 %	-0.05 %		-0.06		-0.10 %
全幅偏移(率)	0.04 %	0.62 %	-0.15 %	0.65 %		0.07		0.00 %
有效比率	100.00 %	70.83%	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.69	無效	53.43	2.99	17.68	10.22	1.02	79229.86
1	4.73	無效	60.22	2.50	17.21	10.93	1.03	76900.59
2	6.90	19.78	57.13	2.84	16.48	10.47	1.05	81154.25
3	7.52	18.91	63.21	2.98	17.03	10.55	1.05	81364.97
4	8.45	無效	62.23	3.07	15.82	11.03	1.05	80001.97
5	3.64	16.64	61.47	2.50	16.69	10.93	1.05	79150.16
6	8.47	無效	61.89	3.10	16.03	11.00	1.05	79209.40
7	10.19	無效	62.26	3.27	15.00	11.04	1.06	88759.48
8	7.89	18.60	66.25	2.58	17.21	10.85	1.09	82034.30
9	7.62	18.38	59.83	2.71	16.23	10.92	1.05	78339.26
10	3.43	無效	60.99	2.30	17.99	9.89	1.06	81891.85
11	3.64	無效	52.31	2.96	14.07	10.45	1.07	71203.59
12	6.66	無效	57.63	2.65	17.69	9.89	1.04	77413.47
13	10.09	無效	56.88	3.05	16.90	10.05	1.05	75385.96
14	9.73	無效	53.46	2.90	16.37	9.96	1.04	73360.22
15	8.05	17.21	52.81	2.57	15.67	9.76	1.03	82811.76
16	3.40	無效	49.31	2.34	14.76	9.99	1.05	71401.44
17	1.89	6.40	55.88	2.16	15.60	10.43	1.08	76538.43
18	1.82	16.69	52.15	2.52	14.11	10.36	1.08	75494.40
19	2.89	19.94	61.46	2.71	14.64	10.58	1.07	74625.16
20	5.03	18.73	60.56	2.13	16.90	10.55	1.06	73726.72
21	2.06	17.05	59.59	1.89	17.34	10.08	1.05	80506.59
22	3.83	無效	55.36	2.06	16.16	10.64	1.05	74914.54
23	1.70	16.94	56.10	1.87	17.56	10.27	1.06	74764.94
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	12	24	24	24	24	24	24
平均值	5.72	17.11	58.02	2.61	16.30	10.45	1.05	77924.30
最大值	10.19	19.94	66.25	3.27	17.99	11.04	1.09	88759.48
發生時間	7	19	8	7	10	7		7
最小值	1.70	6.40	49.31	1.87	14.07	9.76	1.02	71203.59
發生時間	23	17	16	23	11	15		11
零點偏移(率)	-0.04 %	0.00 %	-0.09 %	-0.02 %		0.00		0.00 %
全幅偏移(率)	0.04 %	0.38 %	-0.40 %	0.51 %		0.42		0.20 %
有效比率	100.00 %	50.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								