

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年01月29日

報表日期: 115年01月29日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.36	13.71	55.80	2.58	15.47	11.96	0.64	78569.68
1	9.83	13.81	37.37	3.16	15.96	11.36	0.64	83241.23
2	9.94	12.73	39.69	2.58	14.25	11.91	0.64	79835.66
3	12.09	11.69	45.57	2.87	13.34	11.87	0.65	81786.59
4	10.07	12.34	45.32	3.12	13.04	12.37	0.65	77475.29
5	11.54	12.77	44.22	2.01	15.22	11.94	0.79	75647.65
6	9.79	12.25	49.37	2.19	14.27	12.05	0.81	78672.83
7	11.53	12.52	55.87	2.50	13.57	12.35	0.81	76867.04
8	9.18	13.04	64.41	2.10	13.80	12.60	0.80	74421.22
9	10.46	14.09	42.65	2.15	14.35	11.62	0.79	82355.16
10	10.91	13.47	56.14	2.74	13.36	12.42	0.81	75713.74
11	12.14	12.38	55.50	3.06	13.03	12.04	0.77	79870.91
12	13.83	13.26	69.67	2.90	13.20	12.80	0.79	72674.39
13	10.21	12.69	51.69	1.96	14.37	12.24	0.81	77084.54
14	10.32	12.31	51.70	1.55	15.49	11.93	0.82	77977.05
15	9.97	12.15	60.05	1.71	15.15	11.87	0.82	79062.38
16	9.90	12.03	53.30	1.61	15.21	11.80	0.81	79617.15
17	9.16	11.94	55.40	1.21	15.44	11.67	0.79	80530.13
18	10.14	12.06	43.25	2.14	14.81	11.36	0.78	83664.13
19	10.78	13.82	32.94	2.35	14.18	11.82	0.81	80413.84
20	9.12	12.75	46.49	2.05	14.06	12.34	0.81	75979.43
21	10.07	12.79	66.42	1.66	14.61	12.41	0.81	74840.60
22	10.88	12.78	53.37	1.78	16.33	11.12	0.81	84149.99
23	17.33	13.98	43.70	2.28	15.64	11.72	0.81	79017.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.77	12.81	50.83	2.26	14.51	11.98	0.77	78727.84
最 大 值	17.33	14.09	69.67	3.16	16.33	12.80	0.82	84149.99
發生時間	23	9	12	1	22	12		22
最 小 值	9.12	11.69	32.94	1.21	13.03	11.12	0.64	72674.39
發生時間	20	3	19	17	11	22		12
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	-0.01 %		-0.09	-0.01	0.40 %
全幅偏移(率)	1.55 %	0.86 %	0.16 %	-0.14 %		0.19	0.04	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A 報表日期: 115年01月29日

報表日期: 115年01月29日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.01	11.96	41.01	1.52	16.71	10.58	0.96	75253.28
1	11.11	11.97	42.12	2.57	16.58	10.55	0.97	75001.31
2	7.55	11.90	52.67	2.66	15.84	10.29	0.97	76777.48
3	8.96	11.70	51.98	2.79	15.02	10.67	0.97	73769.31
4	8.73	12.20	50.22	3.55	14.62	10.67	0.96	72842.29
5	9.50	11.89	54.48	3.54	14.74	10.53	0.96	73449.96
6	4.88	13.07	39.78	1.67	14.32	11.19	1.00	72509.41
7	10.51	12.62	49.82	2.17	14.86	11.08	1.00	74752.24
8	10.55	11.55	45.94	2.12	15.49	10.60	0.98	77074.47
9	9.12	11.87	43.59	2.06	14.92	10.88	0.97	74525.91
10	10.98	11.53	45.04	1.97	15.72	10.51	1.01	76145.29
11	9.38	11.40	44.88	2.01	15.80	10.33	0.98	74983.52
12	12.93	11.46	51.28	2.80	15.56	10.46	0.95	76493.07
13	9.11	12.04	48.47	1.67	15.51	10.99	0.96	72660.92
14	10.91	12.79	60.15	2.25	15.07	11.61	0.98	75847.02
15	10.87	12.66	51.00	2.46	14.20	11.59	0.99	77511.82
16	9.25	12.60	48.95	2.19	13.30	11.45	0.98	77351.85
17	9.01	12.86	50.36	2.11	13.82	11.45	0.96	76791.79
18	9.55	12.42	53.42	1.71	14.82	11.40	0.98	76718.66
19	10.90	12.19	50.36	1.76	15.80	11.05	1.00	80053.15
20	9.57	12.64	52.74	1.87	14.80	11.48	1.01	77202.83
21	9.91	12.83	62.09	1.49	15.94	11.56	1.01	76166.25
22	9.65	12.34	49.84	1.44	16.09	11.00	1.00	77299.68
23	9.43	12.05	55.67	1.44	17.38	10.77	0.99	77981.29
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.68	12.19	49.83	2.16	15.29	10.95	0.98	75798.45
最 大 值	12.93	13.07	62.09	3.55	17.38	11.61	1.02	80053.15
發生時間	12	6	21	4	23	14		19
最 小 值	4.88	11.40	39.78	1.44	13.30	10.29	0.94	72509.41
發生時間	6	11	6	22	16	2		6
零點偏移(率)	-0.09 %	-0.04 %	-0.05 %	-0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-0.89 %	0.33 %	0.52 %	-0.19 %		-0.14	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年01月29日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.30	11.65	48.96	1.49	16.30	9.34	1.46	72025.15
1	6.80	11.34	48.84	1.92	17.00	9.72	1.48	72844.75
2	7.77	11.53	53.95	2.44	15.03	9.98	1.47	72194.96
3	6.86	11.62	56.64	3.13	14.26	10.07	1.47	70807.36
4	8.85	11.21	50.65	3.05	14.31	9.97	1.46	70490.93
5	8.65	11.30	47.26	2.66	15.13	9.82	1.47	71401.45
6	8.11	11.27	55.94	2.81	14.89	10.25	1.48	70080.26
7	7.98	11.48	46.64	2.98	14.42	10.23	1.48	68880.02
8	8.61	11.42	47.14	2.64	14.62	10.34	1.49	72452.66
9	9.59	11.70	46.44	3.16	13.42	10.65	1.48	70175.55
10	8.74	11.59	48.17	2.43	14.61	10.38	1.48	71437.59
11	10.23	11.39	53.67	2.43	15.36	10.06	1.48	73258.42
12	10.43	12.21	46.51	3.18	14.49	9.97	1.47	71949.04
13	9.80	11.52	44.68	2.86	14.68	10.11	1.47	69368.30
14	9.50	10.94	45.75	2.72	14.59	9.82	1.46	71165.50
15	9.33	11.45	39.45	2.16	15.30	9.89	1.46	71338.59
16	9.78	11.30	49.22	2.61	14.25	10.10	1.47	72838.44
17	9.79	12.72	46.39	2.60	15.59	9.87	1.48	72426.36
18	8.58	11.99	34.74	0.85	16.16	9.33	1.45	68381.87
19	8.31	12.12	47.66	0.48	15.30	10.22	1.48	72155.96
20	9.37	12.33	52.96	1.40	15.58	9.79	1.48	74279.85
21	8.64	11.47	53.09	2.35	14.82	10.17	1.48	73437.30
22	9.19	11.68	49.56	2.42	14.38	10.20	1.48	72498.41
23	9.92	11.31	44.33	1.69	16.68	9.70	1.48	73064.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.92	11.61	48.28	2.35	15.05	10.00	1.47	71623.04
最 大 值	10.43	12.72	56.64	3.18	17.00	10.65	1.49	74279.85
發生時間	12	17	3	12	1	9		20
最 小 值	6.80	10.94	34.74	0.48	13.42	9.33	1.43	68381.87
發生時間	1	14	18	19	9	18		18
零點偏移(率)	-0.13 %	-0.05 %	-0.04 %	-0.01 %		-0.07	-0.01	0.10 %
全幅偏移(率)	-2.01 %	0.15 %	0.06 %	-0.16 %		0.20	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								