

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月14日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.78	4.21	39.87	0.51	17.57	11.61	1.06	81482.38
1	9.26	7.50	41.95	1.63	15.55	11.65	1.06	82620.99
2	9.20	6.15	44.79	1.20	16.05	11.77	1.06	81912.48
3	9.32	7.14	40.55	1.27	15.45	11.79	1.05	82097.34
4	8.97	7.61	46.54	0.85	16.05	11.80	1.04	81483.69
5	7.64	12.35	41.16	1.67	15.10	11.60	1.06	82354.04
6	9.55	12.30	42.50	2.01	14.44	11.93	1.06	81373.12
7	9.33	11.67	41.65	2.42	14.41	11.98	1.03	81310.76
8	9.44	7.83	44.27	1.64	15.49	11.55	1.04	83675.90
9	8.55	7.95	54.26	0.93	15.81	12.12	1.07	78306.73
10	9.11	7.42	43.83	0.71	16.00	11.76	1.07	80750.71
11	9.30	7.95	49.50	0.95	16.21	11.87	1.08	79826.48
12	9.28	7.46	45.11	0.97	16.70	11.42	1.05	83217.95
13	9.01	7.07	40.67	1.00	16.06	11.49	1.06	83053.40
14	9.78	6.72	49.26	1.21	15.82	11.67	1.09	82125.25
15	9.11	8.20	45.23	1.97	14.98	11.63	1.06	82995.28
16	8.34	11.95	44.82	1.82	15.38	11.91	1.06	80263.29
17	8.18	7.56	52.59	0.57	16.48	11.82	1.05	80455.31
18	6.47	8.73	62.04	0.83	15.99	12.19	1.08	77253.43
19	5.96	8.91	37.52	0.69	16.03	11.70	1.09	81377.56
20	5.61	8.23	42.29	0.65	16.37	11.85	1.07	79941.29
21	9.15	8.10	31.57	1.08	17.08	11.32	1.05	84069.88
22	8.20	7.53	36.60	1.53	16.67	11.35	1.08	83872.73
23	10.24	7.85	42.71	2.08	15.85	11.61	1.06	82958.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.57	8.27	44.22	1.26	15.90	11.72	1.06	81615.79
最 大 值	10.24	12.35	62.04	2.42	17.57	12.19	1.10	84069.88
發生時間	23	5	18	7	0	18		21
最 小 值	5.61	4.21	31.57	0.51	14.41	11.32	1.02	77253.43
發生時間	20	0	21	0	7	21		18
零點偏移(率)	0.00 %	0.00 %	-0.02 %	0.01 %		-0.04		0.20 %
全幅偏移(率)	0.02 %	0.41 %	-0.00 %	0.31 %		-0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月14日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	2.69	3.47	35.07	0.29	17.08	9.39	1.09	85113.66
1	2.20	3.50	50.26	0.55	15.18	10.29	1.09	78455.45
2	2.21	3.43	52.13	0.51	16.44	10.15	1.10	81218.31
3	2.41	5.66	51.42	0.78	15.64	10.47	1.10	80353.56
4	2.72	4.77	52.38	0.87	14.58	10.42	1.10	80702.04
5	2.16	4.64	56.59	0.90	14.32	10.72	1.09	78791.70
6	1.99	8.10	57.46	1.10	14.17	10.58	1.09	81049.79
7	0.09	6.50	55.49	0.90	14.94	10.28	1.09	79135.04
8	2.16	4.29	58.99	1.24	14.37	10.65	1.09	81632.94
9	2.42	4.62	58.84	1.25	14.47	10.63	1.11	82079.64
10	2.78	4.57	54.67	1.06	15.11	10.32	1.13	82699.93
11	1.22	4.72	55.04	0.96	15.20	10.19	1.12	81617.13
12	3.39	5.83	49.12	1.51	14.68	10.15	1.11	81305.13
13	4.37	22.04	52.52	2.48	14.01	10.45	1.16	77955.39
14	2.58	9.76	54.78	1.76	14.25	10.55	1.10	77087.81
15	2.03	8.08	55.02	1.23	14.70	10.36	1.10	79825.81
16	1.34	1.42	51.52	1.16	15.12	10.15	1.12	82080.09
17	2.04	8.19	50.36	1.11	15.24	10.03	1.10	80085.85
18	3.22	4.68	47.84	0.76	15.46	9.96	1.09	76086.77
19	3.52	3.08	46.56	0.86	15.50	9.94	1.09	76379.24
20	3.54	5.22	41.58	0.86	15.86	9.75	1.09	78021.14
21	3.25	3.27	47.50	0.57	16.27	9.94	1.09	77601.63
22	3.18	6.01	42.26	0.89	15.46	9.80	1.09	78169.33
23	3.24	3.59	46.83	1.11	14.57	10.12	1.09	75675.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.53	5.81	51.01	1.03	15.11	10.22	1.10	79713.46
最 大 值	4.37	22.04	58.99	2.48	17.08	10.72	1.24	85113.66
發生時間	13	13	8	13	0	5		0
最 小 值	0.09	1.42	35.07	0.29	14.01	9.39	1.09	75675.55
發生時間	7	16	0	0	13	0		23
零點偏移(率)	-0.12 %	-0.01 %	-0.04 %	0.01 %		0.04		-0.10 %
全幅偏移(率)	-0.13 %	0.26 %	-0.29 %	-0.03 %		0.13		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								