

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月20日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.10	5.90	68.82	1.94	15.07	12.87	1.07	65816.60
1	0.00	9.69	65.72	2.35	14.15	13.36	1.10	63555.20
2	3.14	2.34	42.01	1.73	16.35	10.84	1.03	86349.62
3	14.04	2.03	45.37	2.52	16.16	10.59	1.04	87603.21
4	10.07	6.89	58.07	2.62	15.48	11.14	1.04	83347.66
5	11.06	3.43	61.42	2.17	16.88	10.35	1.04	88771.57
6	9.51	3.51	46.74	2.57	15.49	11.04	1.04	84097.78
7	6.76	4.98	56.91	2.16	15.49	11.65	1.03	78977.42
8	9.07	7.79	53.03	2.53	14.86	11.58	1.04	79909.37
9	9.39	3.13	49.71	2.22	15.59	11.10	1.04	83654.20
10	7.05	7.40	48.13	2.87	14.01	11.43	1.05	82348.59
11	6.66	3.18	50.47	2.49	15.91	10.83	1.04	85982.63
12	4.94	1.25	42.06	2.32	15.76	10.79	1.04	85913.02
13	2.70	1.38	41.65	2.67	15.44	10.98	1.04	84291.50
14	3.90	4.52	46.55	2.41	15.99	10.73	1.04	86035.39
15	9.01	2.32	56.31	2.62	16.15	10.82	1.04	85122.48
16	6.72	5.15	58.67	3.40	14.77	10.72	1.04	84703.73
17	4.97	2.15	66.79	1.74	16.91	11.18	1.04	81536.75
18	8.31	1.98	48.27	1.81	18.34	9.66	1.04	91879.95
19	11.49	2.03	58.48	2.31	16.66	9.98	1.04	91681.36
20	6.57	2.14	59.59	1.64	17.12	10.50	1.04	86529.79
21	2.29	1.39	55.78	1.67	16.61	11.20	1.04	81500.93
22	0.66	2.76	60.14	1.91	15.76	12.19	1.04	74146.49
23	2.64	5.38	57.78	1.76	16.10	11.68	1.04	78265.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.29	3.86	54.10	2.27	15.88	11.13	1.04	82584.18
最 大 值	14.04	9.69	68.82	3.40	18.34	13.36	1.17	91879.95
發生時間	3	1	0	16	18	1		18
最 小 值	0.00	1.25	41.65	1.64	14.01	9.66	1.02	63555.20
發生時間	1	12	13	20	10	18		1
零點偏移(率)	-0.08 %	0.00 %	-0.14 %	-0.01 %		-0.07		-0.20 %
全幅偏移(率)	0.14 %	1.32 %	-0.07 %	0.17 %		-0.16		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月20日

[illegible]