

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.30	5.71	51.51	1.61	16.22	11.85	0.97	79860.87
1	2.03	3.00	44.12	1.61	16.72	11.61	0.97	78949.92
2	1.97	2.95	43.11	2.29	14.82	12.10	0.97	77111.84
3	3.17	2.81	46.84	1.91	15.90	11.91	0.97	77714.43
4	2.77	3.51	58.83	1.31	16.12	11.84	0.97	79811.23
5	2.23	3.44	50.75	1.11	16.40	11.91	1.01	75942.32
6	1.75	2.87	47.53	1.48	16.92	11.73	1.02	80781.37
7	1.37	2.85	60.26	0.52	17.98	11.36	1.02	82460.65
8	3.22	2.68	43.82	1.61	15.90	11.72	1.02	81114.44
9	2.03	2.74	33.09	1.43	16.05	11.99	1.04	76658.05
10	0.46	2.76	45.17	0.47	17.72	11.33	1.04	80395.00
11	1.77	2.77	42.40	1.41	16.05	11.97	1.02	77519.51
12	2.06	2.87	62.64	0.70	16.51	12.33	1.05	75240.51
13	3.28	3.32	42.15	1.41	15.94	12.14	1.04	77187.50
14	2.90	2.84	38.64	1.46	15.70	11.95	1.02	78741.80
15	2.69	6.61	43.87	2.60	14.35	12.74	1.02	70120.60
16	4.06	2.75	43.99	1.43	15.94	12.03	1.03	77845.28
17	4.38	2.57	45.28	1.29	16.61	11.53	1.06	81542.55
18	8.31	2.75	43.96	1.86	16.24	11.92	1.06	79378.83
19	3.05	2.23	49.64	0.75	17.86	11.32	1.05	83479.15
20	0.63	2.82	52.84	0.47	18.13	11.42	1.04	81971.03
21	0.29	4.01	42.19	1.34	16.04	11.84	1.03	80506.97
22	2.50	5.76	49.51	1.64	16.28	12.00	1.02	78752.20
23	2.38	5.85	61.11	1.20	16.65	12.46	1.04	74430.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.61	3.44	47.64	1.37	16.38	11.87	1.02	78646.51
最 大 值	8.31	6.61	62.64	2.60	18.13	12.74	1.06	83479.15
發生時間	18	15	12	15	20	15		19
最 小 值	0.29	2.23	33.09	0.47	14.35	11.32	0.97	70120.60
發生時間	21	19	9	10	15	19		15
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	0.00 %		-0.07		0.00 %
全幅偏移(率)	0.00 %	0.00 %	-0.02 %	-0.01 %		-0.12		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年08月15日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.49	9.86	42.42	1.93	14.07	11.29	1.15	71913.72
1	9.09	3.88	44.07	1.48	15.49	11.04	1.15	71981.73
2	13.47	2.37	40.59	2.13	14.80	10.79	1.15	72611.46
3	7.43	2.23	40.96	0.99	15.87	10.62	1.15	74338.17
4	9.48	2.27	38.30	1.05	15.92	10.68	1.15	74735.20
5	5.33	2.14	57.97	0.71	16.56	10.78	1.16	78257.78
6	4.21	2.75	42.21	0.85	15.55	11.17	1.18	77704.25
7	8.39	2.74	53.85	1.35	16.45	10.80	1.16	77050.56
8	6.07	2.23	47.97	0.78	16.67	10.57	1.11	76541.50
9	6.91	2.80	42.51	1.22	14.99	11.04	1.10	73662.58
10	1.92	2.12	55.71	0.65	16.96	10.57	1.10	75929.06
11	2.96	2.45	53.48	0.95	15.75	11.04	1.14	73748.29
12	4.17	2.51	54.39	1.00	15.37	11.35	1.13	72107.21
13	1.86	2.10	55.90	0.51	16.18	11.26	1.13	70365.64
14	3.61	3.14	42.57	0.55	15.71	10.75	1.16	74363.66
15	2.78	2.27	49.15	1.57	13.69	11.84	1.12	64342.49
16	1.43	4.23	53.60	0.65	16.15	10.57	1.16	74008.47
17	4.50	2.30	51.16	2.61	12.68	11.49	1.16	71228.08
18	5.65	1.20	56.26	1.26	15.91	11.19	1.17	74315.81
19	6.70	2.23	64.08	0.62	17.75	10.62	1.16	80388.29
20	3.37	3.81	40.36	0.58	17.22	10.74	1.16	79837.21
21	3.05	5.46	56.09	0.80	16.31	10.87	1.16	78866.12
22	3.55	5.16	68.48	0.44	17.30	11.08	1.17	78281.99
23	2.79	5.94	53.22	0.38	16.75	11.18	1.16	77450.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.43	3.26	50.22	1.04	15.84	10.97	1.15	74751.26
最 大 值	13.47	9.86	68.48	2.61	17.75	11.84	1.18	80388.29
發生時間	2	0	22	17	19	15		19
最 小 值	1.43	1.20	38.30	0.38	12.68	10.57	1.10	64342.49
發生時間	16	18	4	23	17	8		15
零點偏移(率)	-0.06 %	-0.06 %	-0.03 %	0.00 %		-0.08		-0.10 %
全幅偏移(率)	0.02 %	0.24 %	-0.16 %	0.34 %		0.30		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								