

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.17	8.60	45.58	6.13	13.92	12.56	1.47	69139.81
1	8.87	3.29	56.60	4.11	16.67	12.27	1.51	72226.98
2	9.75	4.62	56.59	5.01	14.73	12.66	1.50	70916.69
3	9.35	2.83	61.22	4.87	15.05	12.60	1.46	71965.95
4	9.25	10.18	50.66	5.81	13.97	12.81	1.45	69394.05
5	10.06	8.95	52.37	6.45	13.70	12.72	1.41	68223.86
6	8.83	6.97	54.91	5.56	14.45	12.73	1.42	69332.13
7	10.45	8.78	52.24	6.75	13.99	12.73	1.44	69064.93
8	9.78	2.34	58.26	5.08	15.21	12.52	1.46	69656.63
9	9.50	2.88	54.00	5.65	14.55	12.65	1.43	68790.70
10	9.53	1.40	54.74	4.97	16.13	11.97	1.42	71034.99
11	8.90	4.88	42.98	6.25	13.74	12.40	1.39	66643.80
12	7.46	7.82	47.55	7.38	14.01	12.69	1.40	63734.55
13	10.29	8.94	58.14	5.87	15.35	12.18	1.41	66737.91
14	9.27	13.02	34.67	8.96	13.27	12.29	1.37	63042.76
15	4.24	5.59	52.16	6.60	12.59	12.81	1.35	62199.78
16	5.29	10.67	56.96	8.01	11.12	13.13	1.31	61573.14
17	8.17	3.50	40.53	6.76	13.28	12.28	1.29	63844.17
18	10.37	2.81	48.76	6.33	13.81	12.37	1.32	65290.00
19	10.87	1.57	46.17	5.53	14.44	12.09	1.35	66275.52
20	15.62	3.85	47.25	8.15	14.02	12.05	1.35	65778.18
21	10.49	3.11	45.86	5.95	13.98	12.11	1.33	65461.92
22	10.20	4.28	44.33	6.05	13.76	12.04	1.40	66328.01
23	7.65	5.11	42.38	6.72	12.79	12.58	1.37	62517.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.35	5.67	50.20	6.21	14.11	12.47	1.40	67048.92
最大值	15.62	13.02	61.22	8.96	16.67	13.13	1.56	72226.98
發生時間	20	14	3	14	1	16		1
最小值	4.24	1.40	34.67	4.11	11.12	11.97	1.28	61573.14
發生時間	15	10	14	1	16	10		16
零點偏移(率)	-0.01 %	-0.01 %	-0.02 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	3.74 %	-0.09 %	0.14 %	0.15 %		-0.08	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.20	2.67	50.34	2.02	19.47	9.89	1.36	82555.54
1	6.37	1.79	57.24	1.80	21.30	9.69	1.38	87743.04
2	8.37	1.76	51.74	2.28	19.87	9.93	1.38	86759.73
3	9.01	1.83	53.76	3.12	19.33	9.78	1.38	87044.18
4	9.62	2.06	50.23	2.76	19.46	9.85	1.38	85687.39
5	12.23	3.96	49.58	3.05	18.51	10.12	1.38	87109.98
6	9.91	7.38	50.24	2.64	20.70	9.20	1.38	90544.91
7	9.48	3.52	54.09	2.40	20.40	9.52	1.38	87246.08
8	9.58	1.35	47.58	2.74	20.56	9.27	1.37	86765.55
9	9.88	1.46	54.25	2.30	21.31	9.39	1.38	87512.14
10	8.40	3.72	43.51	2.92	20.77	8.68	1.38	85332.58
11	8.40	4.91	41.47	3.75	19.27	9.11	1.37	83225.18
12	10.93	4.26	44.21	4.91	19.02	9.20	1.36	83326.36
13	9.87	4.63	47.96	3.76	18.43	8.99	1.37	80563.70
14	9.43	4.99	47.23	3.93	17.94	8.65	1.38	79755.14
15	11.25	5.19	51.24	3.80	16.09	9.18	1.36	79246.32
16	9.92	5.55	38.45	2.31	18.96	8.38	1.38	83534.14
17	9.55	3.04	42.36	2.51	16.56	9.37	1.39	81778.19
18	10.77	4.59	50.66	2.33	18.12	9.52	1.38	83457.80
19	13.26	4.28	41.17	3.05	15.96	10.07	1.39	78284.22
20	12.81	1.56	55.23	2.23	18.79	9.66	1.39	79293.08
21	9.98	1.39	63.48	1.86	18.66	9.21	1.39	80700.22
22	10.72	6.57	47.84	3.76	16.29	9.69	1.38	82058.75
23	9.04	1.25	51.51	2.54	17.38	9.67	1.39	80744.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.87	3.49	49.39	2.87	18.88	9.42	1.38	83761.20
最大值	13.26	7.38	63.48	4.91	21.31	10.12	1.43	90544.91
發生時間	19	6	21	12	9	5		6
最小值	6.37	1.25	38.45	1.80	15.96	8.38	1.34	78284.22
發生時間	1	23	16	1	19	16		19
零點偏移(率)	-0.05 %	0.00 %	-0.09 %	-0.02 %		0.01	0.00	0.00 %
全幅偏移(率)	1.29 %	0.70 %	-0.03 %	0.36 %		0.18	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.81	2.50	52.71	2.40	18.18	10.65	1.38	82476.76
1	8.22	4.17	49.16	2.64	17.98	10.58	1.38	84949.28
2	6.83	3.40	43.85	2.60	17.48	10.23	1.36	82848.62
3	7.85	7.60	49.00	3.27	17.46	10.02	1.36	86495.47
4	8.14	4.88	48.29	2.91	17.77	10.10	1.37	85867.94
5	10.43	1.70	52.02	2.66	18.20	10.26	1.37	84385.86
6	10.37	3.84	55.79	3.00	17.80	10.19	1.37	85343.27
7	7.08	3.08	53.93	2.83	18.10	10.01	1.39	78665.39
8	10.07	1.64	51.47	3.00	16.47	10.30	1.39	83048.19
9	7.53	1.50	58.75	2.59	17.70	10.26	1.39	83966.26
10	6.92	3.25	56.83	2.67	19.03	9.65	1.38	88336.69
11	4.41	3.70	50.48	2.18	16.54	10.38	1.41	83217.80
12	5.26	3.78	56.73	3.05	15.87	10.62	1.43	81109.28
13	4.51	7.20	55.56	3.46	13.90	10.52	1.39	77070.34
14	5.19	5.78	50.97	3.74	12.96	10.51	1.37	77312.51
15	5.94	5.23	54.41	3.68	14.18	10.60	1.40	76801.31
16	5.70	3.45	56.61	2.80	15.12	10.32	1.39	81724.52
17	10.40	3.66	54.70	2.68	16.14	10.16	1.38	83831.13
18	11.45	8.43	47.42	3.47	16.52	9.86	1.37	81613.34
19	10.94	11.44	46.18	2.75	16.72	9.83	1.37	80050.86
20	22.75	19.43	54.30	6.53	14.06	10.72	1.37	75535.57
21	11.93	5.69	44.55	7.71	14.59	10.67	1.38	75475.76
22	10.51	1.74	43.52	3.56	15.48	10.14	1.38	79824.23
23	9.99	5.69	45.44	2.40	17.23	9.75	1.36	81761.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.68	5.12	51.36	3.27	16.48	10.26	1.38	81738.00
最大值	22.75	19.43	58.75	7.71	19.03	10.72	1.43	88336.69
發生時間	20	20	9	21	10	20		10
最小值	4.41	1.50	43.52	2.18	12.96	9.65	1.34	75475.76
發生時間	11	9	22	11	14	10		21
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.05 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.78 %	0.46 %	-0.21 %	0.18 %		-0.14	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								