

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月20日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.18	1.98	51.87	1.52	17.38	11.48	1.29	82792.74
1	6.14	3.97	59.96	0.83	20.52	10.74	1.29	85558.33
2	8.25	3.85	49.29	1.86	16.68	11.25	1.28	85056.28
3	8.15	3.55	47.67	2.35	15.28	11.74	1.27	81961.49
4	6.28	3.40	54.06	2.02	15.94	11.79	1.26	81648.38
5	7.17	2.64	47.25	2.14	15.74	11.61	1.26	86280.03
6	5.49	5.37	50.37	2.36	15.93	11.69	1.28	81023.71
7	7.60	2.42	53.54	2.29	15.84	11.46	1.29	80804.23
8	7.31	2.64	53.10	1.87	15.96	11.53	1.28	81520.88
9	3.81	2.47	54.27	1.03	15.49	11.72	1.27	81038.61
10	6.55	4.75	56.09	1.18	16.03	11.43	1.24	80749.30
11	6.16	4.32	43.63	1.53	17.29	10.54	1.23	81169.91
12	7.36	3.14	47.56	1.81	16.68	10.78	1.24	82002.60
13	3.64	4.75	48.75	2.67	14.99	11.33	1.27	78367.84
14	4.55	4.21	48.16	2.18	14.37	11.30	1.28	77823.08
15	5.17	2.97	48.02	1.42	15.19	11.23	1.28	77598.32
16	8.45	2.54	45.71	1.27	15.61	11.06	1.28	79104.27
17	8.70	3.13	51.15	1.31	16.41	11.14	1.27	82731.67
18	9.01	3.15	55.63	1.27	16.14	11.45	1.29	82219.26
19	9.41	2.75	50.04	1.40	15.83	11.41	1.29	82198.94
20	9.43	3.16	51.02	1.47	15.34	11.54	1.29	81079.85
21	11.48	6.34	50.16	1.96	13.92	11.87	1.29	77626.49
22	9.59	3.91	53.47	1.49	14.14	11.86	1.29	78128.83
23	9.06	2.78	56.20	1.46	15.65	11.73	1.28	79577.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.29	3.51	51.12	1.70	15.93	11.40	1.27	81169.26
最 大 值	11.48	6.34	59.96	2.67	20.52	11.87	1.30	86280.03
發生時間	21	21	1	13	1	21		5
最 小 值	3.64	1.98	43.63	0.83	13.92	10.54	1.23	77598.32
發生時間	13	0	11	1	21	11		15
零點偏移(率)	-0.16 %	-0.03 %	-0.02 %	-0.01 %		0.00		0.30 %
全幅偏移(率)	0.00 %	0.24 %	-0.32 %	-0.26 %		-0.25		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月20日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.99	2.08	50.04	0.72	15.55	11.25	1.10	81961.96
1	2.84	3.20	62.28	2.05	16.93	10.87	1.10	81577.53
2	8.52	9.57	42.60	2.13	16.40	10.21	1.10	84811.34
3	8.35	2.21	48.40	2.46	15.82	10.40	1.09	83926.35
4	3.87	3.36	54.95	2.53	14.90	10.79	1.09	78624.11
5	1.22	2.64	60.20	2.40	14.30	10.60	1.09	80194.36
6	0.59	1.29	60.53	1.52	15.98	10.45	1.10	77954.38
7	5.28	1.20	50.26	2.55	15.19	10.48	1.10	80276.35
8	6.15	1.25	53.25	3.12	14.10	10.87	1.10	79063.77
9	5.36	1.39	59.09	2.70	14.42	11.00	1.07	78692.14
10	6.41	4.25	56.11	2.74	14.13	10.77	1.06	80680.24
11	7.71	1.11	57.38	2.81	13.87	10.76	1.06	82930.25
12	2.20	2.88	53.21	1.35	14.16	10.96	1.06	80794.85
13	6.64	4.25	42.01	1.16	13.48	10.92	1.09	78781.44
14	8.02	1.88	46.82	1.33	12.92	11.13	1.10	77710.09
15	8.02	3.47	45.54	1.24	14.20	11.05	1.10	77982.00
16	8.31	2.09	38.50	0.92	15.41	10.76	1.10	81114.44
17	8.32	5.19	44.45	1.01	15.92	10.25	1.09	80552.99
18	5.58	4.42	39.62	1.22	14.56	10.35	1.09	78995.96
19	4.26	6.27	39.53	1.11	14.20	10.39	1.09	76926.98
20	5.82	7.37	40.45	1.36	13.68	10.71	1.09	76066.17
21	10.06	3.74	41.30	1.20	14.99	10.50	1.09	78447.39
22	9.48	3.37	46.15	1.40	15.74	10.36	1.07	78993.65
23	6.97	5.23	56.32	2.24	17.29	9.78	1.06	83168.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.96	3.49	49.54	1.80	14.92	10.65	1.09	80009.46
最 大 值	10.06	9.57	62.28	3.12	17.29	11.25	1.10	84811.34
發生時間	21	2	1	8	23	0		2
最 小 值	0.59	1.11	38.50	0.72	12.92	9.78	1.06	76066.17
發生時間	6	11	16	0	14	23		20
零點偏移(率)	-0.13 %	-0.01 %	-0.03 %	-0.01 %		0.00		0.10 %
全幅偏移(率)	0.14 %	0.64 %	-0.41 %	0.37 %		-0.27		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

