

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.70	3.87	55.75	2.20	17.34	12.09	1.43	69591.99
1	8.09	7.36	60.40	2.64	16.53	12.30	1.43	68765.82
2	8.79	3.39	55.69	2.28	17.19	11.69	1.42	73039.76
3	8.31	4.06	47.01	2.62	16.43	11.99	1.42	71253.85
4	10.45	6.13	46.75	3.16	15.44	11.84	1.44	73127.93
5	0.08	7.70	60.21	1.75	17.93	11.95	1.47	65980.83
6	0.20	3.66	58.88	1.55	18.46	11.58	1.46	73115.67
7	0.65	6.15	55.57	2.02	17.09	12.56	1.49	66221.45
8	0.13	12.77	63.34	2.31	16.77	13.04	1.61	63031.46
9	0.16	3.41	50.79	2.70	15.77	13.61	1.48	59943.41
10	0.20	2.31	45.52	2.24	16.43	12.63	1.49	66455.86
11	2.79	9.42	39.78	2.94	14.95	12.13	1.49	71132.44
12	10.53	2.25	54.19	3.33	15.50	12.07	1.51	71079.47
13	7.00	2.03	59.78	3.39	14.82	12.41	1.51	68691.16
14	11.17	2.41	56.02	3.23	16.46	11.91	1.51	71298.70
15	10.09	6.96	55.88	3.88	14.66	12.55	1.51	68480.85
16	10.77	2.25	63.47	2.68	15.71	11.98	1.51	71760.41
17	10.50	2.42	46.28	3.09	15.59	12.30	1.51	69610.42
18	10.86	1.69	57.17	2.36	16.72	11.93	1.50	71996.86
19	9.70	1.67	52.00	2.47	16.29	11.90	1.48	72709.56
20	11.35	1.80	55.03	2.73	16.09	12.09	1.46	71775.91
21	10.78	1.94	55.77	2.63	16.38	11.88	1.46	72551.24
22	9.66	3.56	50.05	2.68	16.10	12.12	1.46	70832.02
23	10.18	3.96	58.58	2.52	16.50	12.27	1.46	69024.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.01	4.30	54.33	2.64	16.30	12.20	1.48	69644.66
最大值	11.35	12.77	63.47	3.88	18.46	13.61	2.11	73127.93
發生時間	20	8	16	15	6	9		4
最小值	0.08	1.67	39.78	1.55	14.66	11.58	1.41	59943.41
發生時間	5	19	11	6	15	6		9
零點偏移(率)	-0.09 %	-0.01 %	-0.04 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	-1.30 %	0.06 %	-0.39 %	-0.03 %		0.14	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.83	8.13	50.83	1.86	19.11	9.95	1.47	88644.73
1	8.81	2.61	51.71	1.68	18.51	10.57	1.49	83179.31
2	9.17	2.40	50.06	1.76	18.49	10.23	1.48	85171.78
3	9.81	3.57	53.73	2.37	17.08	10.74	1.45	81758.17
4	9.59	2.46	49.20	2.44	17.43	10.33	1.45	83138.60
5	8.43	9.26	55.04	2.44	17.31	10.48	1.45	85055.65
6	7.80	9.95	47.58	1.77	19.36	9.63	1.44	83611.88
7	3.66	5.23	38.96	1.54	18.08	10.21	1.43	81272.16
8	4.26	3.82	49.01	1.65	17.87	10.68	1.45	80553.32
9	5.58	4.63	42.64	1.91	18.05	10.05	1.49	84015.41
10	9.61	3.92	47.19	2.42	17.16	10.38	1.49	82503.83
11	9.34	3.41	47.85	2.39	17.08	10.30	1.47	80156.97
12	9.92	6.49	45.25	2.51	16.63	10.43	1.45	78973.31
13	11.06	6.03	65.89	2.61	16.73	10.53	1.44	81729.83
14	10.52	4.80	43.32	3.36	16.46	10.52	1.42	77160.23
15	9.27	4.84	41.82	2.59	16.58	10.47	1.43	76725.44
16	10.78	3.46	57.73	2.00	17.56	10.17	1.44	86389.95
17	10.80	3.85	64.35	2.14	17.21	10.54	1.46	83917.29
18	10.08	4.59	49.40	2.05	17.86	10.58	1.48	83301.06
19	10.27	4.08	54.26	1.79	18.03	10.69	1.49	84015.67
20	9.43	3.74	53.72	1.96	17.34	10.58	1.49	84565.72
21	10.73	5.27	55.89	2.28	16.78	10.53	1.46	81529.01
22	9.54	3.69	53.58	2.02	17.64	10.57	1.46	81625.82
23	11.29	3.74	48.18	2.14	18.26	10.25	1.46	83727.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.02	4.75	50.72	2.15	17.61	10.39	1.46	82613.43
最大值	11.29	9.95	65.89	3.36	19.36	10.74	1.50	88644.73
發生時間	23	6	13	14	6	3		0
最小值	3.66	2.40	38.96	1.54	16.46	9.63	1.41	76725.44
發生時間	7	2	7	7	14	6		15
零點偏移(率)	-0.01 %	0.00 %	-0.12 %	-0.01 %		-0.07	0.00	0.00 %
全幅偏移(率)	1.39 %	-0.20 %	-0.07 %	0.15 %		-0.07	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.00	5.55	39.30	1.62	17.84	11.08	1.42	86365.78
1	0.01	4.31	39.86	1.52	18.43	11.15	1.41	85209.62
2	0.73	9.40	33.91	1.25	18.36	10.37	1.41	91328.12
3	3.83	8.98	53.32	1.50	17.25	10.76	1.40	88386.28
4	8.46	11.29	51.06	2.33	16.29	10.79	1.40	88208.11
5	10.27	5.67	58.05	2.25	17.16	10.74	1.39	89391.30
6	8.13	4.65	60.39	1.90	17.52	10.62	1.38	90115.20
7	9.60	7.77	48.19	1.45	17.93	10.38	1.42	99262.27
8	9.22	2.51	60.88	1.46	17.43	11.00	1.43	85715.89
9	7.20	2.75	57.16	1.40	19.12	10.28	1.43	90197.98
10	7.71	6.70	43.95	1.65	15.92	10.79	1.43	84572.36
11	9.92	5.30	52.28	2.88	14.52	11.20	1.43	79946.53
12	10.46	10.88	42.56	2.62	14.84	10.97	1.43	77542.50
13	11.45	3.58	50.31	2.04	15.79	10.84	1.43	79705.52
14	12.14	3.91	49.97	2.35	14.96	10.81	1.43	79306.82
15	9.90	3.75	54.57	2.49	14.79	11.67	1.43	76651.09
16	10.01	3.33	56.21	2.47	16.09	10.51	1.43	81422.61
17	9.83	2.26	57.40	2.16	15.59	10.60	1.42	83516.20
18	8.20	3.06	54.03	1.72	15.47	11.24	1.43	80394.96
19	7.54	3.13	63.26	1.36	16.78	11.19	1.43	80329.64
20	9.81	6.15	47.10	1.65	16.07	10.75	1.43	83770.98
21	9.06	6.09	49.44	1.52	16.55	10.36	1.43	81238.84
22	9.13	8.08	49.80	1.70	15.32	10.82	1.43	78568.24
23	8.43	6.52	62.27	1.81	15.68	11.27	1.43	80420.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.21	5.65	51.47	1.88	16.49	10.84	1.42	84231.99
最大值	12.14	11.29	63.26	2.88	19.12	11.67	1.46	99262.27
發生時間	14	4	19	11	9	15		7
最小值	0.01	2.26	33.91	1.25	14.52	10.28	1.38	76651.09
發生時間	1	17	2	2	11	9		15
零點偏移(率)	-0.01 %	0.00 %	-0.27 %	-0.03 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.19 %	0.33 %	-0.28 %	0.22 %		0.13	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								