

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.51	13.05	61.11	2.93	17.49	11.32	1.18	73568.03
1	4.77	12.99	55.91	2.69	17.45	11.39	1.18	73244.23
2	15.52	12.90	58.94	3.89	17.32	11.35	1.18	73674.04
3	6.56	12.54	55.32	1.87	18.49	10.95	1.18	75961.28
4	5.44	12.90	52.15	1.79	16.71	11.35	1.19	74349.60
5	8.32	12.55	51.29	2.16	17.78	10.99	1.20	77163.12
6	8.93	12.95	53.66	2.32	17.13	11.47	1.20	73029.61
7	8.37	13.22	62.17	2.18	16.29	11.68	1.20	72636.35
8	9.25	13.21	59.67	2.02	15.93	11.81	1.20	71267.83
9	13.57	13.15	60.37	2.10	16.14	11.75	1.20	72314.03
10	13.55	12.80	65.11	1.68	16.99	11.39	1.21	73612.52
11	8.66	12.97	45.38	2.23	16.52	11.50	1.22	72838.79
12	7.85	13.20	49.52	2.61	16.39	11.71	1.21	71430.71
13	14.22	13.31	53.22	3.44	15.70	11.83	1.19	71247.54
14	12.77	13.47	59.22	3.18	16.81	11.66	1.18	71483.81
15	11.26	13.29	54.95	2.47	16.11	11.77	1.19	70969.80
16	8.46	13.45	62.99	2.32	16.68	11.83	1.20	70387.24
17	4.43	13.32	66.01	1.75	17.00	11.65	1.21	71459.34
18	1.17	12.48	60.15	0.81	18.57	10.87	1.21	75627.84
19	1.16	12.52	58.96	0.86	18.31	10.94	1.21	75491.22
20	1.09	13.20	61.89	0.63	19.13	11.22	1.20	72738.05
21	3.81	12.85	50.76	1.09	17.39	11.25	1.18	74878.63
22	12.68	13.13	50.79	1.23	17.38	11.42	1.18	73305.43
23	15.45	13.16	60.81	1.02	18.64	11.05	1.18	74778.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.78	13.03	57.10	2.05	17.18	11.42	1.19	73227.41
最大值	15.52	13.47	66.01	3.89	19.13	11.83	1.25	77163.12
發生時間	2	14	17	2	20	13		5
最小值	1.09	12.48	45.38	0.63	15.70	10.87	1.18	70387.24
發生時間	20	18	11	20	13	18		16
零點偏移(率)	-0.06 %	0.00 %	-0.32 %	-0.00 %		-0.09	-0.01	0.20 %
全幅偏移(率)	1.82 %	0.32 %	0.84 %	-0.33 %		-0.16	0.10	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.37	13.64	50.20	1.21	16.51	10.73	1.07	79781.69
1	10.11	13.59	52.37	1.04	18.79	10.39	1.06	81468.19
2	7.74	13.73	45.61	0.97	17.66	10.63	1.04	79453.53
3	9.37	13.81	53.06	1.41	16.83	10.76	1.03	79704.62
4	10.49	13.86	67.28	1.46	16.59	10.90	1.02	78381.71
5	9.45	13.68	57.23	1.30	17.92	10.59	1.02	81046.74
6	5.68	12.50	58.95	1.74	17.20	10.92	1.02	84258.22
7	10.76	11.89	55.75	2.13	17.29	10.56	1.02	79289.85
8	8.37	11.91	62.23	1.49	17.50	10.65	1.03	80409.89
9	11.46	11.92	60.53	1.77	17.68	10.49	1.03	82227.77
10	9.08	12.34	56.73	2.04	16.35	11.10	1.03	77903.84
11	11.21	12.61	55.69	1.58	17.00	10.74	1.02	78662.97
12	12.07	12.97	62.98	1.23	17.58	10.51	1.03	78889.40
13	9.42	13.04	60.46	2.06	16.97	10.50	1.04	78990.85
14	12.45	13.19	59.60	2.09	16.77	10.73	1.04	78189.96
15	9.19	11.88	57.14	1.24	17.31	10.64	1.05	77816.83
16	11.70	11.82	49.82	1.94	16.59	10.18	1.02	76808.88
17	10.93	11.96	53.61	1.06	17.80	10.47	1.03	77504.94
18	11.58	12.38	51.78	0.69	17.83	10.52	1.04	78343.29
19	9.98	11.48	66.15	0.54	19.46	9.94	1.04	83215.93
20	11.67	12.50	50.58	1.11	17.19	11.17	1.05	78075.01
21	13.16	12.10	49.67	1.39	17.73	10.58	1.05	79514.15
22	8.16	11.73	53.81	1.73	17.63	10.46	1.04	79991.30
23	8.84	11.85	52.44	1.17	18.53	10.32	1.04	81465.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.05	12.60	55.99	1.43	17.45	10.60	1.04	79641.46
最大值	13.16	13.86	67.28	2.13	19.46	11.17	1.09	84258.22
發生時間	21	4	4	7	19	20		6
最小值	5.68	11.48	45.61	0.54	16.35	9.94	1.02	76808.88
發生時間	6	19	2	19	10	19		16
零點偏移(率)	-0.08 %	-0.01 %	-0.10 %	-0.01 %		-0.06	-0.01	0.00 %
全幅偏移(率)	0.13 %	-2.02 %	-0.34 %	-1.76 %		-0.13	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.29	13.50	59.11	2.89	17.63	9.74	1.31	73411.49
1	10.49	13.47	54.71	2.80	18.42	9.70	1.32	72104.95
2	10.23	13.57	49.47	2.83	19.20	9.06	1.32	74066.59
3	10.10	13.35	60.33	2.68	17.43	9.67	1.34	74616.32
4	9.80	12.90	50.47	2.55	17.08	9.48	1.34	73291.25
5	9.70	12.96	49.09	2.47	16.89	9.41	1.34	73877.85
6	9.86	12.87	51.66	2.54	17.65	9.31	1.35	74507.37
7	7.18	10.76	55.36	3.17	15.24	9.71	1.34	75274.30
8	8.31	10.80	57.78	3.05	17.41	9.32	1.35	74109.53
9	9.17	10.82	48.72	2.85	16.83	9.37	1.36	73614.49
10	9.01	10.99	52.02	2.79	17.38	9.45	1.36	75341.92
11	9.54	11.27	52.92	2.90	17.42	9.62	1.36	74581.00
12	7.70	10.94	50.88	2.65	16.41	9.66	1.35	73304.28
13	8.42	11.43	62.94	3.00	18.54	9.34	1.36	75844.94
14	7.99	11.10	56.26	2.68	17.32	9.64	1.36	73872.39
15	7.59	11.29	51.52	2.71	16.54	9.73	1.36	72362.77
16	7.81	11.18	60.70	2.90	17.79	9.49	1.35	76083.92
17	8.14	11.27	66.49	2.95	17.26	10.01	1.36	76861.48
18	8.32	11.42	66.30	3.06	18.10	10.00	1.36	75537.28
19	8.04	11.05	65.28	3.02	18.03	9.71	1.36	76835.97
20	8.14	11.30	67.58	3.02	16.91	10.08	1.36	75569.79
21	7.99	11.16	59.93	2.91	17.45	9.73	1.36	76556.03
22	8.70	11.35	74.80	3.45	18.99	9.86	1.36	75860.03
23	8.49	11.78	59.43	3.23	18.60	9.80	1.36	79717.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.79	11.77	57.66	2.88	17.52	9.62	1.35	74883.46
最大值	10.49	13.57	74.80	3.45	19.20	10.08	1.36	79717.00
發生時間	1	2	22	22	2	20		23
最小值	7.18	10.76	48.72	2.47	15.24	9.06	1.31	72104.95
發生時間	7	7	9	5	7	2		1
零點偏移(率)	-0.07 %	-0.01 %	-0.03 %	-0.01 %		-0.08	-0.01	0.20 %
全幅偏移(率)	0.16 %	-0.31 %	0.75 %	-0.26 %		0.26	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								