

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.30	12.73	48.63	1.39	17.72	11.40	1.07	81557.14
1	8.04	11.29	59.42	1.07	19.07	11.73	1.07	77693.69
2	7.91	2.96	47.45	1.26	19.49	10.97	1.07	83309.17
3	7.86	16.04	53.47	1.71	17.93	11.64	1.06	79775.71
4	7.59	11.06	49.08	1.11	18.69	11.25	1.06	81871.96
5	9.94	16.64	58.32	1.55	18.93	11.76	1.07	74777.80
6	9.33	9.00	47.92	1.52	18.43	11.18	1.07	82174.96
7	6.33	11.37	64.84	1.32	17.59	12.56	1.09	71570.70
8	4.60	8.48	57.01	0.87	18.89	11.47	1.10	79475.66
9	5.17	8.25	45.22	1.60	16.30	11.76	1.08	78546.38
10	5.96	9.62	56.28	1.13	17.42	11.70	1.08	78313.15
11	8.36	13.20	51.47	2.38	15.55	12.19	1.10	73964.85
12	8.28	9.29	57.99	1.43	16.38	11.93	1.10	77461.61
13	9.06	9.95	56.65	2.38	15.29	12.07	1.10	76620.51
14	8.04	9.58	51.75	2.55	15.11	11.95	1.10	75698.90
15	7.86	11.88	48.41	3.33	14.37	11.96	1.09	74995.27
16	7.17	11.33	49.82	2.09	15.44	11.84	1.07	76456.33
17	6.58	11.12	55.26	2.09	15.60	12.06	1.07	76794.01
18	7.95	10.46	55.38	1.39	17.95	11.23	1.09	82961.62
19	5.54	11.47	62.89	1.26	17.37	11.66	1.10	79115.18
20	8.35	13.94	51.02	1.95	16.49	11.53	1.10	81956.07
21	7.62	11.28	52.86	2.78	14.60	12.07	1.10	77172.17
22	9.50	9.66	51.30	2.80	14.52	12.07	1.09	77039.87
23	5.68	13.57	64.38	1.22	17.35	11.95	1.09	77290.51
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.58	11.01	54.03	1.76	16.94	11.75	1.08	78191.38
最大值	9.94	16.64	64.84	3.33	19.49	12.56	1.16	83309.17
發生時間	5	5	7	15	2	7		2
最小值	4.60	2.96	45.22	0.87	14.37	10.97	1.05	71570.70
發生時間	8	2	9	8	15	2		7
零點偏移(率)	-0.02 %	0.00 %	-0.00 %	-0.00 %		0.01		0.00 %
全幅偏移(率)	0.04 %	0.48 %	-0.33 %	0.45 %		-0.04		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.61	3.41	52.27	1.88	16.75	10.15	1.20	82437.40
1	5.68	6.62	63.92	1.52	18.85	10.43	1.20	79584.47
2	3.55	7.80	36.75	3.97	19.19	9.90	1.19	83142.77
3	0.09	11.31	46.14	0.93	19.80	9.87	1.20	82557.06
4	0.93	9.80	42.58	1.01	20.85	9.80	1.20	83937.71
5	5.25	7.30	33.03	2.25	20.00	9.36	1.20	86189.32
6	5.10	7.85	43.73	1.73	20.16	9.86	1.18	86614.32
7	4.13	9.21	45.29	1.49	20.64	9.44	1.18	85104.47
8	1.55	7.32	47.05	1.29	19.74	9.73	1.20	79658.40
9	4.61	6.33	49.40	1.83	17.37	9.51	1.19	78599.56
10	8.28	4.95	59.47	1.28	19.16	9.70	1.22	81638.31
11	7.14	5.77	56.96	1.47	18.82	9.35	1.20	83796.70
12	8.72	8.47	60.07	1.55	18.80	9.37	1.20	81184.09
13	8.34	15.32	61.44	1.91	16.72	9.82	1.20	70912.05
14	9.44	9.02	56.54	2.24	16.08	9.87	1.19	71233.44
15	10.83	12.46	59.68	3.67	16.08	8.84	1.20	85781.16
16	8.80	9.21	54.64	1.95	16.51	9.45	1.20	78789.65
17	10.40	7.12	65.17	2.37	15.81	9.78	1.20	82413.35
18	8.78	5.29	49.07	1.97	15.85	10.27	1.19	79056.20
19	7.80	10.17	47.96	1.62	17.59	9.79	1.18	81027.10
20	6.13	7.17	53.83	1.39	17.98	10.00	1.19	83541.08
21	9.14	15.08	52.47	1.93	16.49	10.20	1.18	81956.66
22	8.87	7.35	47.91	1.70	17.61	9.84	1.18	80379.94
23	7.41	7.75	60.39	1.54	17.19	10.93	1.18	74325.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.65	8.42	51.91	1.85	18.09	9.80	1.19	80994.21
最大值	10.83	15.32	65.17	3.97	20.85	10.93	1.23	86614.32
發生時間	15	13	17	2	4	23		6
最小值	0.09	3.41	33.03	0.93	15.81	8.84	1.18	70912.05
發生時間	3	0	5	3	17	15		13
零點偏移(率)	-0.02 %	-0.01 %	-0.04 %	-0.04 %		0.02		0.00 %
全幅偏移(率)	0.18 %	1.25 %	-0.84 %	0.43 %		-0.14		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.17	12.28	49.69	1.32	15.39	10.97	1.02	77405.20
1	0.41	8.78	53.13	1.28	16.02	10.95	1.02	76564.00
2	3.21	6.89	68.09	0.73	17.49	11.05	1.01	75775.15
3	1.36	10.85	48.28	0.82	17.35	10.51	0.99	81500.80
4	2.73	7.95	45.19	0.78	18.81	10.18	0.99	82247.84
5	4.77	10.70	48.14	0.90	18.30	10.35	0.99	79876.75
6	6.16	13.87	44.51	0.94	18.09	10.33	1.00	81566.95
7	2.31	8.36	51.11	0.91	17.55	11.09	1.04	77758.71
8	0.53	6.84	54.64	0.64	17.87	10.89	0.99	78850.46
9	1.47	6.82	50.97	0.75	17.00	10.58	1.00	80441.82
10	8.18	7.68	56.95	1.54	15.60	11.21	1.04	77521.58
11	7.74	12.20	49.17	2.42	14.60	11.10	1.04	77356.89
12	4.83	8.25	44.31	1.88	15.27	10.53	1.02	73940.17
13	0.22	14.25	41.05	0.97	15.29	10.29	1.03	73240.09
14	0.01	12.90	33.34	0.41	16.74	9.88	1.02	69559.96
15	1.25	9.84	40.93	1.59	14.09	10.44	1.02	74693.71
16	3.72	15.54	40.27	2.17	14.02	10.36	0.98	72697.55
17	4.52	12.24	47.06	2.74	12.61	11.13	0.97	70193.08
18	4.40	10.03	53.49	1.42	15.42	10.72	0.98	74664.79
19	3.61	5.64	57.40	1.31	15.58	10.99	1.01	75464.02
20	3.71	7.94	56.04	1.27	15.76	10.92	1.04	79554.69
21	3.33	13.46	56.51	1.92	14.01	11.29	1.02	76106.84
22	3.01	10.32	55.10	1.13	16.16	10.89	1.02	77834.19
23	0.99	13.35	56.89	0.55	17.79	10.69	0.98	76644.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.07	10.29	50.09	1.27	16.12	10.72	1.01	76727.48
最大值	8.18	15.54	68.09	2.74	18.81	11.29	1.05	82247.84
發生時間	10	16	2	17	4	21		4
最小值	0.01	5.64	33.34	0.41	12.61	9.88	0.95	69559.96
發生時間	14	19	14	14	17	14		14
零點偏移(率)	-0.01 %	0.00 %	-0.07 %	-0.10 %		-0.03		0.00 %
全幅偏移(率)	0.04 %	0.70 %	-0.39 %	0.03 %		0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								